SOUTH DAKOTA PUBLIC UTILITIES COMMISSION CASE NO. EL05-022

IN THE MATTER OF THE APPLICATION BY OTTER TAIL POWER COMPANY

ON BEHALF OF THE BIG STONE II CO-OWNERS

FOR AN ENERGY CONVERSION FACILITY SITING PERMIT FOR THE

CONSTRUCTION OF THE BIG STONE II PROJECT

PREFILED REBUTTAL TESTIMONY

OF

GERALD A. TIELKE

OPERATIONS MANAGER

MISSOURI RIVER ENERGY SERVICES

JUNE 16, 2006

**** PUBLIC, VERSION****



PREFILED REBUTTAL TESTIMONY OF GERALD A. TIELKE

TABLE OF CONTENTS

I.	INTRODUCTION	1
II.	PURPOSE AND SUMMARY OF TESTIMONY	1
III.	NEED FOR AND TIMING OF BASELOAD CAPACITY	2
IV.	FORECASTING	3
V.	DEMAND-SIDE MANAGEMENT (DSM)	4
VI.	RENEWABLES 1	0
VII.	RESOURCE PLANNING 1	0

1		BEFORE THE SOUTH DAKOTAPUBLIC UTILITIES COMMISSION
2		PREFILED REBUTTAL TESTIMONY OF
3		GERALD A. TIELKE
4	I.	INTRODUCTION
5	Q:	Please state you name and business address.
6	A:	Gerald A. Tielke, Missouri River Energy Services, 3724 West Avera Drive, Sioux Falls,
7	South	Dakota.
8	Q:	Did you previously submit testimony in this proceeding?
9	A:	Yes. I submitted direct testimony, Applicants' Exhibit 14.
10	II.	PURPOSE AND SUMMARY OF TESTIMONY
11	Q:	What is the purpose of your testimony?
12	A:	The purpose of my rebuttal testimony is to present the results of the recent capacity
13	expan	sion modeling that Missouri River Energy Services (MRES) completed in May 2006. This
14	model	ing effort also included an analysis of Hutchinson Utility Commission's (HUC) future
15	needs.	Another purpose of my testimony is to respond to some of the statements made by
16	MCE	A witnesses Schlissel and Sommer in their May 26 direct testimony regarding MRES'
17	resour	ce planning efforts.
18	Q:	Please summarize your testimony.

A: The capacity expansion modeling that MRES recently completed confirms that a coal
plant like Big Stone Unit II is the least cost option to MRES for meeting a projected need for 110
MW of additional generating capacity. The modeling also shows that Big Stone Unit II is the
least cost option for addressing a need by HUC for 40 MW of baseload capacity. MRES took

1

PUBLIC, VERSION

into account the possibility of lowering demand by expanding its DSM and conservation efforts
 in these modeling efforts. Witnesses Schlissel and Sommer have made a number of incorrect
 assumptions about MRES's resource planning modeling and other efforts.

4 III. NEED FOR AND TIMING OF BASELOAD CAPACITY

5 Q: At pages 3 to 4 of their May 26 testimony, MCEA witnesses Schlissel and Sommer

6 state that the Applicants do not need additional baseload capacity in 2011. Do you agree?

7 A: No. MRES prepares a resource plan on a periodic basis. The most recent resource plan 8 was filed with the Minnesota Public Utilities Commission (MPUC) in July 2005, and was the 9 source for the information used in developing the Application in this matter. On May 9, 2006 10 MRES filed a Supplement to its Integrated Resource Plan that built upon the resource planning 11 data and assumptions used in the Application and provided, among other things, additional information regarding our capacity expansion modeling. A copy of the Supplement was 12 13 provided to MCEA, et al. at that time. I describe this supplemental data in more detail later in 14 my testimony.

The results of the Supplement analysis confirm the conclusion that MRES needs baseload capacity and that its proposed 110 MW of the Big Stone Unit II project is least cost. This is in addition to obtaining 40 MW of Big Stone Unit II to satisfy the Hutchinson Power Sale Agreement, under which MRES has an obligation to sell, and HUC to purchase, 40 MW of capacity and related energy from the proposed Big Stone Unit II. MRES conducted a separate resource plan analysis for HUC, and submitted it as part of the Supplement.

21 Q: How does MRES know it needs baseload capacity, rather than other sources?

PUBLIC, VERSION

A: MRES has performed a detailed power supply capacity expansion study to examine its
future energy resource needs to test the results against our already extensive modeling exercises
which formed the basis for our participation in the project. This study confirms the need for Big
Stone Unit II's baseload capacity starting in 2011, along with other resources including demandside management (DSM) and renewables.
The MRES capacity expansion study is based on an updated load forecast, and on

estimates of current and feasible DSM activities. Through substantial analysis, a Preferred
Alternative was identified. This Preferred Alternative confirms that baseload power, specifically
110 MW of Big Stone Unit II, is needed to meet growing member demand and is least cost.

10 IV. FORECASTING

11 Q: What are the future capacity and energy requirements for MRES according to its12 forecasts?

A: The 2006 summer peak demand for the MRES member cities is forecasted at 818 MW, of which MRES will be responsible for 418 MW plus 15% planning reserves, or 480 MW. The MRES forecasts estimate that member total demand will grow annually by an average of 1.8% between 2006 and 2010, and by an average of 1.5% between 2010 and 2020. By 2011, MRES will have an expected shortfall of 8 MW of generation capacity, increasing to 230 MW by 2020.

18 The MRES portion of the total energy demand is forecasted to grow at an average annual19 growth rate of 3.6% over the period 2006-2015.

20 MRES also created short-term and long-term load forecasts for HUC. However, MRES 21 and Western Area Power Administration (WAPA) do not serve any portion of HUC, so only the 22 total load of HUC was forecasted. The HUC load forecast uses the same sources as MRES uses

PUBLIC, VERSION

APPLICANTS' EXHIBIT 44

for its Minnesota member load forecasts. The HUC load is reported separately, and is not
 included in any of the total MRES load values reported.

3 Q: Why is the MRES annual energy growth rate so high, when the growth rates for
4 your members are only about half that rate?

5 MRES provides only "supplemental" power and energy service to its members; not their A: 6 entire load. This is service over and above what the members take from other suppliers, 7 primarily the Western Area Power Administration (WAPA). Member contracts with WAPA are 8 for a fixed amount, and do not provide any additional power, but instead decease slightly over 9 As a result, because loads continue to grow, MRES was created to serve this time. 10 "supplemental" need. MRES currently serves about half of the member needs, on average. As a 11 result, the MRES annual energy growth rate, calculated on an MRES base energy amount that is 12 about half that of the members' total energy use, yields an MRES annual growth rate (in %) of 13 about twice that of the members. It is the same annual growth in MWH as the members, but 14 calculated on a smaller, MRES base energy.

15 V. DEMAND-SIDE MANAGEMENT (DSM)

16 Q: MCEA witnesses Schlissel and Sommer advocate the use of demand-side 17 management (DSM) in conducting resource planning. Does MRES consider DSM in its 18 resource plans?

A: Yes. The members of MRES have enacted significant DSM measures. Equally
important, the MRES resource plan includes the accomplishment of a significant amount of new
DSM in future years, in addition to Big Stone Unit II.

22 Q: What has MRES accomplished in DSM to-date?

4

1 A: Our best estimate is that DSM and conservation efforts among MRES members have 2 reduced generation capacity requirements by approximately 57 MW as of 2005. Please explain the ongoing DSM planning efforts of MRES. 3 **Q**: 4 A: MRES has modeled potential DSM additions to allow the capacity expansion software to 5 analyze the direct impact of various levels of additional DSM on supply-side choices, in order to 6 allow DSM to compete directly against supply-side (including renewables) resources in 7 developing the optimal resource mix. The results of this capacity expansion modeling were filed 8 as part of a recent Supplemental filing with the Minnesota PUC on May 8, 2006. 9 To prepare the DSM models, MRES estimated the current amount of DSM, and 10 evaluated the potential for new DSM by its long-term power-supply members. (A separate 11 analysis was performed for HUC.) MRES staff surveyed members, reviewed their most current 12 energy efficiency and conservation reports, and conducted telephone interviews to assess current 13 DSM activities within the membership. Based on this information, the current DSM activities 14 total an estimated 57 MW of demand reduction, and 22,408 MWH per year of energy impact. 15 MRES also retained a consulting firm, Summit Blue, to review the information MRES collected concerning existing DSM activities of MRES members. Based on this information and 16 17 on benchmark data from Minnesota investor-owned utilities, Summit Blue estimated the current 18 saturation amounts for 27 commercial/industrial and 13 residential DSM technologies 19 (programs) likely to be feasible. Summit Blue also estimated the technical potential theoretically

21 they were implemented.

20

5

possible, and the achievable potential most likely to be reached under each program by 2020, if

According to the results of the final Summit Blue study, the potential DSM programs had an estimated total achievable potential of up to 85 MW and 233,250 MWh per year by 2020, at a total cost of almost \$25 million in 2006 dollars. These are potential load reduction impacts in addition to current DSM activities already assumed in the historic and forecasted loads. However, not all of the 40 potential DSM programs were found to be cost-effective when compared against future supply-side options.

MRES used the results of the Summit Blue analysis to group the 40 potential DSM programs into ten DSM Portfolios, each representing between two and seven individual DSM programs. The ten DSM portfolios, and the DSM programs making up those portfolios, were defined as shown in the table below. Also shown are the amounts of additional load reduction expected from each DSM portfolio and the Net Present Value (NPV) in millions of 2006 dollars of the cost of each DSM portfolio.

6

MRES DSM Portfolios						
DSM Portfolios	Class	MW by 2020	GWh by 2020	15-Year NPV		
		[TRADE SE	CRET DATA	BEGINS		
Cooling – Low Cost	R/C/I					
Cooling – High Cost	R/C/I					
Custom Comm. – Low Cost	C/I					
Custom Comm. – High Cost	C/I					
Water Heating – Low Cost	R					
Water Heating – High Cost	R					
Lighting Measures	R/C/I					
Refrigeration	C/I					
Building Envelope	C/I					
Direct Load Control	R/C/I					
		TRADE SECRET DATA ENDS]				
Grand Totals:		85.2 MW	233.2 GWh	\$24.9 M		

We used our Strategist planning model to calculate the least-cost combination of supplyside and DSM resources in each scenario. DSM portfolios were included in the Strategist model as optional resources, freely available for selection by the model as economics dictated. For the Preferred Case scenario results, nine of the ten DSM portfolios were found to be optimal for MRES. By 2020 the resource need is reduced by 82 MW due to the added new DSM. In order to grow to 82 MW of new DSM by 2020, MRES has assumed a constant increase of 6.8 MW per year in DSM programs starting in 2009.

8 Because energy efficiency programs are usually implemented at the retail level, DSM has 9 traditionally been the responsibility of each individual member. Internally, MRES staff has 10 traditionally focused on existing, but loosely-coordinated efforts such as digital infrared 11 thermography, compressed air leak detection and similar, large customer energy efficiency 12 programs.

7

In an effort to bridge the traditional DSM gap between MRES as a wholesale supplier and members as retail DSM providers, the MRES Board of Directors and staff have begun taking additional steps to expand the extent of MRES' involvement with its members in influencing the amounts of DSM. To this end, the MRES Board of Directors created the DSM Task Force, the purpose of which is to evaluate conservation and demand strategies that will allow MRES to achieve the DSM goals identified in the MRES IRP Supplement, and to make recommendations to the Board of Directors regarding implementation of those strategies.

8 Q: What effects do new DSM programs have on the MRES capacity requirements?

9 A: The new DSM programs were chosen by Strategist when calculating the optimum 10 combination of resources, including Big Stone Unit II, renewables, and other options. The 11 effects of the new DSM programs were to reduce the amount of new capacity additions required 12 starting in 2011.

Q: At page 6 of their May 26 testimony, MCEA witnesses Schlissel and Sommer state
that MRES projects an 11 MW capacity surplus, including new DSM, in the peak summer
hours in 2011 without Big Stone Unit II. Do you agree?

A: Their math is correct. The important fact, however, is that MRES is deficit of capacity by 8 MW in 2011 without adding new DSM programs. As described above, the new DSM programs were cost-effective only in the context of a combination of resources including Big Stone Unit II, so the statement by Schlissel and Sommer uses the new DSM amount in the wrong context.

Q: Please explain how MRES included potential DSM programs in the HUC capacity expansion modeling.

A: A separate DSM study was not performed for HUC. Rather, it was assumed that HUC
would have similar DSM characteristics and opportunities as the existing MRES membership.
Because the HUC total load is approximately 15% in size relative to the total load of the MRES
membership excluding HUC, we assumed that the amount of potential DSM effect for HUC
would be equal to 15% of the total DSM potential for MRES members. The same ten DSM
portfolios were used, but sized at 15% of the membership amounts, as shown in the following
table:

HUC DSM Portfolios						
DSM Portfolios	Class	MW by 2020	GWh by 2020	15-Year NPV		
	[TRADE SECRET DATA BEGINS					
Cooling – Low Cost	R/C/I					
Cooling – High Cost	R/C/I					
Custom Comm. – Low Cost	C/I					
Custom Comm. – High Cost	C/I					
Water Heating – Low Cost	R					
Water Heating – High Cost	R					
Lighting Measures	R/C/I					
Refrigeration	C/I					
Building Envelope	C/I					
Direct Load Control	R/C/I					
		TRADE SECRET DATA ENDS]				
Grand Totals:		12.8 MW	35.0 GWh	\$3.74 M		

8 We used the Strategist planning model to calculate the least-cost combination of supply-side and 9 DSM resources in each scenario for HUC. The HUC model was based on the HUC load 10 characteristics and forecasts, as well as the resources owned by HUC, rather than on MRES 11 loads and resources. For the Base Case scenario results, only eight of the ten DSM Portfolios 12 were optimal; High-cost Cooling and Direct Load Control were not optimal. Results were

calculated for HUC under other scenarios as well. The same eight DSM portfolios were also
 found to be optimal in most of the other scenarios considered for HUC.

3 VI. RENEWABLES

4 Q: Describe the status of MRES' efforts in adding renewables to its system.

A: MRES has existing renewable energy resources, and is planning significant renewable resource additions as part of its good faith effort to meet Minnesota's Renewable Energy Obligation (REO) (which effectively requires that MRES meet 10% of our Minnesota load requirements through qualifying renewable technologies). MRES is currently supplied with the wind energy output of four wind turbines at its Worthington, Minnesota, Wind Project. These four turbines have a total nameplate capacity of 3.7 MW.

11 Q: Is MRES in compliance with its REO?

A: In 2005, MRES' renewable energy resources were sufficient to satisfy the requirement
that 1% of total sales to Minnesota members be generated by eligible energy technologies under
the REO. MRES expects to achieve the goal of 10% renewables by 2015.

15 VII. RESOURCE PLANNING

16 Q: Please summarize the results of your Resource Plan and Supplement, including the 17 capacity expansion modeling.

A: The Supplement was based on data and assumptions from the Resource Plan filing, with updated load forecasts and improvements in DSM and renewable modeling. In essence, our capacity expansion analysis using Strategist modeling software has replaced our previous production cost analysis. MRES allowed all resource options to be evaluated in all scenarios, including DSM, wind, coal, combustion turbine, and integrated-gasification combined-cycle

PUBLIC, VERSION

units. Consistent with the Resource Plan, the Supplement covered the period 2006-2020 for all
MRES load, not just the Minnesota members. Emission costs were included in the analysis, at
the environmental cost prices established by the Minnesota PUC. The HUC requirements for
Big Stone Unit II were analyzed separately – i.e., not included in the MRES scenario analysis.

5 Because MRES has committed to a 110 MW share of Big Stone Unit II, several scenarios 6 limited the amount of Big Stone Unit II capacity to 110 MW. Due to the change in modeling 7 software, the commitment to a 110 MW share of Big Stone Unit II, the addition of DSM to the 8 analysis, and the updated load forecast data, the Scenario Analysis results have changed from 9 those in the original Resource Plan.

10 The resulting least-cost, Base Case scenario has a present value cost over 15 years of 11 \$559.8 million in 2005 dollars, and shows that the least-cost amount of Big Stone Unit II for 12 MRES is 155 MW, along with 85 MW of DSM by 2020. Surplus sales revenues were not 13 considered in determining the optional resource mix, so that the resource decision focused on 14 member power supply rather than on potential energy surplus energy sales. The results, shown 15 on the following table do include surplus sales revenues, reflecting the actual expected cost effects once the resource mix was established for each scenario. Several additional scenarios, 16 17 also summarized in the following table, determine the effects of various changes in assumptions 18 in comparison to the Base Case.

MRES Scenario Results Compared to the Base Case							
Scenario Name	BSP II MW	RC MW	CT MW	Wind MW (Accredited)	IGCC MW	DSM MW	Cost vs Base Case
Base Case (least-cost):	155	0	0	0	0	85	
Base Case against which other sco	enarios w	ere com	pared.	•			
Wind: 10% of MN Load (REO)	135	0	15	40 (6)	0	85	+1.1%
40 MW Wind added in 2011, accred	dited at 6 l	MW.					
Wind: 10% of S-1 Load:	130	0	15	80 (12)	0	82	+1.6%
40 MW Wind (accredited at 6 MW)	added in	2011 an	d 40 N	IW in 2014.			
50% Renewable Energy	105	0	15	280(42)	0	85	+4.6%
75% Renewable Energy	60	0	0	760 (114)	0	85	+22.9%
110 MW BSP II, 10% REO for	110	0	45	40 (6)	0	82	+1.9%
MN (Preferred Alternative):							
Limited BSP II to contractual 110 MW and sufficient resources to meet MN REO.							
110 MW BSP II, 10% REO for all	110	0	45	80 (12)	0	82	+2.4
S-1 members:							
Considered the application of MN REO of 10% to all S-1 members.							

1

The revised Preferred Alternative, chosen upon review of the above scenarios, is the least-cost scenario that meets the Minnesota REO, given that MRES has a maximum share of 110 MW of Big Stone Unit II. It is important to point out that the Revised Preferred Alternative also includes 45 MW of future natural gas combustion turbine units, 40 MW of wind, and 82 MW of DSM by 2020.

7 The MRES capacity expansion modeling shows that MRES should obtain ownership in at 8 least 110 MW of the Big Stone Unit II project. This is in addition to obtaining 40 MW of Big 9 Stone Unit II to satisfy the Hutchinson Power Sale Agreement. MRES should also continue to 10 expand its renewable resources to meet the 10% Minnesota REO goal by 2015, by constructing 11 and/or purchasing energy generated by wind, biomass and/or other eligible technologies. 12 Finally, MRES should also implement additional DSM research and development.

PUBLIC, VERSION

Q: Please summarize the results of your Resource Plan for HUC, including the capacity expansion modeling.

A: While HUC is exempt from the Minnesota resource planning requirements, MRES felt that presenting a separate capacity expansion analysis for HUC's need would be useful. Currently, HUC owns no baseload resources, and is entirely dependent on natural gas, fuel oil, and short-term energy purchases for its supply. The MRES analysis showed that obtaining Big Stone Unit II capacity, along with implementing additional DSM, would meet the goals of HUC of obtaining adequate and reliable generation that also reduces HUC's power supply risks related to natural gas supply and market purchases.

10 Q: Why are these capacity-planning results showing a benefit for adding Big Stone 11 Unit for HRC?

A: As I mentioned earlier, HUC currently has no baseload resources. Their existing capacity is fueled by oil and natural gas, and a power supply contract that is due to expire. In a world where natural gas prices are high, and both natural gas and purchased energy prices are potentially very volatile, baseload energy is a preferable offset to energy that would otherwise be purchased or produced by its gas-fired units. So, this is an energy cost situation for HUC, rather than a question of having enough capacity. Simply, they have enough capacity, but the production (energy) costs of that existing capacity are too high.

19 The analysis considered wind in all scenarios as well, but wind was unable to20 successfully compete with other alternatives in the HUC scenarios.

21 Q: Could MRES and HUC use more baseload capacity than their proposed share of 22 Big Stone II?

A: We find that our proposed shares are a good fit for both MRES and HUC. As I noted earlier, our Supplement modeling shows a 155 MW share of Big Stone Unit II would be optimum for MRES, in addition to the amount required for HUC. This is larger than our proposed 110 MW share of the unit. If anything, our modeling shows that we could increase our proposed share. Similarly, our modeling for HUC shows that a 45 MW share of Big Stone Unit II would be optimum for them. This also is larger than their proposed 40 MW share.

7 Q: What do you conclude from the capacity expansion modeling for MRES and HUC?

8 A: We conclude that the best, most cost-efficient plan includes a diverse and balanced mix
9 of optimum levels of conservation, renewables, and baseload resources.

10 Q: At footnote 6 to page 6 of their May 26 testimony, MCEA witnesses Schlissel and 11 Sommer state that the assumption of extreme weather biases MRES' demand forecast to 12 the high side by a significant amount. Do you agree?

A: No. Their suggested alternative, of building capacity only to meet the needs of load conditions under normal weather conditions, would cause capacity shortages whenever a heat wave which exceeds normal conditions came through the system. Basing the capacity expansion plan on normal weather would mean that there would be a 50% chance that MRES would be deficient in capacity during peak periods.

18 The MRES demand forecast corrects for this with the goal of having a demand forecast 19 high enough to predict loads under 90% of historical weather conditions. It should be noted that 20 the energy forecast is still based only on an average weather year. This methodology has been 21 the standard practice of MRES and has been accepted in all past resource plans filed with the 22 Minnesota PUC.

Q: At page 11 of their May 26 testimony, MCEA witnesses Schlissel and Sommer state that none of the Applicants' economic studies reflected any dispatching of the proposed Big Stone II facility, in response to changes in demand or any other factors. Do you agree?

4 A: No. Each of the scenarios considered and submitted by MRES was calculated using a 5 capacity-expansion planning model which used a load duration curve analysis to estimate the 6 amounts of energy production from each resource in detail. Many variables were modeled in 7 calculating the amount of energy production from Big Stone Unit II in the model, including the relative fuel costs of the units, their other operating costs, MRES loads inside and outside of the 8 9 Midwest Independent System Operator footprint, system losses, and how those values changed 10 over the time period of the model. MCEA has had our new information since on or about May 9, 11 2006, when it was filed with the Minnesota PUC.

Q: At pages 23 and 31 of their May 26 testimony, MCEA witnesses Schlissel and Sommer state that all but two of the MRES scenarios assumed some participation in Big Stone II. Do you agree?

No. In fact, in each of the first seven scenarios presented and summarized in Table A-2 15 A: 16 of the MRES Supplement, the amount of Big Stone Unit II would have been allowed to vary to 17 as low as zero MW depending on the capacity expansion software model results. In each of 18 those scenarios a non-zero amount of Big Stone II was selected by the model. In the remaining 19 scenarios, after the first seven, the amount of Big Stone Unit II was pre-selected at 110 MW by 20 design to study other factors such as low or high load growth. In this way the effects of those 21 other factors could be seen given the decision to participate in Big Stone Unit II at the level of 22 110 MW.

1 **Q**: At pages 23 and 31 of their May 26 testimony, MCEA witnesses Schlissel and 2 Sommer state that MRES did not include any non-coal or natural gas alternatives in their 3 evaluation. Do you agree? 4 A: No. Unless explicitly excluded in a given scenario, natural gas-fired combustion 5 turbines, integrated-gasification combined-cycle units, wind units, and DSM were included for 6 evaluation in each scenarios. 7 **O**: In Table 2 of their May 26 testimony, MCEA witnesses Schlissel and Sommer show 8 a cost comparison of coal versus combinations of wind and gas units. Did you examine 9 similar combinations? 10 Yes. The IRP process followed by MRES examined combinations of gas and wind, A: 11 along with combinations of other resource alternatives, in each scenario. This is part of the basic 12 design of the Strategist capacity expansion software. In no scenario was such a combination 13 found to be less expensive than the results presented in the Supplement. 14 In addition, MRES ran some specific cases to mimic the combinations described in Table 15 2 of the Schlissel and Sommer testimony. While Table 2 was based on up to 1200 MW of wind 16 and up to a 480 MW of combined-cycle gas turbine (CCGT), the MRES cases were based on a 17 pro-rata share of those amounts. The pro-rata share was based on the 110 MW MRES share of 18 the proposed Big Stone Unit II out of the total 600 MW planned rating. 19 For this table, MRES assumed that the production tax credit (PTC) will be a levelized \$12 per MWh for ten years, and that all new capacity would require transmission at a cost of 20 21 \$129 per kW in 2005 dollars. The Minnesota PUC published CO2 externalities for a unit outside 22 of the state was assumed, namely zero dollars per ton. For some of these cases MRES assigned 16 Prefiled Rebuttal Testimony of Gerald A. Tielke South Dakota Public Utilities Commission Case No. EL05-022

wind a 25% capacity credit only to mimic the results of the Schlissel and Sommer table; other
than in these calculations, MRES applies a maximum of 15% capacity credit to wind. Based on
MAPP accreditation history, the assumed maximum accreditation credit for wind should not
exceed 15%.

5 Q: What were the results of your comparison?

A: The results shown in the table below compare the wind and CCGT to the MRESPreferred Alternative scenario results.

8

Cost Comparison: Wind/CCNG vs. MRES Preferred Alternative							
Wind MW	Wind Accreditation %	Combined Cycle Natural Gas	Production Tax Credit?	% Increased Cost vs. Preferred Alternative	Increased Cost vs. Preferred Alternative		
800	15%	480	No PTC	+19.2%	\$110M		
1200	15%	420	No PTC	+21.3%	\$122M		
800	25%	400	No PTC	+17.6%	\$100M		
1200	25%	300	No PTC	+18.2%	\$104M		
800	15%	480	With PTC	+7.9%	\$45M		
1200	15%	420	With PTC	+4.7%	\$27M		
800	25%	400	With PTC	+6.3%	\$36M		
1200	25%	300	With PTC	+1.6%	\$9M		

9

10 **Q:** Please explain the results.

11 A: These results show that in all cases the wind and combined-cycle combinations are more 12 expensive than the Preferred Alternative results. This analysis used the Strategist load-duration 13 curve calculation which modeled each month over many years, rather than the much less detailed 14 levelized-cost spreadsheet relied upon by the Schlissel and Sommer testimony. In addition, as

Mr. Koegel and Mr. Morlock discuss in their related testimonies, the cases which rely on 25% capacity accreditation for wind over the summer peak are not realistic for utilities in MAPP. Finally, it should be realized that there is a great deal of uncertainty in the pricing of natural gas and in the availability of the PTC, not to mention the hourly production pattern of wind. So, those alternatives have additional risks beyond the penalties shown on the table.

6 Q: What do the cost penalties on your Cost Comparison table represent?

A: These are direct cost penalties our customers would pay on their electric bills if the
Commission would choose a wind/gas combination to replace Big Stone Unit II.

9 Q: Does this conclude your prepared testimony?

10 A: Yes.

18