

# Deuel County Road Permits

APPLICATION FOR OCCUPANCY  
RIGHT-OF-WAY OF COUNTY ROADS

To: The Board of County Commissioners, Deuel County, South Dakota.

Applications is made by Xcel Energy for Aerial Wire Crossing  
occupancy of Highway Number 309, in Section 6/7, Township 115N,  
Range 47W, Deuel County South Dakota

Project Number: CAPX2020 345 kV transmission line

A sketch showing the location must be attached.

The following information is pertinent to the proposed installation:

- 1. Intended usage transmission of electrical energy - 345 kV
- 2. Cable type 2-556 ACSR 26/7 Twisted Pair Conductors + shield wire
- 3. Outside Diameter or Pipe Size N/A
- 4. Method of installation Steel poles on concrete foundations outside Road ROW - wire crosses only
- 5. Crossing Bituminous Roads Overhead aerial crossing - Plan Attached  
49.2' clearance over Road.

\*This installation will comply with the National Safety Code and all Federal Guidelines.

\*Warning signs will be installed where appropriate.

\*Ditches will be restored back to present condition

\*Owner will move its buried cable or pipe, in case of road construction, at no cost to the County

\*Prior to any road construction or maintenance with the County, the owner shall call South Dakota One-Call at 1 800 781-7474 for location facilities.

Submitted: 3/31/15

Company: Xcel Energy

By Authority, By: Chris Rogers, SELR Agent

Recommended for Approval by: \_\_\_\_\_  
Deuel County Highway Superintendent

Approved: Board of Deuel County Commissioners

By: Steven Rhody Date 4-7-15

W

314

APPLICATION FOR OCCUPANCY  
RIGHT-OF-WAY OF COUNTY ROADS

To: The Board of County Commissioners, Deuel County, South Dakota.

Applications is made by Xcel Energy for Aerial wire crossing  
occupancy of Highway Number 314, in Section 22/27, Township 114N,  
Range 48W, Deuel County South Dakota

Project Number: C9PX0000 345KV transmission line

A sketch showing the location must be attached.

The following information is pertinent to the proposed installation:

1. Intended usage transmission of electrical energy - 345KV
2. Cable type 2-SS6 ASCR 26/7 Twisted Pair 6 conductors + shield wire
3. Outside Diameter or Pipe Size N/A
4. Method of installation Steel poles on concrete foundations outside Road ROW - wire crossing only
5. Crossing Bituminous Roads overhead aerial crossing - Plan Attached  
36.1' wire clearance over Road

- \*This installation will comply with the National Safety Code and all Federal Guidelines.
- \*Warning signs will be installed where appropriate.
- \*Ditches will be restored back to present condition
- \*Owner will move its buried cable or pipe, in case of road construction, at no cost to the County
- \*Prior to any road construction or maintenance with the County, the owner shall call South Dakota One-Call at 1 800 781-7474 for location facilities.

Submitted: 4-1-15

Company: Xcel Energy

By Authority, By: Chris Rogers, S&LR Agent

Recommended for Approval by: \_\_\_\_\_  
Deuel County Highway Superintendent

Approved: Board of Deuel County Commissioners

By: Steven Rhoody Date 4-7-15

375

APPLICATION FOR OCCUPANCY  
RIGHT-OF-WAY OF COUNTY ROADS

To: The Board of County Commissioners, Deuel County, South Dakota.

Applications is made by Xcel Energy for Aerial wire crossing  
occupancy of Highway Number 375, in Section 6/7, Township 114N,  
Range 47W, Deuel County South Dakota

Project Number: CapX2020 345KV transmission Line

A sketch showing the location must be attached.

The following information is pertinent to the proposed installation:

1. Intended usage transmission of electrical energy - 345KV
2. Cable type 2-556 ACSR 26/7 Twisted Pair 6 conductors + shield wire
3. Outside Diameter or Pipe Size N/A
4. Method of installation steel poles on concrete foundations outside Road ROW - wire crossing only
5. Crossing Bituminous Roads Overhead aerial crossing - Plan Attached  
63.2' clearance over Road.

\*This installation will comply with the National Safety Code and all Federal Guidelines.

\*Warning signs will be installed where appropriate.

\*Ditches will be restored back to present condition

\*Owner will move its buried cable or pipe, in case of road construction, at no cost to the County

\*Prior to any road construction or maintenance with the County, the owner shall call South Dakota One-Call at 1 800 781-7474 for location facilities.

Submitted: 4-1-15

Company: Xcel Energy

By Authority, By: Chris Rogers, SELR Agent

Recommended for Approval by: \_\_\_\_\_  
Deuel County Highway Superintendent

Approved: Board of Deuel County Commissioners

By: Steven Rhody Date 4-7-15

513

APPLICATION FOR OCCUPANCY  
RIGHT-OF-WAY OF COUNTY ROADS

To: The Board of County Commissioners, Deuel County, South Dakota.

Applications is made by Xcel Energy for Aerial wire crossing  
occupancy of Highway Number 513, in Section 23/24, Township 116N,  
Range 47W, Deuel County South Dakota 14/13 Glenwood Township  
Project Number: CapX2020 345KV TRANSMISSION LINE

A sketch showing the location must be attached.

The following information is pertinent to the proposed installation:

1. Intended usage transmission of electrical energy - 345KV
2. Cable type 2-556 ACSR 26/7 Twisted Pair 6 conductors + shield wire
3. Outside Diameter or Pipe Size N/A
4. Method of installation steel poles on concrete foundations outside Road ROW - wire crossing only
5. Crossing Bituminous Roads overhead aerial crossing - Plan Attached

- \*This installation will comply with the National Safety Code and all Federal Guidelines.
- \*Warning signs will be installed where appropriate.
- \*Ditches will be restored back to present condition
- \*Owner will move its buried cable or pipe, in case of road construction, at no cost to the County
- \*Prior to any road construction or maintenance with the County, the owner shall call South Dakota One-Call at 1 800 781-7474 for location facilities.

Submitted: 3/31/15

Company: Xcel Energy

By Authority, By: Chris Rogers, SCLR Agent

Recommended for Approval by: \_\_\_\_\_  
Deuel County Highway Superintendent

Approved: Board of Deuel County Commissioners

By: Steven Rhody Date 4-7-15

APPLICATION FOR OCCUPANCY  
RIGHT-OF-WAY OF COUNTY ROADS

To: The Board of County Commissioners, Deuel County, South Dakota.

Applications is made by Xcel Energy for Aerial wire crossing  
occupancy of Highway Number 519, in Section 23/24, Township 114 N,  
Range 48 W, Deuel County South Dakota

Project Number: CapX2020 345KV transmission line

A sketch showing the location must be attached.

The following information is pertinent to the proposed installation:

1. Intended usage transmission of Electrical Energy - 345KV
2. Cable type 2-556 ACSR 26/7 Twisted Pair 6 conductors + shield wire
3. Outside Diameter or Pipe Size N/A
4. Method of installation steel poles on concrete foundations outside Road ROW - wire crossing only
5. Crossing Bituminous Roads Overhead aerial crossing - Plan attached.  
61.7' Clearance over Road

\*This installation will comply with the National Safety Code and all Federal Guidelines.

\*Warning signs will be installed where appropriate.

\*Ditches will be restored back to present condition

\*Owner will move its buried cable or pipe, in case of road construction, at no cost to the County

\*Prior to any road construction or maintenance with the County, the owner shall call South Dakota One-Call at 1 800 781-7474 for location facilities.

Submitted: 4/1/15

Company: Xcel Energy

By Authority, By: CHRIS ROGERS, S&LR Agent

Recommended for Approval by: \_\_\_\_\_  
Deuel County Highway Superintendent

Approved: Board of Deuel County Commissioners

By: Steven Rhody Date 4-7-15