

**BLACK HILLS POWER, INC.**  
SD PUC DOCKET: EL14-061

REQUEST DATE : August 21, 2014

RESPONSE DATE : September 17, 2014

REQUESTING PARTY: SDPUC Staff

---

**SDPUC Request No. 24:**

On page 37 of the Application, the Applicant details a 100' ROW on public lands and 125' ROW on private lands. Please provide an explanation for the different ROW widths.

**Response to SDPUC Request No. 24:**

Public lands are less likely to experience development under and near the line. Increased width on private lands helps to reduce encroachments, structures within right of way, and increase clearance to obstructions.

**Attachments:** None