

**From:** Tim Praska <tpraska@bradley-cm.com>

**Sent:** Thursday, October 3, 2019 9:33 AM

**To:** Trevor Sholly <tsholly@lincolnclean.com>; Evan McCausland <EMcCausland@lincolnclean.com>; Brandon Denne <bdenne@lincolnclean.com>; Udit Goyal <ugoyal@lincolnclean.com>; Diego Ramirez <dramirez@lincolnclean.com>

**Cc:** Holly Wilson <hwilson@bradley-cm.com>; John Telecky <jtelecky@bradley-cm.com>

**Subject:** FW: Willow Creek Wind Farm Fuel Tank Storage on Site

See comments below regarding requireds Cert or Permit for Willow Creek.

TAP

Tim A. Praska

mobile: 480-800-9152

email: [tpraska@bradley-cm.com](mailto:tpraska@bradley-cm.com)

[www.bradley-cm.com](http://www.bradley-cm.com)

Bradley Construction Management

1412 Main Street, Suite 405

Dallas, Texas 75202



From: "Chance Hershey" <[CHershey@cbhcoop.com](mailto:CHershey@cbhcoop.com)>

To: "[Rbustamante@fageninc.com](mailto:Rbustamante@fageninc.com)" <[Rbustamante@fageninc.com](mailto:Rbustamante@fageninc.com)>

Cc: "Amanda Maine" <[AMaine@cbhcoop.com](mailto:AMaine@cbhcoop.com)>

Date: 10/03/2019 09:08 AM

Subject: Willow Creek Wind Farm

---

To whom it may concern,

We (CBH Co-op) loaned two tanks to Fagen Inc. for use at the Willow Creek Wind Farm project approximately 13 miles East of Newell, SD. Fagen Inc. constructed a large, earthen, lined containment that appears to be more than adequate to contain the largest tank in the containment, which is a 2000 gallon tank, plus at least 10%. They also have spill kits on site. This meets guidelines for Federal SPCC plans.

Based on conversations with Zachary Burgraff, a Natural Resources Engineer with the South Dakota Environment and Natural Resources, the tanks do not need to be registered with the State of South Dakota for the following reasons:

1. This is a temporary fueling site
2. The fuel at this site is used on-location and doesn't leave the site.

I am of the opinion that all rules and regulations are being followed for this jobsite.

**Chance Hershey**

**COO/Director of Refined Fuels**

**(605)720-2946 Ext. 906**

