

**Montana-Dakota Utilities Co. Peak Customer Load and Annual Energy Requirements
 1985-2014**

	Annual Energy Requirements (MWh)	Summer Peak Load (MW)	Winter Peak Load (MW)
1985	1,834,294	350	331
1986	1,751,503	338	324
1987	1,716,377	359	293
1988	1,834,232	387	306
1989	1,828,665	384	321
1990	1,788,854	382	342
1991	1,836,243	387	330
1992	1,827,866	339	312
1993	1,870,268	350	334
1994	1,934,561	370	323
1995	1,952,872	413	349
1996	2,014,830	393	343
1997	2,005,195	405	333
1998	2,007,534	403	354
1999	1,996,647	421	342
2000	2,077,579	432	354
2001	2,104,119	453	329
2002	2,158,431	459	344
2003	2,226,531	471	368
2004	2,204,012	458	384
2005	2,327,117	459	387
2006	2,397,793	486	397
2007	2,510,540	526	407
2008	2,596,990	477	455
2009	2,593,368	474	460
2010	2,718,192	503	458
2011	2,776,082	536	511
2012	2,919,752	574	516
2013	3,115,064	547	582
2014	3,250,683	533	557

Montana-Dakota Utilities Co. Peak Customer Load and Annual Energy Requirements 1985-2014

