

Docket Number: EL17-049
Subject Matter: First Data Request
Request to: Sioux Valley-Southwestern Electric Cooperative, Inc. dba Sioux Valley Energy and Lyon Rural Electric Cooperative, Inc.
Request from: South Dakota Public Utilities Commission Staff
Date of Request: December 22, 2017
Responses Due: January 10, 2018

- 1-1. Please confirm whether all future additions for this customer or his successors at this location, such as outbuildings, will fall under this agreement.

Lyon Rural Electric Cooperative will supply all future single phase additions for this member or his successors at this location. The territory exception would be revisited if this member required three phase service at some point in the future.

- 1-2. What would be the customer's contribution to the line extension for each company?

Lyon Rural Electric Cooperative has no required contribution in aid of construction for new permanent facilities. Therefore, no contribution in aid of construction will required.

Sioux Valley Energy would require a CIAC of approximately \$9,200 for this new home.

- 1-3. What distance are LREC's facilities from the new home?

Lyon Rural Electric Cooperative has a primary underground conductor on the south side of 268th Street and primary underground conductor on the west side of the existing driveway which will require 186' to serve the new home.

Sioux Valley Energy's facilities are along 268th street but they are approximately 2,500 feet west or 3,400 feet east of the new home.

- 1-4. The Lyon Rural Electric Staking Sheet attached to the map identifies the new house as in Township 100 North. Please confirm whether this should say Township 101 North.

Lyon Rural Electric Cooperative erred on it's Staking Sheet. The correct location is Township 101 North.