

LAW OFFICES

**Lynn, Jackson, Shultz & Lebrun, P.C.**

LAWYERS ALSO ADMITTED IN MINNESOTA, IOWA, NORTH DAKOTA, AND WYOMING

[www.lynnjackson.com](http://www.lynnjackson.com)

Member of Lex Mundi

A Global Association of 125 Independent Law Firms

135 E. COLORADO BOULEVARD

SPEARFISH, SD 57783-2755

605-722-9000

FAX 605-722-9001

909 ST. JOSEPH STREET

SUITE 800

RAPID CITY, SD 57701-3301

605-342-2592

FAX 605-342-5185

110 N. MINNESOTA AVENUE

SUITE 400

SIoux FALLS, SD 57104

605-332-5999

FAX 605-332-4249

REPLY TO: Sioux Falls 605-332-5999

***From the office of Miles F. Schumacher***

*e-mail address: [mschumacher@lynnjackson.com](mailto:mschumacher@lynnjackson.com)*

May 3, 2019

**Via Electronic Filing**

Ms. Patricia Van Gerpen  
Executive Director  
South Dakota Public Utilities Commission  
500 East Capitol Avenue  
Pierre, SD 57501

Re: In the Matter of the Application of Crowned Ridge Wind, LLC  
for a Facility Permit to Construct a 230kV Transmission Line  
Docket EL17-050

Dear Ms. Van Gerpen:

In accordance with paragraph 30 of the Terms and Conditions of the Settlement Stipulation approved by the South Dakota Public Utilities Commission ("Commission") and included as part of its November 21, 2018, Order Granting Joint Motion for Approval of Settlement Stipulation; Order Approving Settlement Stipulation and Order Granting Permit to Construct Transmission Facility and Notice of Entry ("Order") in the above-referenced docket, Crowned Ridge Wind, LLC ("Crowned Ridge") submits the enclosed documents:

1. Transmission Line Plan and Profile (Parts 1 and 2);
2. Final Site Plan; and
3. Certificate of Service.

The centerline has shifted from what was filed as the centerline along with the Motion for Approval and Acceptance of Circuit Change in three specific locations to accommodate utility locates typically completed immediately prior to construction and a recent South Dakota Department of Transportation (SD DOT) highway widening project the Applicant recently learned about. In the first instance, the centerline shifted between structures 27

Ms. Patricia Van Gerpen  
May 6, 2019  
Page 2

and 30 to maintain a 25-foot setback from an existing Grant County Rural water line. In the second instance, the centerline between structures 92 and 100 approximately 25 feet east to accommodate a planned SD DOT highway widening in their ROW. In the third instance, the centerline shifted 31 feet southwest to accommodate an existing Whetstone Valley underground distribution line and field verified wetland constraint. In all cases, shifts were minor (all less than 31 feet) and remain within the Project Corridor. In addition, the majority of changes resulted in shorter structures with reduced foundation footprints that ultimately reduce the overall environmental impact.

If you have any questions, please contact me.

Yours very truly,

LYNN, JACKSON, SHULTZ & LEBRUN, P.C.



Miles F. Schumacher

MFS:kab

cc: Brian Murphy