

Exhibit B

Summary of Turbine Shifts greater than 325 feet from December 15, 2017 Facility Permit Layout

Turbine Number	Turbine Shift Distance (ft)	Turbine Shift Direction	Distance to nearest residence (ft) ¹	Type of Residence	Max Sound Level modeled at nearest residence (dBA) ²	Shadow Flicker modeled at nearest residence (hours/year) ³	Distance to nearest Road (ft) ⁴	Distance to nearest Cemetery (ft) ⁵	Distance to nearest non-participating parcel (ft) ⁴
19	546	E	2,842	Participating	46	10.1	2,915	21,116	1,448
23	339	SW	4,103	Non-Participating	41	3.0	5,340	27,824	3,712
69	430	SW	4,192	Non-Participating	40	0.0	1,243	12,694	1,293
155	526	SW	2,775	Participating	45	19.3	1,382	12,488	1,897
178	463	S	3,736	Participating	48	14.9	3,108	12,691	2,279
220	803	W	2,084	Participating	47	10.3	847	17,520	4,476

¹ Setback requirements – 3,960 feet from non-participating residences; 1,000 feet from participating residences
² Max sound level for all residences: 50 dBA at a participant and 41 dBA at a non-participant
³ Max shadow flicker hours/year at all residences: 19.3 at a participant and 5.4 at a non-participant
⁴ Setback requirements – 550 feet
⁵ Setback requirements – 5,280 feet