

## EXHIBIT B

**Summary of Turbine Shifts within 325 feet from December 15, 2017 Facility Permit Layout**

Turbine Number	Turbine Shift Distance (ft)	Turbine Shift Direction	Distance to nearest residence (ft) <sup>1</sup>	Type of Residence	Max Sound Level modeled at nearest residence (dBA) <sup>2</sup>	Shadow Flicker modeled at nearest residence (hours/year) <sup>3</sup>	Distance to nearest Road (ft) <sup>4</sup>	Distance to nearest Cemetery (ft) <sup>5</sup>	Distance to nearest non-participating parcel (ft) <sup>4</sup>
7	322	NW	8,254	Non-Participating	40	0.0	2,962	12,065	3,041
15	106	E	4,377	Participating	47	8.4	4,534	18,648	1,757
71	92	NW	5,336	Non-Participating	40	0.0	3,991	15,377	1,973
87	323	NE	6,229	Non-Participating	41	3.0	7,047	30,062	2,052
88	280	NE	6,528	Non-Participating	41	3.0	5,948	31,371	742
91	50	N	3,934	Participating	46	9.0	4,179	19,953	1,611
93	220	SE	3,708	Participating	46	16.3	3,600	17,247	1,388
102	10	N	4,251	Non-Participating	40	0.0	802	36,786	6,07
158	206	S	3,165	Participating	46	16.3	1,301	18,353	626
180	10	S	2,118	Participating	48	14.9	566	14,962	1,934
187	269	NE	5,340	Participating	47	11.1	4,839	10,365	574
189	151	W	8,746	Participating	47	11.1	2,530	7,863	2,179
197	212	SW	4,084	Participating	47	11.1	2,718	13,024	3,828
198	264	W	2,889	Participating	47	11.1	1,847	13,595	3,942
210	98	W	6,166	Non-Participating	39	1.6	886	15,361	851
214	145	W	5,987	Participating	43	0.0	862	26,622	972
215	49	NE	2,942	Participating	50	2.5	3,408	21,859	1,851
216	101	W	2,104	Participating	50	2.5	2,444	22,129	995
218	269	SW	1,087	Participating	50	2.5	1,012	21,714	748
221	1	W	3,288	Participating	47	10.3	3,390	19,113	1,941

<sup>1</sup> Setback requirements – 3,960 feet from non-participating residences; 1,000 feet from participating residences  
<sup>2</sup> Max sound level for all residences: 50 dBA at a participant and 41 dBA at a non-participant  
<sup>3</sup> Max shadow flicker hours/year at all residences: 19.3 at a participant and 5.4 at a non-participant  
<sup>4</sup> Setback requirements – 550 feet  
<sup>5</sup> Setback requirements – 5,280 feet