

EXHIBIT B

Summary of Turbine Adjustment Requirement Compliance

Turbine ID (LAY 045)	Turbine ID (LAY 043)	LAT	LONG	Turbine Shift Distance (ft.)	Turbine Shift Direction	Distance to nearest residence (ft.) ¹	Type of residence	Max Sound Level modeled at nearest residence (dBA)	Shadow Flicked modeled at nearest residence	Distance to nearest road (ft.) ²	Distance to nearest Cemetery (ft.)	Distance to nearest non-participating parcel (ft.) ²	Distance to Punished Woman's Lake (ft.) ³
43a	43	45.197182	96.97312	34.4	East	7,759	House	39	4:14	1,125	1,315	560	29,864
¹ Setback requirements – 1,000 feet from non-participating residences; 500 feet from participating residences ² Setback requirements – 541 feet ³ Setback requirements – 2 miles from the shoreline of Punished Woman's Lake													