

Applicant's and Staff's Revised Joint Proposed Condition 29 and New Joint Proposed Condition, Docket No. EL18-026

29. Not less than 30 days prior to commencement of construction work in the field for the Project, Applicant will provide to Commission staff the following information:

- a) the most current preconstruction design, layout, turbine model and plans;
- b) a sound level analysis showing compliance with the applicable sound level requirements;
- c) a shadow flicker analysis showing the anticipated shadow flicker levels will not exceed 30 hours per year and/or 30 minutes per day at any non-participating residence and an affidavit from the Applicant identifying the turbine numbers that will be operationally controlled in order to meet the shadow flicker requirements;
- d) such additional Project preconstruction information as Commission staff requests; and
- e) should Applicant decide at a later point to use a different lower megawatt turbine model, it shall provide the information required in parts a-d above. Applicant shall also demonstrate that in selecting locations for the small turbines, it considered how to reduce impacts on non-participating landowners.

New: Should any installed wind turbine not be operated for a consecutive 12-month period, Applicant shall remove and decommission the non-operating turbine within the subsequent 12-month period.