



500 East Capitol Avenue Pierre, South Dakota 57501-5070 www.puc.sd.gov (605) 773-3201

Consumer Hotline 1-800-332-1782

Email puc@state.sd.us

September 3, 2019

Patricia Van Gerpen Executive Director SD Public Utilities Commission 500 E. Capitol Ave. Pierre, SD 57501

## RE: Information on Prevailing Wind Park Turbine 8 Material Deviation, Docket EL18-026

Dear Ms. Van Gerpen,

After reviewing the material deviation request for turbine 8 filed by Prevailing Wind Park on August 6, 2019, Staff did not have any concerns with the turbine shift due to (1) the turbine shift remaining in compliance with permit conditions and (2) the expected minimal change in impact to the closest non-participating receptor. Therefore, Staff did not request further review of the material deviation in accordance with Condition 23.

The closest non-participating receptor to turbine 8 is Mr. Fuerniss. In response to Mr. Fuerniss' comments regarding the material deviation of turbine 8 submitted on August 30, 2019, Staff provides a summary of the expected impacts to Mr. Fuerniss below.

Expected Change to Receptor 68 (Fuerniss)		
	Before	After
Noise	35.8 dba	36.1 dba
Shadow Flicker	3.13 hours	7.28 hours
<b>Turbine 8 Distance</b>	4,691 ft	4,257 ft
Nearest Turbine Distance	4,059 ft	4,059 ft

Expected Change to Receptor 69 (Fuerniss)			
	Before	After	
Noise	36.0 dba	36.2 dba	
Shadow Flicker	3.20 hours	7.53 hours	
Turbine 8 Distance to Receptor	4,579 ft	4,134 ft	
<b>Turbine 8 Distance to Property Line</b>	2,456 ft	1,968 ft	
Nearest Turbine Distance	3,845 ft	3,845 ft	

Also attached to this letter is an aerial image of Mr. Fuerniss' closest receptor and the turbine 8 shift, providing a visual of the distance impacts due to the shift of turbine 8.

## /s/ Kristen N. Edwards

Kristen N. Edwards
Staff Attorney
South Dakota Public Utilities Commission
500 East Capitol Avenue
Pierre, SD 57501
Phone (605)773-3201
Kristen.edwards@state.sd.us