

LAW OFFICES

Lynn, Jackson, Shultz & Lebrun, P.C.

LAWYERS ALSO ADMITTED IN MINNESOTA, IOWA, NORTH DAKOTA, AND WYOMING

www.lynnjackson.com

Member of Lex Mundi

A Global Association of 125 Independent Law Firms

135 E. COLORADO BOULEVARD

SPEARFISH, SD 57783-2755

605-722-9000

FAX 605-722-9001

909 St. JOSEPH STREET

SUITE 800

RAPID CITY, SD 57701-3301

605-342-2592

FAX 605-342-5185

110 N. MINNESOTA AVENUE
SUITE 400
SIOUX FALLS, SD 57104
605-332-5999
FAX 605-332-4249

REPLY TO: Sioux Falls 605-332-5999

From the office of Miles F. Schumacher

e-mail address: mschumacher@lynnjackson.com

July 29, 2019

Via Electronic Filing

Ms. Patricia Van Gerpen
Executive Director
South Dakota Public Utilities Commission
500 East Capitol Avenue
Pierre, SD 57501

Re: Docket #EL19-003
Application to the SD PUC for a Facility Permit to Construct
A 300 megawatt Wind Facility

Dear Ms. Van Gerpen:

Pursuant to Condition No. 41 (a)(b) and (c), Crowned Ridge Wind LLC (Crowned Ridge) submits its 30 day prior to construction compliance filings. Crowned Ridge plans to start construction on August 29, 2019.

Based on the final sound report, Crowned Ridge notes that turbine CR-49 has been permanently dropped from the array to ensure compliance with the sound requirements under all construction of turbine scenarios.

Based on the final sound report, Crowned Ridge Wind, II LLC (Crowned Ridge II) will file a letter explaining that turbine CR11-126 has been removed to ensure compliance, and will only be used if receptor CR1-C11-NP, who is actually in the Crowned Ridge II footprint, becomes a participant. Crowned Ridge II will also shift turbine CR11-133 50 feet to the east to ensure Crowned Ridge is in compliance with sound requirements.

Turbine CR-Alt 22 was been shifted approximately 33 feet to the south for constructability purposes.

Ms. Patricia Van Gerpen
July 29, 2019
Page 2

Last, turbine CR-16 is a Hessler alternate turbine. In the event this alternate turbine location is allowed as a primary turbine location consistent with Condition No. 27, turbine CR-16 will be curtailed for 13 hours on an annual basis to ensure shadow flicker is below the 30 hr/year threshold at receptor CR1-C61-NP

Thank you.

Yours very truly,

LYNN, JACKSON, SHULTZ & LEBRUN, P.C.



Miles F. Schumacher
MFS:kab
Enclosure