

OTTER TAIL POWER COMPANY

Docket No: EL21-001

Response to: SD Public Utilities Commission

Analyst: Staff

Date Received: January 15, 2021

Date Due: January 29, 2021

Date of Response: January 29, 2021

Responding Witness: David G. Prazak, Supervisor, Pricing- (218) 739-8595

---

Data Request:

Is Otter Tail able to meter all energy consumed by its Small Power Producer customers (including energy self-generated and consumed) separate from all the energy that is self-generated (including energy self-generated and consumed)? Explain.

Attachments:

Response:

Yes. In order to meet this requirement OTP must install two meters. One to measure energy delivered to the customer and energy received at the point of interconnection. A second meter is installed near the Distribution Resource to measure energy delivered to the Distribution Resource and energy received from the Distribution Resource.