

OTTER TAIL POWER COMPANY

Docket No: EL21-015

Response to: SD Public Utilities Commission

Analyst: SD PUC Staff

Date Received: May 21, 2021

Date Due: June 04, 2021

Date of Response: June 11, 2021

Responding Witness: Jason A. Grenier, Manager Market Planning - (218) 739-8639

---

Data Request:

Refer to the chart on the top of page 5 of the Status Report.

- a. Provide the incremental energy and demand savings for the 12 new participants this last year.
- b. Why does “Actual Savings at the Generator” equal what was shown in docket EL20-016 if there were 12 participants added this last year? Revise if necessary.

Attachments: 0

Response:

- a. The 12 new participants in the air conditioning control program account for 372.13 kWh and 8.874 kW in savings. Since each participant has the same energy and demand savings associated with it and there was a reduction of 12 participants from the program it resulted in an incremental energy and demand savings of 0.
- b. Each participant has the same amount of energy and demand savings. There were 12 new participants added in 2020, however, there was also a reduction of 12 participants. This resulted in the “Actual Savings at the Generator” to equal what was shown in EL20-016.