

- Not-Public Document – Not For Public Disclosure
- Public Document – Not-Public Data Has Been Excised
- Public Document

Xcel Energy Data Request No. 2-2
Docket No.: EL23-032
Response To: South Dakota Public Utilities Commission Staff
Requestor: Joseph Rezac
Date Received: February 29, 2024

Question:

How is the maximum 300 hours calculated? By total control event time, or by total minutes the load is actually interrupted?

Response:

The maximum 300 hours is calculated by the duration of the control event(s). For example, the Company could control for one hour for 300 days or 4 hours for 75 days.

Preparer: Patrik Ronnings
Title: Sr Product Portfolio Manager
Department: Demand Management
Telephone: (612) 330-5787
Date: March 8, 2024