



Gary Hanson, Chair
Steve Kolbeck, Vice Chair
Dustin Johnson, Commissioner

SOUTH DAKOTA PUBLIC UTILITIES COMMISSION

500 East Capitol Avenue
Pierre, South Dakota 57501-5070
www.puc.sd.gov

Capitol Office
(605) 773-3201
1-866-757-6031 fax

Warehouse
(605) 773-5280
(605) 773-3225 fax

Consumer Hotline
1-800-332-1782

December 4, 2008

Ms. Patricia Van Gerpen, Executive Director
South Dakota Public Utilities Commission
500 E. Capitol Avenue
Pierre, SD 57501-5070

RE: PS08-004

Dear Ms. Van Gerpen:

This letter will serve to file some additional facts regarding the low income housing facility that may be of use in reaching a decision. Those facts are:

1. There are 23 tenants in seven buildings that use propane heat.
2. Four propane tanks manifolded together serve four buildings each containing four apartments.
3. Three propane tanks manifolded together serve three buildings containing a total of seven apartments and one community room and one laundry facility.
4. The system is pre-code as it was installed in 1967.
5. There are no meters on the system.
6. One furnace supplies heat to every two apartments.

Sincerely,

Nathan Solem
Acting Pipeline Safety Program Manager