

Certification of Functionality in Emergency Situation

Golden West Telecommunications Cooperative, Inc. (hereinafter “The Company”) hereby certifies that it is able to function in emergency situations as set forth in §54.202(a)(2).¹ The Company’s critical network infrastructure is designed to remain functional in emergency situations without an external power source, is able to reroute traffic around damaged facilities, and is capable of managing traffic spikes resulting from emergency situations as required by Section 54.202(a)(2). The Company can take reasonable steps to reroute traffic around damaged facilities and manage traffic spikes throughout its network, as emergency situations require.

Specifically, each central office building is supplied with standby generators and battery back-up that enable the central office to keep running until power is restored so long as fuel is available and the facility can be safely accessed, or until system changes are made to reroute traffic.

¹ Section 54.202(a)(2) requires ETCs that are designated by the Commission to “demonstrate its ability to remain functional in emergency situations, including a demonstration that it has a reasonable amount of back-up power to ensure functionality without an external power source, is able to reroute traffic around damaged facilities, and is capable of managing traffic spikes resulting from emergency situations.”