



Fergus Falls, Minnesota

Section 4.14 COMBINED METERING

Combined Metering is defined as the addition of multiple service or metering points so that the Energy and Demand is registered on one Meter. This results in coincident Demand for these loads, thus treating it as one larger load for billing one rate. To qualify for Combined Metering a Customer must be served at a service location consisting of contiguous property with the same occupant and each service entrance to be combined must have a minimum entrance rating of 750 kVa (750 kVa entrance at various voltages which is equivalent to: 900 amps @ 277/480; 1800 amps @ 120/240 delta; 2100 amps @ 120/208 wye). Combined Metering can be accomplished with hardware or software totalizers or by installing primary metering. The Company will, in its sole discretion, reasonably determine whether to use primary metering or totalizing for any particular Customer that qualifies for Combined Metering.