

**EL 18-003 Dakota Range
Amendments Proposed by Commissioner Nelson
To Applicants' Recommended Permit Conditions**

1. In Section 11 prior to "NRHP" insert "National Register of Historic Places" and put parenthesis around "NRHP".
2. In Section 27, delete "Unless operational or maintenance changes result in a reasonable assumption of higher turbine sound levels than modeled, such requests for field surveys or post-construction monitoring data shall be limited to situations where complaints have been made by landowners whose homes had a modeled sound level of 40 dBA or higher based on the Sound Level Modeling Report in Appendix I of the Applicant's Application, or any subsequent iteration thereof provided pursuant to Paragraphs 22 or 28(c)."
3. In Section 27, in the second to the last sentence delete "reasonably" and "and".
4. In Section 32, delete "in the manner they choose" and replace with "on the Commission website."
5. In Section 38, amend the second to the last sentence following "assurance" insert "consistent with the provisions in Section 37 of the EL-17-055 permit conditions".
6. Section 40 will be a public condition, not a confidential condition.
7. In Section 40, add "The project owner will pay for any documented damage caused by ice thrown from a turbine."
8. Add New Section "Applicant shall utilize an Aircraft Detection Lighting System."