

- 3-1) Does Crowned Ridge Wind, LLC participate in the MISO Dispatchable Intermittent Resource (DIR) protocol?

**Response:** Crowned Ridge Wind, LLC ("Crowned Ridge") objects to Data Request 3-1, as it seeks information that is not relevant to the complaint proceeding. Subject to and without waiving this objection, Crowned Ridge responds: Yes.

Stefan J. Martinsen, NextEra Energy Resources, LLC Regional Wind Site Manager, Wind Operations – Midwest Center Region.

- 3-2) Does Crowned Ridge Wind, LLC ever manually curtail, downward dispatch, or ramp down any wind turbines in the CRW project? If yes, please provide documentation of any such events during the sound study period of November 2, 2021 through November 18, 2021. Specify the event (curtailment, downward dispatch, ramping down, and any other event which would provide similar electrical retardation of output). Provide the duration, date and times of any such events. Provide the reason for any such events.

**Response:** Crowned Ridge objects to Data Request 3-2 as it is not limited in time. Subject to and without waiving this objection, Crowned Ridge responds: Yes. Attachment A to Data Request 3-2 identifies the manual shutdowns during the sound study period.

Stefan J. Martinsen, NextEra Energy Resources, LLC Regional Wind Site Manager, Wind Operations – Midwest Center Region.

- 3-3) When automatic curtailments are implemented by MISO via SCADA, (a) how is Crowned Ridge Wind notified and (b) does such curtailment and/or notification of curtailment require a response by CRW to MISO?

**Response:** Crowned Ridge objects to Data Request 3-3 as it is not limited in time and not relevant to the complaint proceeding. Subject to and without waiving these objections, Crowned Ridge responds: (a) ) Crowned Ridge is not notified about curtailments as such curtailments are automatically implemented by MISO; and (b) no response is required to be provided by Crowned Ridge to MISO in the event of a MISO imposed curtailment.

Stefan J. Martinsen, NextEra Energy Resources, LLC Regional Wind Site Manager, Wind Operations – Midwest Center Region.

- 3-4) During the 2021 sound study, were MISO curtailments, downward dispatches, ramping down events, automatically restarted by MISO? Were any of the MISO events manually

restarted by CRW? If so, provide dates, times, and details related to the ramping up of each turbine.

**Response:** During the 2021 sound study, MISO curtailments, downward dispatches, or ramping down events, no Crowned Ridge wind turbines were automatically restarted by MISO. During the sound study period, there were no MISO curtailments, downward dispatches, or ramping down events in which Crowned Ridge manually restarted wind turbines.

Stefan J. Martinsen, NextEra Energy Resources, LLC Regional Wind Site Manager, Wind Operations – Midwest Center Region.

- 3-5) Did CRW receive compensation (constraint payments) for curtailment (also downward dispatch, ramping down) periods for the period of November 2, 2021 through November 18, 2021?

**Response:** Crowned Ridge objects to Data Request 3-5, as it seeks information that is not relevant to the complaint proceeding. Subject to and without waiving this objection, Crowned Ridge responds: [REDACTED]

Stefan J. Martinsen, NextEra Energy Resources, LLC Regional Wind Site Manager, Wind Operations – Midwest Center Region.