

From "Future 1 Modeling Assumptions" at http://eipconline.com/Modeling_Results.html

Appendix A, Exhibit 1 - 2006 Load Shapes
Based on eastern interconnection sorting.

*ExGen added note at bottom on 2006 choice

By Load Blocks - Eastern Interconnection Regions
Average Load during block relative to average of highest block

NEEM Region	Season Hours Year	Summer										Shoulder					Winter				
		10 B1	25 B2	75 B3	100 B4	200 B5	300 B6	400 B7	500 B8	800 B9	1262 B10	25 B11	200 B12	600 B13	900 B14	1203 B15	25 B16	100 B17	400 B18	700 B19	935 B20
ENT	2011	1.000	0.996	0.946	0.946	0.910	0.862	0.824	0.774	0.698	0.601	0.822	0.681	0.629	0.594	0.532	0.747	0.687	0.647	0.613	0.561
FRCC	2011	1.000	0.943	0.914	0.900	0.876	0.831	0.793	0.743	0.674	0.515	0.800	0.680	0.631	0.583	0.445	0.704	0.632	0.582	0.552	0.450
MAPP_US	2011	1.000	1.064	1.058	1.005	0.960	0.905	0.852	0.784	0.721	0.627	0.792	0.851	0.837	0.806	0.715	0.996	1.011	0.989	0.944	0.782
MISO_IN	2011	1.000	0.986	0.927	0.875	0.842	0.785	0.716	0.652	0.591	0.514	0.695	0.657	0.632	0.594	0.521	0.806	0.737	0.683	0.637	0.560
MISO_MI	2011	1.000	0.921	0.829	0.772	0.730	0.690	0.647	0.607	0.565	0.485	0.605	0.602	0.585	0.539	0.450	0.714	0.654	0.622	0.574	0.473
MISO_MO-IL	2011	1.000	0.964	0.882	0.823	0.795	0.733	0.682	0.617	0.543	0.458	0.705	0.586	0.553	0.518	0.445	0.742	0.653	0.605	0.560	0.492
MISO_W	2011	1.000	1.058	1.017	0.958	0.906	0.837	0.785	0.702	0.634	0.533	0.735	0.706	0.686	0.638	0.542	0.868	0.798	0.771	0.708	0.545
MISO_WUMS	2011	1.000	0.985	0.907	0.838	0.787	0.740	0.693	0.646	0.596	0.495	0.667	0.657	0.637	0.588	0.481	0.773	0.708	0.673	0.625	0.513
NE	2011	1.000	1.031	1.013	0.989	0.951	0.908	0.865	0.795	0.717	0.610	0.772	0.703	0.679	0.635	0.542	0.797	0.742	0.721	0.685	0.591
NEISO	2011	1.000	0.935	0.860	0.785	0.748	0.703	0.653	0.614	0.565	0.450	0.630	0.624	0.599	0.555	0.435	0.718	0.683	0.656	0.606	0.486
NYISO_A-F	2011	1.000	0.952	0.902	0.843	0.808	0.773	0.734	0.707	0.670	0.566	0.727	0.742	0.715	0.671	0.559	0.823	0.801	0.776	0.730	0.615
NYISO_G-I	2011	1.000	0.950	0.852	0.780	0.748	0.698	0.649	0.609	0.557	0.445	0.604	0.586	0.556	0.517	0.411	0.659	0.625	0.607	0.563	0.461
NYISO_J-K	2011	1.000	0.959	0.874	0.797	0.763	0.705	0.641	0.597	0.540	0.429	0.595	0.550	0.532	0.487	0.383	0.577	0.551	0.545	0.516	0.411
NonRTO_Midwest	2011	1.000	0.981	0.930	0.888	0.857	0.808	0.750	0.696	0.627	0.529	0.745	0.708	0.658	0.613	0.529	0.933	0.836	0.757	0.687	0.605
PJM_E	2011	1.000	0.960	0.868	0.800	0.768	0.708	0.643	0.592	0.538	0.439	0.580	0.552	0.526	0.488	0.399	0.635	0.601	0.575	0.533	0.446
PJM_ROM	2011	1.000	0.971	0.908	0.853	0.827	0.783	0.719	0.669	0.619	0.513	0.683	0.672	0.641	0.597	0.496	0.833	0.776	0.719	0.664	0.565
PJM_ROR	2011	1.000	0.959	0.889	0.838	0.805	0.760	0.705	0.658	0.606	0.512	0.675	0.661	0.631	0.588	0.501	0.814	0.752	0.694	0.644	0.557
SOCO	2011	1.000	0.975	0.962	0.938	0.907	0.861	0.801	0.734	0.650	0.528	0.749	0.648	0.595	0.555	0.473	0.801	0.708	0.629	0.579	0.512
SPP_N	2011	1.000	0.980	0.935	0.907	0.869	0.811	0.764	0.699	0.618	0.510	0.760	0.609	0.574	0.537	0.451	0.712	0.638	0.610	0.577	0.498
SPP_S	2011	1.000	0.995	0.958	0.946	0.897	0.836	0.792	0.733	0.654	0.552	0.773	0.619	0.579	0.549	0.478	0.704	0.640	0.607	0.575	0.518
TVA	2011	1.000	0.982	0.942	0.926	0.884	0.824	0.763	0.705	0.629	0.533	0.746	0.681	0.634	0.598	0.527	0.921	0.799	0.702	0.644	0.580
VACAR	2011	1.000	0.970	0.937	0.894	0.859	0.811	0.737	0.677	0.610	0.496	0.672	0.641	0.588	0.551	0.472	0.843	0.746	0.647	0.591	0.525
MAPP_CA	2011	1.000	1.014	1.012	0.993	0.979	0.957	0.934	0.901	0.853	0.753	0.898	0.965	0.949	0.913	0.810	1.078	1.093	1.076	1.043	0.931
IESO	2011	1.000	0.956	0.894	0.855	0.825	0.800	0.770	0.736	0.699	0.604	0.765	0.786	0.761	0.716	0.603	0.882	0.858	0.830	0.781	0.657

area around the time of the 2006 summer peak load. Would that inappropriately model too much wind during a normally low wind period? MISO staff provided specific peak timing as