

BLACK HILLS POWER, INC.
SD PUBLIC UTILITIES COMMISSION
DOCKET NO. EL15-049 – Line Extension Policy

REQUEST DATE : January 14, 2016

RESPONSE DATE : January 27, 2016

REQUESTING PARTY : South Dakota Public Utilities Commission

SDPUC Request 1-2:

Explain why these secondary service voltage options are no longer offered.

Response to SDPUC Request 1-2:

The industry standard has changed from a delta connection to a wye connection.