

**Proposed Noise Condition****Crocker Wind Farm**

The Project, exclusive of all unrelated background noise, shall not generate a long-term average sound pressure level (equivalent continuous sound level, Leq), as measured over a period of at least two weeks that includes all integer wind speeds from cut in to full power, of more than 45 dBA at any non-participating residence or more than 50 dBA at any participating residence. The Applicant shall, upon Commission formal request, conduct field surveys or provide post-construction monitoring data verifying compliance with specified noise level limits. If the long-term average level exceeds 45 dBA at any non-participating residence or 50 dBA at any participating residence, then the Project Owner shall take whatever steps are necessary to rectify the situation. Sound monitoring will not be repeated in a representative area during any five year period unless operational or maintenance changes result in a reasonable assumption of higher turbine sound levels.

