

## **EXHIBIT B**

### **Summary of Turbine Shifts Within 250 Feet of Locations in Exhibit A25 (Updated Layout Map)**

Turbine Number	Turbine Shift Distance (ft)	Turbine Shift Direction	Distance to nearest residence (ft) <sup>1</sup>	Type of Residence	Distance to nearest Road (ft) <sup>2</sup>	Distance to the Shoreline of Punished Woman's Lake (ft) <sup>3</sup>	Distance to nearest non-participating parcel (ft) <sup>2</sup>
26	217.7	NE	5,600	Participating	4,420	34,528	1,136
62	23.4	NW	1,844	Non-participating	1,460	20,306	1,646

<sup>1</sup> Setback requirements – 1,000 feet from non-participating residences; 500 feet from participating residences  
<sup>2</sup> Setback requirements – 541 feet  
<sup>3</sup> Setback requirements – 2 miles from the shoreline of Punished Woman's Lake

64540183.2