

## EXHIBIT B

### Summary of Turbine Adjustment Requirement Compliance

Turbine Number	Turbine Shift Distance (ft)	Turbine Shift Direction	Distance to nearest receptor (ft) <sup>1</sup>	Type of Nearest Receptor	Distance to nearest Road (ft) <sup>2</sup>	Distance to nearest non-participating parcel (ft) <sup>2</sup>
8	492	West	4,120	residence	1,576	1,247

<sup>1</sup> Setback requirements –  
Bon Homme & Hutchinson counties: 1,000 feet from non-participating residences; 500 feet or 1.1 times total system height from participating residences.  
Charles Mix County: 2,000 feet or 3.5 times the system height feet from non-participating residences; 1,000 feet from participating residences.

<sup>2</sup> Setback requirements – 500 feet or 1.1 times total system height