

**EXHIBIT B**

**Summary of Turbine Adjustment Requirement Compliance**

Turbine ID (Layout 54)	Latitude	Longitude	Turbine Shift Distance (ft)	Turbine Shift Direction	Distance to Nearest Residence (ft)	Type of Residence	Max Sound Level Modeled at Nearest Residence (dBA)	Shadow Flicker Modeled at Nearest Residence (hr)	Distance to Nearest Road (ft)	Distance to Nearest Cemetery (ft)	Distance to Nearest Non-Participating Parcel (ft)	Distance to Punished Woman's Lake (ft)
T-016	45.22938	-97.02795	225	East	1,650	House	45	13:26	590	18,758	3,866	45,550
	Setback Requirements - 1,000 Feet from Non-Participating Residences; 500 Feet from Participating Residences											
	Setback Requirements - 541 Feet from any Public Road											
	Setback Requirements - 10,560 Feet or 2 Miles from the Shoreline of Punished Woman's Lake											