



500 West Russell Street
Sioux Falls, South Dakota 57101-0988

May 4, 2022

—Via Electronic Filing—

Ms. Patricia Van Gerpen
Executive Director
South Dakota Public Utilities Commission
State Capitol Building
500 East Capitol Avenue
Pierre, SD 57501-5070

RE: SETBACK DISTANCE
DAKOTA RANGE I, LLC & DAKOTA RANGE II, LLC
DOCKET NO. EL18-003

Dear Ms. Van Gerpen:

At the April 28, 2022 Commission Meeting, Vice Chairperson Kristie Fiegen requested further information on the property line setback distance for the following turbines: T-42, T-55, T-56, T-66, T-70 and T-71. The table below contains the requested information.

Turbine	Setback Type	Minimum required (feet)	As-built setback (feet)
T-42	Non-participating property line	548	553
T-55	Non-participating residence	1,000	1,630
T-56	Non-participating property line	548	559
T-66	Non-participating property line	548	619
T-70	Non-participating property line	548	623
T-71	Non-participating property line	548	559

If you have any questions regarding this filing, please contact Jennifer Roesler at (612) 330-1925 or jennifer.roesler@xcelenergy.com or me at (605) 339-8350 or steven.t.kolbeck@xcelenergy.com.

Sincerely,

/s/

STEVEN T. KOLBECK
PRINCIPAL MANAGER – SOUTH DAKOTA