

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF SOUTH DAKOTA**

**IN THE MATTER OF THE APPLICATION OF
CROWNED RIDGE WIND II, LLC FOR A FACILITIES PERMIT TO
CONSTRUCTION 300 MEGAWATT WIND FACILITY**

Docket No. EL19-

**DIRECT TESTIMONY AND EXHIBITS
OF JAY HALEY**

July 8th, 2019

INTRODUCTION AND QUALIFICATIONS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29

Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

A. My name is Jay Haley. My business address is 3100 DeMers Ave., Grand Forks, ND, 58201.

Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?

A. I am a Partner in EAPC Wind Energy and work as a Wind Engineer.

Q. WHAT ARE YOUR RESPONSIBILITIES?

A. My responsibility was to conduct the sound and shadow flicker studies for Crowned Ridge Wind II, LLC (“CRW II”).

Q. PLEASE DESCRIBE YOUR BACKGROUND AND QUALIFICATIONS

A. I have more than 30 years of experience in wind farm design. My experience includes financial feasibility studies, technical due diligence, wind farm design, energy assessments, visual simulations, ice throw studies, noise studies, and shadow flicker studies. I have performed more than 60 noise impact assessments and shadow flicker studies in over 15 states across the U.S. I have also worked on wind energy projects in Australia, Puerto Rico, Argentina, Chile, Uruguay and Venezuela. I am also the North and South American sales and support representative for windPRO, which is the world’s leading software tool used for the design of wind farms including noise and shadow flicker studies. I have trained hundreds of engineers and environmental consultants on the proper use of windPRO with regard to wind farm design, energy assessments, visual simulations, and noise and shadow flicker studies. I have provided expert witness testimony on noise impacts, shadow flicker issues, ice throw and visual impacts in adjudicatory hearings front of local boards and in judicial proceedings.

I have a Bachelor of Science degree in Mechanical Engineering from the University of North Dakota. I am a participating member of the International Electrotechnical Commission (IEC) Technical Committee TC88, Working Group 15 as a Technical Advisor for the U.S. National Committee. The purpose of this group is to develop an International Standard for the

1 assessment of wind resource, energy yield, and site suitability input conditions for wind
2 power plants.

3
4 **Q. HAS THIS TESTIMONY BEEN PREPARED BY YOU OR UNDER YOUR
5 DIRECT SUPERVISION?**

6 A. Yes.

7
8 **Q. HAVE YOU PREVIOUSLY TESTIFIED BEFORE THE SOUTH DAKOTA
9 PUBLIC UTILITIES COMMISSION?**

10 A. Yes.

11 **PURPOSE OF TESTIMONY**

12 **Q. PLEASE DESCRIBE THE PURPOSE OF YOUR TESTIMONY.**

13 A. The purpose is to provide a description of the sound and shadow/flicker studies
14 conducted for CRW II and to set forth the results of the studies.

15
16 **SOUND STUDY**

17 **Q. PLEASE DESCRIBE THE SOUND STUDY THAT WAS CONDUCTED FOR
18 CRW II.**

19 A. Wind turbine noise can originate from a number of sources, but primarily from mechanical
20 sound from the interaction of turbine components, and aerodynamic sound produced by the
21 airflow over the rotor blades. In addition to the turbines, the transformer located at a wind
22 project's substation will also emit sound.

23
24 Wind turbine sound pressure levels are measured using a sound level meter and a
25 microphone. Sound level meters used for monitoring can pick up sounds perfectly, but the
26 human ear is not as precise. The human ear cannot hear very low or very high frequencies.
27 The sensitivity range of the human ear is approximately 20 to 20,000 Hz. Weighting
28 networks are used in noise monitors in order to adjust specific frequencies in the audio
29 spectrum to attempt to duplicate the response of the human ear.

1
2 The C-weighting network represents the actual sound pressure level that is received by the
3 sound level meter, and does not noticeably vary in its amount of compensation throughout
4 the audio spectrum. C-weighting is used during the calibration of sound level meters to
5 ensure that the sound level displayed on the meter is accurate and the same as the frequency
6 of the calibrator. The A-weighting network is then used to duplicate the sensitivity of the
7 human ear (20-20,000 Hz).

8
9 Sounds in the environment vary with time. The two sound level metrics that are commonly
10 reported in community noise monitoring are:

- 11 • L_{90} , which is the sound level in dBA that is exceeded 90 percent of the time during a
12 measurement period. The L_{90} is close to the lowest sound level observed. It is
13 essentially the same as the “residual”, or ambient sound level, which is the sound level
14 observed when there are no obvious nearby intermittent noise sources.
- 15 • L_{eq} , the equivalent level, is the level of a hypothetical steady sound that would have
16 the same energy as the actual fluctuating sound observed. The equivalent level is
17 designated L_{eq} and is commonly A-weighted. The equivalent level represents the time
18 average of the fluctuating sound pressure, but because sound is represented on a
19 logarithmic scale and the averaging is done with time-averaged mean square sound
20 pressure values, the L_{eq} is mostly determined by occasional loud noises.

21
22 The sound levels at the base of a modern utility-scale wind turbine typically range between
23 55 to 60 dBA when the wind turbine is operating at full power. By comparison, a normal
24 conversation between two people is typically 55-65 dBA when they are three feet apart.
25 Sound levels decrease with distance. At 50 dBA it would be approximately half as loud as
26 conversational speech, and between 30 and 40 dBA it is comparable to the ambient sound
27 levels in a quiet rural area. A conservative prediction of sound levels associated with the
28 Project was made using windPRO, the world’s leading software tool for wind farm design,
29 which is commonly used in the industry world-wide for sound modeling. This software
30 incorporates the International Standard ISO 9613-2 for sound propagation (Acoustics –
31 Attenuation of sound during propagation outdoors – Part 2: General method of calculation).

32

1 In addition to the turbine model specifications, proposed Project layout, and the receptor
2 locations discussed above, inputs and significant parameters employed in the model included:
3

- 4 • Project Layout: 393 locations were modeled (136 for Crowned Ridge, 133 for
5 Crowned Ridge II and 124 for Deuel Harvest).
- 6 • Receptor Locations: For Codington County, sound receptors were modeled as
7 areas representing the land parcels and sound levels were calculated at the parcel
8 boundaries. For Deuel County, sound levels were calculated at receptors that were
9 modeled as discrete points at a height of 1.5 meters (“m”) above ground level at
10 the perimeter of the structure. For Grant County, sound levels were calculated at
11 receptors that were modeled as discrete points at a height of 1.5 m above ground
12 level and 50 feet from the perimeter of the structures. Sound levels were also
13 calculated on a 25 m x 25 m receptor grid in order to generate the sound level
14 isolines, which are lines on a map depicting sound levels.
- 15 • Terrain Elevation: The terrain height contour elevations for the area modeled
16 were generated from elevation information derived from the 3 m National
17 Elevation Dataset (“NED”), developed by the U.S. Geological Survey.
- 18 • Wind Turbine Sound Levels: The expected sound power levels associated with
19 the GE wind turbines were obtained from GE technical reports. The 1/3 octave-
20 band sound power levels calculated for the GE 2.3-116-90, GE 2.3-116-80, and
21 GE 2.1-116-80 wind turbines represent the highest operational sound level
22 emissions. In addition, all turbines were assumed to be operating simultaneously
23 and at the design wind speed corresponding to the greatest sound level impacts,
24 and upwind from all receptors, with an additional 2.0 dBA added to the maximum
25 sound power level for each wind turbine.
- 26 • Ground Attenuation: Spectral ground absorption was calculated using a G-factor
27 of 0.5, which corresponds to “mixed ground” consisting of both hard and porous
28 ground cover. No additional attenuation due to tree shielding, air turbulence, or
29 wind shadow effects was considered.
- 30 • Meteorological Assumptions: Meteorological conditions were selected to
31 minimize atmospheric attenuation. The model also assumed favorable conditions

1 for sound propagation, corresponding to a moderate, well-developed ground-
2 based temperature inversion, as might occur on a calm, clear night.

3
4 **Q. WHAT WAS THE SOUND STANDARD YOU APPLIED?**

5 A. For Codington County, per Section 5.22.03 paragraph 12 of the *Comprehensive Zoning*
6 *Regulations for Codington County*, Codington County requires the following:

7 “Noise level shall not exceed 50 dBA, average A-weighted Sound pressure level effects at
8 the property line of existing non-participating residences, businesses, and buildings owned
9 and/or maintained by a governmental entity.”

10 For Deuel County, per Section 1215.03, paragraph 13. a) of the Deuel County Zoning
11 Ordinance B2004-01-23B, Deuel County requires the following:

12 “13. a) Noise level shall not exceed 45 dBA average A-weighted sound pressure at the
13 perimeter of existing residences, for non-participating residences.”

14 For Grant County, per Section 1211.04, paragraph 14 of the Grant County Zoning Ordinance
15 2016-01C, Grant County imposes the following requirement for wind energy facilities:

16 “14.) Noise. Noise level shall not exceed 45 dBA, average A-weighted Sound pressure
17 including constructive interference effects measured twenty-five (25) feet from the perimeter
18 of existing off-site non-participating residences, businesses, buildings owned and/or
19 maintained by a governmental entity.”

20 “Noise level shall not exceed 50 dBA, average A-weighted Sound pressure including
21 constructive interference effects measured twenty-five (25) feet from the perimeter of
22 participating residences, businesses, and buildings owned and/or maintained by a
23 governmental entity.”

24 **Q. WHAT WERE THE RESULTS OF YOUR SOUND STUDY?**

25 A. The results of the study indicate that there were no sound pressure levels in exceedance
26 of any of the three respective county’s noise ordinances. Sound pressure levels at all non-
27 participating occupied structures were 45 dBA or less, and 50 dBA or less at all
28 participating occupied structures for all three counties. Codington County’s ordinance
29 only requires 50 dBA or less at non-participating property lines (no requirements at

1 structures) and the highest sound pressure level was 49.7 dBA at a non-participating
2 property line.

4 SHADOW/FLICKER STUDY

5 **Q. WHAT IS SHADOW AND FLICKER AS IT RELATES TO WIND TURBINES?**

6 A. Shadow flicker from wind turbines occurs when rotating wind turbine blades move between
7 the sun and the observer. Shadow flicker is generally experienced in areas near wind turbines
8 where the distance between the observer and wind turbine blade is short enough that sunlight
9 has not been significantly diffused by the atmosphere. When the blades rotate, this shadow
10 creates a pulsating effect, known as shadow flicker. If the blade's shadow is passing over the
11 window of a building, it will have the effect of increasing and decreasing the light intensity in
12 the room at a low frequency in the range of 0.5 to 1.2 Hz, hence the term "flicker." In this
13 case, with a maximum rotational speed of 15.6 rpm for the GE 2.3-116, the frequency would
14 be 0.78 Hz. This flickering effect can also be experienced outdoors, but the effect is typically
15 less intense, and becomes less intense when farther from the wind turbine causing the flicker.

17 **Q. PLEASE DESCRIBE THE SHADOW AND FLICKER STUDY THAT WAS** 18 **CONDUCTED.**

19 A. This shadow flicker analysis was performed utilizing windPRO, which is the most commonly
20 used software world-wide for performing shadow flicker studies. It has the capability to
21 calculate detailed shadow flicker maps across an entire area of interest or at site-specific
22 locations using shadow receptors.

23
24 Shadow maps which indicate where the shadows will be cast and for how long, are generated
25 using windPRO, calculating the shadow flicker in varying user-defined resolutions. Standard

1 resolution was used for this study and represents shadow flicker being calculated every three
2 minutes of every day over the period of an entire year over a grid with a 20 m by 20 m
3 resolution.

4
5 In addition to generating a shadow flicker map, the amount of shadow flicker that may occur
6 at a specific point can be calculated more precisely by placing a shadow receptor at the
7 location of interest and essentially “recording” the shadow flicker that occurs as the relative
8 sunrise to sunset motion of the sun is simulated throughout an entire year.

9
10 The point-specific shadow flicker calculation is run at a higher resolution as compared to the
11 shadow flicker map calculation to utilize the highest precision available within windPRO.
12 Shadow flicker at each shadow receptor location is calculated every minute of every day for
13 an entire year. Shadow receptors can be configured to represent an omni-directional window
14 of a specific size at a specific point (greenhouse mode) or a window facing a single direction
15 of a specific size at a specific point (single direction mode). The shadow receptors used in
16 this analysis were configured as greenhouse-mode receptors representing a 1 m x 1 m
17 window located 1 m above ground level. This represents more of a “worst-case” scenario,
18 and, thus, will produce more conservative results since it assumes that all windows are
19 always in direct line of sight with the turbines and the sun.

20
21 As a part of the calculation method, windPRO must determine whether or not a turbine will
22 be visible at the receptor locations and not blocked by local topography. It does this by
23 performing a preliminary Zones of Visual Influence calculation, utilizing 10 m grid spacing.
24 If a particular turbine is not visible within the 10 m x 10 m area that the shadow receptor is
25 contained within, then that turbine is not included in the shadow flicker calculation for that
26 receptor.

27
28 The inputs for the windPRO shadow flicker calculation include the following:

- 29 • Turbine Coordinates: The location of a wind turbine in relation to a shadow
30 receptor is one of the most important factors in determining shadow flicker
31 impacts. A line-of-sight is required for shadow flicker to occur. The intensity
32 of the shadow flicker is dependent upon the distance from the wind turbine

1 and weather conditions.

- 2
- 3 • Turbine Specifications: A wind turbine's total height and rotor diameter will
- 4 be included in the windPRO shadow flicker model. The taller the wind
- 5 turbine, the more likely shadow flicker could have an impact on local shadow
- 6 receptors as the ability to clear obstacles (such as hills or trees) is greater,
- 7 although in this analysis, no credit is taken for any such blockage from trees.
- 8 The larger the rotor diameter is, the wider the area where shadows will be
- 9 cast. Also included with the turbine specifications are the cut-in and cut-out
- 10 wind speeds within which the wind turbine is operational. If the wind speed is
- 11 below the cut-in threshold or above the cut-out threshold, the turbine rotor
- 12 will not be spinning and thus shadow flicker will not occur. The blade width
- 13 is also taken into consideration. The wider the blade is, the farther from the
- 14 wind turbine the shadow effect will persist.
- 15
- 16 • Shadow Receptor Coordinates: As with the wind turbine coordinates, the
- 17 elevation, distance and orientation of a shadow receptor in relation to the
- 18 wind turbines and the sun are the main factors in determining the impact of
- 19 shadow flicker.
- 20
- 21 • Monthly Sunshine Probabilities: windPRO calculates sunrise and sunset times
- 22 to determine the total annual hours of daylight for the modeled area. To
- 23 further refine the shadow flicker calculations, the monthly probability of
- 24 sunshine is included to account for cloud cover. The greater the probability of
- 25 cloud cover, the less of an impact from shadow flicker. The monthly sunshine
- 26 probabilities for many of the larger cities across the United States are
- 27 available from the National Climatic Data Center. For this study, 18 years'
- 28 worth of monthly sunshine probability data was retrieved for Huron, SD,
- 29 which was the closest, most representative station, to create the long-term
- 30 representative monthly sunshine probabilities.
- 31
- 32 • Joint Wind Speed and Direction Frequency Distribution: A set of long-term

1 corrected wind distributions was provided by Crowned Ridge Wind, LLC to
2 represent the annual wind speed and direction distribution for the project site.
3 This data was used to estimate the probable number of operational hours for
4 the wind turbines from each of the 12 wind direction sectors. During
5 operation, the wind turbine rotors will always be assumed to face into the
6 wind and automatically orient themselves as the wind direction changes.
7 Shadow flicker can only occur when the blades are turning and the wind
8 turbine rotor is between the sun and the receptor. Shadow flicker is most
9 significant when the rotor is facing the sun.

- 10
- 11 • USGS Digital Elevation Model (DEM) (height contour data): For this study,
12 3 m USGS NED DEMs were used to construct 10-foot interval height contour
13 lines for the windPRO shadow flicker model. The height contour information
14 is important to the shadow flicker calculation since it allows the model to
15 place the wind turbines and the shadow receptors at the correct elevations.
16 The height contour lines also allow the model to include the topography of
17 the site when calculating the zones of visual influence surrounding the wind
18 turbine and shadow receptor locations.

19

20 The actual calculation of potential shadow flicker at a given shadow receptor is carried out by
21 simulating the environment near the wind turbines and the shadow receptors. The position of
22 the sun relative to the turbine rotor disk and the resulting shadow is calculated in time steps
23 of one minute throughout an entire year. If the shadow of the rotor disk (which in the
24 calculation is assumed solid) at any time casts a shadow on a receptor window, then this step
25 will be registered as one minute of shadow flicker. The calculation also requires that the sun
26 must be at least 3.0° above the horizon in order to register shadow flicker. When the sun
27 angle is less than 3.0° , the shadow quickly becomes too diffuse to be distinguishable since
28 the amount of atmosphere that the light must pass through is 15 times greater than when the
29 sun is directly overhead.

30

31 The sun's path with respect to each wind turbine location is calculated by the software to
32 determine the paths of cast shadows for every minute of every day over a full year. The

1 turbine runtime and direction are calculated from the site's long-term wind speed and
2 direction distribution. The effects of cloud cover are calculated using long-term reference
3 data (monthly sunshine probability) to arrive at the projected annual flicker time at each
4 receptor.

5
6 Shadow flicker does not extend beyond a distance of approximately 1,700 meters from the
7 wind turbine base, which is why all occupied structures within a conservative distance of
8 2 kilometer (km) from a wind turbine were included in the analysis.

9
10 **Q. WHAT WAS THE SHADOW AND FLICKER STANDARD YOU APPLIED?**

11 A. There are no federal shadow flicker regulations. There are regulations in Codington, Deuel
12 and Grant Counties that require a limit of 30 hours of shadow flicker per year, which is the
13 standard used in the study.

14
15 **Q. WHAT WERE THE RESULTS OF YOUR SHADOW AND FLICKER STUDY?**

16 A. Using the conservative modeling methodology which includes the use of greenhouse sensors,
17 turbines always facing the sun, and no credit for any blockage by trees or buildings, the
18 Project is not projected to result in shadow flicker levels above 30 hours per year at any
19 residence, business, or building owned and/or maintained by a governmental entity, with the
20 exception of one participating structure (CR1-C10-P), which will experience up to 38:22 of
21 shadow flicker per year.

22
23 A total of 234 existing residences within 2 km of a wind turbine were analyzed and standard
24 resolution realistic shadow flicker maps were generated for the turbine array. The 234
25 shadow receptors were then modeled as greenhouse-mode receptors and the estimated
26 shadow flicker was calculated for the array. No shadow receptors are expected to experience
27 more than 30 hours and 0 minutes of shadow flicker per year, with the exception of CR1-
28 C10-P. Assuming either curtailment or a signed waiver for this 1 receptor, CRW II would be
29 in compliance with Codington County Ordinance #68, Section 5.22.03, paragraph 13, Deuel
30 County Ordinance B2004-01-23B, Section 1215.03, paragraph 13 b.), as well as Grant
31 County Ordinance 2016-01C, Section 1211.04, paragraph 14, all of which limit shadow

1 flicker to 30 hours per year.

2

3 **Q. HAVE ANY OF THE RECEPTORS THAT ARE NOTED AS PENDING OR NON-**

4 **PARTICIPATING IN YOUR STUDIES RECENTLY EXECUTED EASEMENT**

5 **OPTION AGREEMENTS?**

6

7 A. Yes. My understanding is following two receptors have executed option
8 agreements: CR2-D38-P * and CR2-C45-NP.

9

10 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**

11 A. Yes.

STATE OF NORTH DAKOTA)
) ss
COUNTY OF GRAND FORKS)


I, Jay Haley, being duly sworn on oath, depose and state that I am the witness identified in the foregoing prepared testimony and I am familiar with its contents, and that the facts set forth are true to the best of my knowledge, information and belief.



Jay Haley

Subscribed and sworn to before me this 8th day of June, 2019.

SEAL





Notary Public

My Commission Expires April 11, 2023