

Attachment 2

Table B-1: Crowned Ridge Wind Farm 200 MW

GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's

LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)

UTM NAD83 Zone 14

WTG	Type	Turbine Model	Easting (m)	Northing (m)	Base Elev. AMSL (m)	Sound Profile
CRI-20	Primary	GE2.3 116RD 90HH r2.madE	659,920	4,994,924	594.0	LNTE
CRI-21	Primary	GE2.3 116RD 90HH r2.madE	657,925	4,994,896	617.1	LNTE
CRI-22	Primary	GE2.3 116RD 90HH r2.madE	656,543	4,994,796	616.5	LNTE
CRI-24	Primary	GE2.3 116RD 90HH r2.madE	655,852	4,994,652	609.0	LNTE
CRI-25	Primary	GE2.3 116RD 90HH r2.madE	658,251	4,994,286	605.5	LNTE
CRI-26	Primary	GE2.3 116RD 90HH r2.madE	665,405	4,994,191	578.5	Normal
CRI-27	Primary	GE2.3 116RD 90HH r2.madE	657,442	4,994,187	621.0	Normal
CRI-28	Primary	GE2.3 116RD 90HH r2.madE	664,517	4,994,168	579.0	Normal
CRI-29	Primary	GE2.3 116RD 90HH r2.madE	655,940	4,994,069	606.9	LNTE
CRI-30	Primary	GE2.3 116RD 90HH r2.madE	659,871	4,994,052	593.7	Normal
CRI-31	Primary	GE2.3 116RD 90HH r2.madE	655,030	4,994,051	603.0	LNTE
CRI-32	Primary	GE2.3 116RD 90HH r2.madE	660,704	4,993,998	606.0	LNTE
CRI-33	Primary	GE2.3 116RD 90HH r2.madE	656,566	4,993,941	618.0	LNTE
CRI-34	Primary	GE2.3 116RD 90HH r2.madE	658,966	4,993,856	599.7	Normal
CRI-35	Primary	GE2.3 116RD 90HH r2.madE	657,602	4,993,347	607.4	Normal
CRI-36	Primary	GE2.3 116RD 90HH r2.madE	659,966	4,993,319	594.0	LNTE
CRI-37	Primary	GE2.3 116RD 90HH r2.madE	664,419	4,993,110	587.3	LNTE
CRI-38	Primary	GE2.3 116RD 90HH r2.madE	658,338	4,992,981	600.5	Normal
CRI-39	Primary	GE2.3 116RD 90HH r2.madE	656,507	4,992,958	609.0	Normal
CRI-41	Primary	GE2.3 116RD 90HH r2.madE	663,782	4,992,883	597.7	LNTE
CRI-43	Primary	GE2.3 116RD 90HH r2.madE	666,181	4,992,815	577.9	Normal
CRI-44	Primary	GE2.3 116RD 90HH r2.madE	665,665	4,992,460	576.0	LNTE
CRI-46	Primary	GE2.3 116RD 90HH r2.madE	664,387	4,992,505	591.0	LNTE
CRI-48	Primary	GE2.3 116RD 90HH r2.madE	663,794	4,991,782	587.1	LNTE
CRI-50	Primary	GE2.3 116RD 90HH r2.madE	662,930	4,991,655	612.0	LNTE
CRI-51	Primary	GE2.3 116RD 90HH r2.madE	666,299	4,991,723	575.3	Normal
CRI-52	Primary	GE2.3 116RD 90HH r2.madE	665,441	4,991,398	575.5	LNTE
CRI-53	Primary	GE2.3 116RD 90HH r2.madE	659,750	4,990,981	598.7	LNTE
CRI-54	Primary	GE2.3 116RD 90HH r2.madE	665,979	4,990,946	573.7	Normal
CRI-55	Primary	GE2.3 116RD 90HH r2.madE	659,045	4,990,899	597.1	Normal
CRI-58	Primary	GE2.3 116RD 90HH r2.madE	665,663	4,990,303	585.0	Normal
CRI-59	Primary	GE2.3 116RD 90HH r2.madE	666,523	4,990,291	573.0	Normal
CRI-61	Primary	GE2.3 116RD 90HH r2.madE	662,982	4,990,178	612.0	LNTE
CRI-62	Primary	GE2.3 116RD 90HH r2.madE	660,954	4,990,170	600.8	Normal
CRI-63	Primary	GE2.3 116RD 90HH r2.madE	664,627	4,989,977	588.6	LNTE
CRI-64	Primary	GE2.3 116RD 90HH r2.madE	663,858	4,990,188	604.3	LNTE
CRI-65	Primary	GE2.3 116RD 90HH r2.madE	661,732	4,989,898	609.0	Normal
CRI-66	Primary	GE2.3 116RD 90HH r2.madE	663,165	4,989,613	614.7	LNTE
CRI-67	Alternate	GE2.3 116RD 90HH r2.madE	666,226	4,989,531	574.8	Normal
CRI-68	Alternate	GE2.3 116RD 90HH r2.madE	665,420	4,989,461	585.0	Normal
CRI-69	Primary	GE2.3 116RD 80HH r2.madE	660,621	4,989,453	605.6	Normal

Table B-1: Crowned Ridge Wind Farm 200 MW

GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's

LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)

UTM NAD83 Zone 14

continued

WTG	Type	Turbine Model	Easting (m)	Northing (m)	Base Elev. AMSL (m)	Sound Profile
CRI-70	Primary	GE2.3 116RD 90HH r2.madE	662,171	4,989,319	611.0	Normal
CRI-71	Primary	GE2.3 116RD 80HH r2.madE	659,405	4,989,320	607.3	Normal
CRI-72	Primary	GE2.3 116RD 80HH r2.madE	660,087	4,989,309	606.0	Normal
CRI-73	Primary	GE2.3 116RD 90HH r2.madE	661,344	4,989,297	609.8	Normal
CRI-74	Primary	GE2.3 116RD 90HH r2.madE	663,041	4,988,744	615.0	Normal
CRI-75	Primary	GE2.3 116RD 90HH r2.madE	664,137	4,988,702	609.0	Normal
CRI-76	Primary	GE2.3 116RD 90HH r2.madE	662,399	4,988,667	615.0	Normal
CRI-77	Primary	GE2.3 116RD 80HH r2.madE	659,158	4,988,642	612.0	Normal
CRI-78	Primary	GE2.3 116RD 80HH r2.madE	660,811	4,988,558	604.1	Normal
CRI-80	Primary	GE2.3 116RD 90HH r2.madE	661,552	4,988,481	608.8	Normal
CRI-81	Primary	GE2.3 116RD 90HH r2.madE	659,825	4,988,365	606.8	Normal
CRI-82	Primary	GE2.3 116RD 90HH r2.madE	663,271	4,988,133	613.0	Normal
CRI-83	Primary	GE2.3 116RD 90HH r2.madE	662,227	4,988,103	606.6	Normal
CRI-84	Primary	GE2.3 116RD 80HH r2.madE	660,677	4,987,880	600.6	Normal
CRI-85	Primary	GE2.3 116RD 90HH r2.madE	659,295	4,987,798	612.0	Normal
CRI-86	Primary	GE2.3 116RD 90HH r2.madE	658,534	4,987,759	613.1	Normal
CRI-87	Primary	GE2.3 116RD 90HH r2.madE	661,830	4,987,596	609.0	Normal
CRI-88	Primary	GE2.3 116RD 90HH r2.madE	660,157	4,987,492	603.0	Normal
CRI-89	Primary	GE2.3 116RD 90HH r2.madE	657,758	4,986,926	614.9	Normal
CRI-90	Primary	GE2.3 116RD 90HH r2.madE	658,545	4,986,881	612.0	Normal
CRI-91	Primary	GE2.3 116RD 90HH r2.madE	657,023	4,986,868	612.0	Normal
CRI-92	Primary	GE2.3 116RD 80HH r2.madE	660,039	4,986,804	607.2	Normal
CRI-93	Primary	GE2.3 116RD 80HH r2.madE	659,133	4,986,700	607.9	Normal
CRI-94	Primary	GE2.3 116RD 80HH r2.madE	660,716	4,986,660	600.6	Normal
CRI-95	Primary	GE2.3 116RD 90HH r2.madE	657,488	4,986,184	612.0	LNTE
CRI-96	Primary	GE2.3 116RD 90HH r2.madE	656,744	4,986,037	609.0	Normal
CRI-97	Primary	GE2.3 116RD 90HH r2.madE	655,899	4,985,715	592.7	Normal
CRI-98	Primary	GE2.3 116RD 90HH r2.madE	657,015	4,985,192	608.9	Normal
CRI-99	Primary	GE2.3 116RD 90HH r2.madE	672,521	4,990,188	556.7	Normal
CRI-100	Primary	GE2.3 116RD 90HH r2.madE	668,885	4,990,286	585.0	Normal
CRI-101	Primary	GE2.3 116RD 90HH r2.madE	672,921	4,990,513	544.6	Normal
CRI-102	Primary	GE2.3 116RD 90HH r2.madE	668,059	4,991,023	581.0	Normal
CRI-103	Primary	GE2.3 116RD 90HH r2.madE	669,279	4,991,115	582.0	Normal
CRI-104	Primary	GE2.3 116RD 90HH r2.madE	672,009	4,991,151	555.0	Normal
CRI-105	Primary	GE2.3 116RD 90HH r2.madE	670,488	4,991,091	571.6	Normal
CRI-106	Primary	GE2.3 116RD 90HH r2.madE	671,278	4,991,335	566.2	Normal
CRI-107	Primary	GE2.3 116RD 90HH r2.madE	667,723	4,991,800	582.0	Normal
CRI-108	Primary	GE2.3 116RD 90HH r2.madE	672,917	4,991,775	541.2	Normal
CRI-109	Primary	GE2.3 116RD 90HH r2.madE	670,897	4,992,616	557.4	Normal
CRI-111	Primary	GE2.3 116RD 90HH r2.madE	671,220	4,993,526	550.6	Normal
CRI-112	Primary	GE2.3 116RD 90HH r2.madE	670,419	4,993,665	561.0	Normal

Table B-2: Crowned Ridge 200 MW Sound Level Tabular Results Sorted by Receptor ID

Realistic case sound results at land parcel boundaries and occupied structures

Results using GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's

LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)

UTM NAD83 Zone 14

Codrington County

Receptor ID	Participation Status	Type	Easting (m)	Northing (m)	Elevation AMSL (m)	Real Case Sound (dB(A))	Distance to Nearest Turbine (ft)
CR1-C1-NP	Non-P	Boundary	657,051	4,983,917	590.3	36.7	4,186
CR1-C2-NP	Non-P	Boundary	658,435	4,984,609	601.8	37.5	5,036
CR1-C3-NP	Non-P	Boundary	657,812	4,984,785	603.4	40.2	2,936
CR1-C4-NP	Non-P	Boundary	659,890	4,985,620	605.2	40.7	3,914
CR1-C6-P	Participant	Boundary	663,383	4,994,502	591.0	38.6	3,878
CR1-C7-NP	Non-P	Boundary	660,455	4,985,631	591.0	40.7	3,484
CR1-C8-P	Participant	Boundary	660,476	4,984,821	597.0	36.9	6,086
CR1-C9-NP	Non-P	Boundary	665,264	4,985,116	609.0	32.8	10,840
CR1-C10-P	Participant	Boundary	662,862	4,985,695	601.7	38.1	4,150
CR1-C11-P	Participant	Boundary	663,622	4,985,714	608.8	36.6	5,397
CR1-C12-NP	Non-P	Boundary	662,246	4,986,500	605.1	45.3	1,532
CR1-C13-NP	Non-P	Boundary	663,599	4,986,512	615.0	39.3	3,875
CR1-C14-NP	Non-P	Boundary	657,803	4,986,003	609.0	46.7	1,191
CR1-C15-NP	Non-P	Boundary	662,794	4,986,895	612.9	48.3	1,017
CR1-C16-NP	Non-P	Boundary	661,244	4,986,473	597.0	44.7	1,837
CR1-C17-P	Participant	Boundary	658,819	4,986,842	611.4	51.3	909
CR1-C18-P	Participant	Boundary	663,578	4,987,413	609.4	42.9	2,566
CR1-C19-P	Participant	Boundary	660,393	4,987,529	608.4	51.7	784
CR1-C20-P	Participant	Boundary	662,024	4,987,612	604.2	52.5	640
CR1-C26-P	Participant	Boundary	658,015	4,987,993	606.7	44.9	1,867
CR1-C27-NP	Non-P	Boundary	657,234	4,988,151	587.2	40.6	4,265
CR1-C28-NP	Non-P	Boundary	665,432	4,989,009	583.9	45.9	1,483
CR1-C29-NP	Non-P	Boundary	666,496	4,989,001	574.3	43.6	1,952
CR1-C30-P	Participant	Boundary	661,978	4,989,318	612.8	52.8	633
CR1-C31-NP	Non-P	Boundary	665,639	4,989,013	584.7	45.6	1,637
CR1-C32-NP	Non-P	Boundary	657,187	4,989,566	573.2	37.7	7,142
CR1-C33-NP	Non-P	Boundary	657,126	4,990,843	567.0	37.9	5,856
CR1-C34-NP	Non-P	Boundary	658,759	4,990,463	589.4	44.6	1,709
CR1-C35-P	Participant	Boundary	661,955	4,990,153	606.1	48.6	1,112
CR1-C36-P	Participant	Boundary	663,116	4,990,548	610.7	46.3	1,293
CR1-C37-NP	Non-P	Boundary	663,829	4,990,572	594.0	46.2	1,263
CR1-C38-NP	Non-P	Boundary	660,955	4,990,468	591.2	49.0	978
CR1-C39-NP	Non-P	Boundary	659,741	4,991,242	583.3	48.4	856
CR1-C40-NP	Non-P	Boundary	658,706	4,991,231	579.8	45.0	1,555
CR1-C41-NP	Non-P	Boundary	664,797	4,992,137	578.8	44.7	1,808
CR1-C42-P	Participant	Boundary	659,828	4,992,807	580.1	52.4	604
CR1-C44-NP	Non-P	Boundary	665,447	4,992,972	578.1	44.9	1,824
CR1-C45-NP	Non-P	Boundary	653,821	4,993,552	573.0	35.7	4,291
CR1-C46-NP	Non-P	Boundary	655,903	4,993,577	609.0	45.2	1,621

Table B-2: Crowned Ridge 200 MW Sound Level Tabular Results Sorted by Receptor ID

Realistic case sound results at land parcel boundaries and occupied structures

Results using GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's

LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)

UTM NAD83 Zone 14

Codington County

continued

Receptor ID	Participation Status	Type	Easting (m)	Northing (m)	Elevation AMSL (m)	Real Case Sound (dB(A))	Distance to Nearest Turbine (ft)
CR1-C47-P	Participant	Boundary	663,454	4,992,888	612.0	46.7	1,076
CR1-C48-P	Participant	Boundary	664,262	4,992,514	586.6	53.5	413
CR1-C49-P	Participant	Boundary	662,224	4,993,664	609.0	38.2	5,105
CR1-C50-P	Participant	Boundary	656,239	4,994,042	618.0	49.6	984
CR1-C51-P	Participant	Boundary	657,753	4,994,889	620.0	51.5	564
CR1-C52-NP	Non-P	Boundary	654,986	4,995,398	603.0	40.6	2,582
CR1-C53-NP	Non-P	Boundary	664,171	4,995,340	580.5	37.6	4,009
CR1-C54-NP	Non-P	Boundary	663,495	4,995,329	582.9	36.4	5,075
CR1-C55-NP	Non-P	Boundary	660,139	4,994,937	607.0	49.5	722
CR1-C56-P	Participant	Boundary	656,199	4,995,194	603.0	44.8	1,726
CR1-C57-P	Participant	Boundary	656,526	4,995,198	616.1	45.6	1,319
CR1-C58-NP	Non-P	Boundary	657,670	4,996,842	615.0	37.1	4,961
CR1-C59-P	Participant	Boundary	660,756	5,000,883	591.5	32.5	6,155
CR1-C60-NP	Non-P	Boundary	656,539	4,998,453	609.3	40.9	2,162
CR1-C61-NP	Non-P	Boundary	656,599	4,997,787	612.0	41.1	2,139
CR1-C62-NP	Non-P	Boundary	658,155	4,994,994	614.5	48.7	820
CR1-C63-NP	Non-P	Boundary	658,543	4,995,211	606.8	42.4	2,277
CR1-C64-P	Participant	Boundary	659,426	4,992,800	576.6	50.9	728
CR1-C65-NP	Non-P	Boundary	665,516	4,995,045	578.0	40.1	2,825
CR1-C70-NP	Non-P	Boundary	664,950	4,988,325	596.1	41.7	2,940
CR1-C71-NP	Non-P	Boundary	664,414	4,988,688	600.0	49.2	909
CR1-C105-NP	Non-P	Boundary	658,351	5,000,265	609.0	49.1	604
CR1-C107-NP	Non-P	Boundary	655,923	4,998,435	595.6	48.3	673
CR1-C109-NP	Non-P	Boundary	654,532	4,997,382	592.6	40.3	1,903
CR1-C110-NP	Non-P	Boundary	654,553	4,996,633	588.7	39.8	2,365
CR1-C111-NP	Non-P	Boundary	654,565	4,996,159	599.1	40.9	1,791
CR1-C112-NP	Non-P	Boundary	659,955	4,984,990	604.0	37.7	5,958
CR2-C150-P	Participant	Boundary	655,905	4,985,521	600.0	51.6	636
CR1-C1-NP	Non-P	Structure	656,743	4,983,525	596.0	34.6	5,541
CR1-C2-NP	Non-P	Structure	658,791	4,984,483	602.0	36.6	6,273
CR1-C3-NP	Non-P	Structure	657,888	4,984,697	604.2	39.4	3,294
CR1-C4-NP	Non-P	Structure	659,744	4,984,749	606.0	36.9	6,706
CR1-C5-NP	Non-P	Structure	659,958	4,984,794	604.8	37.0	6,601
CR1-C6-P	Participant	Structure	662,989	4,995,228	599.8	36.0	6,102
CR1-C7-NP	Non-P	Structure	660,893	4,984,861	593.2	36.8	5,932
CR1-C8-P	Participant	Structure	660,532	4,984,445	599.4	35.6	7,293
CR1-C9-NP	Non-P	Structure	665,352	4,985,004	609.0	32.5	11,283
CR1-C10-P	Participant	Structure	663,510	4,985,195	609.0	35.2	6,535

Table B-2: Crowned Ridge 200 MW Sound Level Tabular Results Sorted by Receptor ID
Realistic case sound results at land parcel boundaries and occupied structures
Results using GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's
LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)
UTM NAD83 Zone 14
Codington County
continued

Receptor ID	Participation Status	Type	Easting (m)	Northing (m)	Elevation AMSL (m)	Real Case Sound (dB(A))	Distance to Nearest Turbine (ft)
CR1-C11-P	Participant	Structure	664,111	4,985,679	609.0	35.5	6,676
CR1-C12-1-NP	Non-P	Structure	662,199	4,986,047	606.0	40.8	2,956
CR1-C12-NP	Non-P	Structure	662,222	4,985,736	603.0	39.1	3,921
CR1-C13-NP	Non-P	Structure	663,792	4,985,785	612.0	36.4	5,643
CR1-C14-NP	Non-P	Structure	657,982	4,985,894	609.0	44.2	1,880
CR1-C15-NP	Non-P	Structure	663,291	4,986,026	615.0	38.5	3,907
CR1-C16-NP	Non-P	Structure	661,960	4,986,288	606.0	42.2	2,648
CR1-C17-P	Participant	Structure	658,031	4,986,373	609.1	46.3	1,886
CR1-C18-P	Participant	Structure	663,651	4,987,157	610.4	41.3	3,435
CR1-C19-P	Participant	Structure	659,243	4,987,276	611.6	48.0	1,722
CR1-C20-P	Participant	Structure	663,054	4,987,455	606.0	44.8	2,336
CR1-C21-P	Participant	Structure	660,756	4,984,086	594.0	34.5	8,445
CR1-C22-P	Participant	Structure	660,755	4,984,082	594.0	34.5	8,458
CR1-C23-P	Participant	Structure	660,619	4,984,078	595.8	34.5	8,478
CR1-C26-P	Participant	Structure	657,767	4,988,493	597.0	41.4	3,484
CR1-C27-NP	Non-P	Structure	656,876	4,988,683	583.0	38.1	5,974
CR1-C28-NP	Non-P	Structure	665,429	4,988,598	590.9	42.0	2,831
CR1-C29-NP	Non-P	Structure	666,572	4,988,867	575.9	42.0	2,457
CR1-C30-P	Participant	Structure	661,699	4,988,957	615.0	49.5	1,614
CR1-C31-NP	Non-P	Structure	665,939	4,988,950	585.4	44.3	2,126
CR1-C32-NP	Non-P	Structure	655,843	4,989,581	568.8	35.0	9,708
CR1-C33-NP	Non-P	Structure	656,839	4,990,404	569.8	36.9	7,418
CR1-C34-NP	Non-P	Structure	658,661	4,990,389	588.2	43.4	2,093
CR1-C35-P	Participant	Structure	662,025	4,990,475	609.0	44.9	2,123
CR1-C36-P	Participant	Structure	663,181	4,990,600	615.0	45.5	1,532
CR1-C37-NP	Non-P	Structure	663,563	4,991,342	605.1	44.9	1,631
CR1-C38-NP	Non-P	Structure	660,639	4,991,557	597.0	41.1	3,474
CR1-C39-NP	Non-P	Structure	660,144	4,991,670	588.0	42.1	2,605
CR1-C40-NP	Non-P	Structure	657,865	4,991,818	583.7	42.1	2,690
CR1-C41-NP	Non-P	Structure	665,053	4,992,084	576.1	44.4	2,356
CR1-C42-P	Participant	Structure	659,458	4,992,229	580.0	43.8	2,077
CR1-C44-NP	Non-P	Structure	665,076	4,993,095	578.2	44.2	2,155
CR1-C45-NP	Non-P	Structure	653,390	4,993,503	573.2	34.0	5,673
CR1-C46-NP	Non-P	Structure	655,802	4,993,540	609.1	44.5	1,795
CR1-C47-P	Participant	Structure	662,825	4,993,508	613.9	39.2	3,750
CR1-C48-P	Participant	Structure	664,247	4,993,646	588.0	45.3	1,847
CR1-C49-P	Participant	Structure	662,250	4,993,731	609.0	38.1	5,148
CR1-C50-P	Participant	Structure	656,806	4,994,388	621.0	47.1	1,591

Table B-2: Crowned Ridge 200 MW Sound Level Tabular Results Sorted by Receptor ID

Realistic case sound results at land parcel boundaries and occupied structures

Results using GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's

LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)

UTM NAD83 Zone 14

Grant County

continued

Receptor ID	Participation Status	Type	Easting (m)	Northing (m)	Elevation AMSL (m)	Real Case Sound (dB(A))	Distance to Nearest Turbine (ft)
CR1-G12-NP	Non-P	Structure	668,229	4,989,039	575.0	38.0	4,623
CR1-G13-NP	Non-P	Structure	672,216	4,989,142	558.0	38.3	3,576
CR1-G14-NP	Non-P	Structure	668,156	4,989,332	574.1	39.2	3,940
CR1-G15-P	Participant	Structure	668,396	4,989,607	576.0	41.0	2,746
CR1-G16-NP	Non-P	Structure	668,419	4,989,861	576.0	43.0	2,070
CR1-G18-P	Participant	Structure	668,678	4,990,722	585.0	46.6	1,585
CR1-G19-P	Participant	Structure	671,018	4,990,744	570.0	45.0	2,077
CR1-G21-P	Participant	Structure	666,766	4,991,807	577.1	46.2	1,555
CR1-G22-NP	Non-P	Structure	674,670	4,991,955	527.6	34.9	5,781
CR1-G23-NP	Non-P	Structure	670,471	4,992,104	560.0	44.1	2,185
CR1-G24-P	Participant	Structure	673,058	4,992,440	539.4	42.0	2,231
CR1-G25-P	Participant	Structure	671,391	4,992,858	549.0	45.4	1,804
CR1-G26-P	Participant	Structure	672,589	4,993,869	531.0	41.2	3,140
CR1-G27-NP	Non-P	Structure	676,630	4,994,642	480.8	29.7	8,678
CR1-G28-P	Participant	Structure	673,113	4,994,772	513.9	44.7	1,614
CR1-G32-P	Participant	Structure	669,477	4,995,401	546.0	46.7	1,545
CR1-G33-P	Participant	Structure	668,911	4,995,550	548.7	41.2	2,779
CR1-G34-NP	Non-P	Structure	671,320	4,995,798	531.0	42.0	2,238
CR1-G36-NP	Non-P	Structure	673,559	4,996,344	498.0	34.1	6,483
CR1-G37-NP	Non-P	Structure	668,998	4,996,452	549.0	36.5	5,246
CR1-G38-P	Participant	Structure	673,972	4,996,493	494.5	33.1	6,827
CR1-G41-P	Participant	Structure	671,563	4,997,050	497.6	35.0	6,378
CR1-G42-NP	Non-P	Structure	670,566	4,997,097	518.9	34.7	6,476
CR1-G43-NP	Non-P	Structure	661,141	5,001,721	583.6	32.2	6,552
CR1-G44-NP	Non-P	Structure	661,781	5,001,732	583.7	31.7	6,939
CR1-G59-P	Participant	Structure	675,755	4,994,888	487.7	32.6	5,981
CR1-G60-P	Participant	Structure	675,830	4,995,687	477.0	31.0	7,329
CR1-G65-P	Participant	Structure	671,496	4,994,973	537.0	46.9	1,539
CR1-G66-P	Participant	Structure	670,802	4,994,681	539.7	45.6	1,801
CR1-G67-P	Participant	Structure	669,597	4,993,440	556.1	44.7	2,106
CR1-G68-NP	Non-P	Structure	669,159	4,993,632	565.6	44.5	2,113
CR1-G70-NP	Non-P	Structure	677,465	4,991,043	492.0	27.6	15,006
CR1-G77-NP	Non-P	Structure	676,031	4,992,629	502.7	31.1	8,878
CR1-G81-P	Participant	Structure	671,478	4,997,523	508.8	32.7	7,828
CR1-G105-NP	Non-P	Structure	668,696	4,998,325	549.0	30.9	11,263
CR1-G108-P	Participant	Structure	669,516	5,001,186	522.2	26.9	19,908
CR1-G109-NP	Non-P	Structure	667,064	5,000,425	566.2	28.2	19,704
CR1-G110-NP	Non-P	Structure	671,218	5,005,064	456.2	23.5	28,615

Table B-3: Crowned Ridge 200 MW Sound Level Tabular Results Sorted by Sound Level

Realistic case sound results at land parcel boundaries and occupied structures

Results using GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's

LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)

UTM NAD83 Zone 14

Codrington County

Receptor ID	Participation Status	Type	Easting (m)	Northing (m)	Elevation AMSL (m)	Real Case Sound (dB(A))	Distance to Nearest Turbine (ft)
CR1-C55-NP	Non-P	Boundary	660,139	4,994,937	607.0	49.5	722
CR1-C71-NP	Non-P	Boundary	664,414	4,988,688	600.0	49.2	909
CR1-C105-NP	Non-P	Boundary	658,351	5,000,265	609.0	49.1	604
CR1-C38-NP	Non-P	Boundary	660,955	4,990,468	591.2	49.0	978
CR1-C62-NP	Non-P	Boundary	658,155	4,994,994	614.5	48.7	820
CR1-C39-NP	Non-P	Boundary	659,741	4,991,242	583.3	48.4	856
CR1-C15-NP	Non-P	Boundary	662,794	4,986,895	612.9	48.3	1,017
CR1-C107-NP	Non-P	Boundary	655,923	4,998,435	595.6	48.3	673
CR1-C14-NP	Non-P	Boundary	657,803	4,986,003	609.0	46.7	1,191
CR1-C37-NP	Non-P	Boundary	663,829	4,990,572	594.0	46.2	1,263
CR1-C28-NP	Non-P	Boundary	665,432	4,989,009	583.9	45.9	1,483
CR1-C31-NP	Non-P	Boundary	665,639	4,989,013	584.7	45.6	1,637
CR1-C12-NP	Non-P	Boundary	662,246	4,986,500	605.1	45.3	1,532
CR1-C46-NP	Non-P	Boundary	655,903	4,993,577	609.0	45.2	1,621
CR1-C40-NP	Non-P	Boundary	658,706	4,991,231	579.8	45.0	1,555
CR1-C44-NP	Non-P	Boundary	665,447	4,992,972	578.1	44.9	1,824
CR1-C41-NP	Non-P	Boundary	664,797	4,992,137	578.8	44.7	1,808
CR1-C16-NP	Non-P	Boundary	661,244	4,986,473	597.0	44.7	1,837
CR1-C34-NP	Non-P	Boundary	658,759	4,990,463	589.4	44.6	1,709
CR1-C29-NP	Non-P	Boundary	666,496	4,989,001	574.3	43.6	1,952
CR1-C63-NP	Non-P	Boundary	658,543	4,995,211	606.8	42.4	2,277
CR1-C70-NP	Non-P	Boundary	664,950	4,988,325	596.1	41.7	2,940
CR1-C61-NP	Non-P	Boundary	656,599	4,997,787	612.0	41.1	2,139
CR1-C60-NP	Non-P	Boundary	656,539	4,998,453	609.3	40.9	2,162
CR1-C111-NP	Non-P	Boundary	654,565	4,996,159	599.1	40.9	1,791
CR1-C7-NP	Non-P	Boundary	660,455	4,985,631	591.0	40.7	3,484
CR1-C4-NP	Non-P	Boundary	659,890	4,985,620	605.2	40.7	3,914
CR1-C52-NP	Non-P	Boundary	654,986	4,995,398	603.0	40.6	2,582
CR1-C27-NP	Non-P	Boundary	657,234	4,988,151	587.2	40.6	4,265
CR1-C109-NP	Non-P	Boundary	654,532	4,997,382	592.6	40.3	1,903
CR1-C3-NP	Non-P	Boundary	657,812	4,984,785	603.4	40.2	2,936
CR1-C65-NP	Non-P	Boundary	665,516	4,995,045	578.0	40.1	2,825
CR1-C110-NP	Non-P	Boundary	654,553	4,996,633	588.7	39.8	2,365
CR1-C13-NP	Non-P	Boundary	663,599	4,986,512	615.0	39.3	3,875
CR1-C33-NP	Non-P	Boundary	657,126	4,990,843	567.0	37.9	5,856
CR1-C32-NP	Non-P	Boundary	657,187	4,989,566	573.2	37.7	7,142
CR1-C112-NP	Non-P	Boundary	659,955	4,984,990	604.0	37.7	5,958
CR1-C53-NP	Non-P	Boundary	664,171	4,995,340	580.5	37.6	4,009
CR1-C2-NP	Non-P	Boundary	658,435	4,984,609	601.8	37.5	5,036

Table B-3: Crowned Ridge 200 MW Sound Level Tabular Results Sorted by Sound Level

Realistic case sound results at land parcel boundaries and occupied structures

Results using GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's

LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)

UTM NAD83 Zone 14

Codington County

continued

Receptor ID	Participation Status	Type	Easting (m)	Northing (m)	Elevation AMSL (m)	Real Case Sound (dB(A))	Distance to Nearest Turbine (ft)
CR1-C58-NP	Non-P	Boundary	657,670	4,996,842	615.0	37.1	4,961
CR1-C1-NP	Non-P	Boundary	657,051	4,983,917	590.3	36.7	4,186
CR1-C54-NP	Non-P	Boundary	663,495	4,995,329	582.9	36.4	5,075
CR1-C45-NP	Non-P	Boundary	653,821	4,993,552	573.0	35.7	4,291
CR1-C9-NP	Non-P	Boundary	665,264	4,985,116	609.0	32.8	10,840
CR1-C48-P	Participant	Boundary	664,262	4,992,514	586.6	53.5	413
CR1-C30-P	Participant	Boundary	661,978	4,989,318	612.8	52.8	633
CR1-C20-P	Participant	Boundary	662,024	4,987,612	604.2	52.5	640
CR1-C42-P	Participant	Boundary	659,828	4,992,807	580.1	52.4	604
CR1-C19-P	Participant	Boundary	660,393	4,987,529	608.4	51.7	784
CR2-C150-P	Participant	Boundary	655,905	4,985,521	600.0	51.6	636
CR1-C51-P	Participant	Boundary	657,753	4,994,889	620.0	51.5	564
CR1-C17-P	Participant	Boundary	658,819	4,986,842	611.4	51.3	909
CR1-C64-P	Participant	Boundary	659,426	4,992,800	576.6	50.9	728
CR1-C50-P	Participant	Boundary	656,239	4,994,042	618.0	49.6	984
CR1-C35-P	Participant	Boundary	661,955	4,990,153	606.1	48.6	1,112
CR1-C47-P	Participant	Boundary	663,454	4,992,888	612.0	46.7	1,076
CR1-C36-P	Participant	Boundary	663,116	4,990,548	610.7	46.3	1,293
CR1-C57-P	Participant	Boundary	656,526	4,995,198	616.1	45.6	1,319
CR1-C26-P	Participant	Boundary	658,015	4,987,993	606.7	44.9	1,867
CR1-C56-P	Participant	Boundary	656,199	4,995,194	603.0	44.8	1,726
CR1-C18-P	Participant	Boundary	663,578	4,987,413	609.4	42.9	2,566
CR1-C6-P	Participant	Boundary	663,383	4,994,502	591.0	38.6	3,878
CR1-C49-P	Participant	Boundary	662,224	4,993,664	609.0	38.2	5,105
CR1-C10-P	Participant	Boundary	662,862	4,985,695	601.7	38.1	4,150
CR1-C8-P	Participant	Boundary	660,476	4,984,821	597.0	36.9	6,086
CR1-C11-P	Participant	Boundary	663,622	4,985,714	608.8	36.6	5,397
CR1-C59-P	Participant	Boundary	660,756	5,000,883	591.5	32.5	6,155
CR1-C37-NP	Non-P	Structure	663,563	4,991,342	605.1	44.9	1,631
CR1-C46-NP	Non-P	Structure	655,802	4,993,540	609.1	44.5	1,795
CR1-C41-NP	Non-P	Structure	665,053	4,992,084	576.1	44.4	2,356
CR1-C31-NP	Non-P	Structure	665,939	4,988,950	585.4	44.3	2,126
CR1-C44-NP	Non-P	Structure	665,076	4,993,095	578.2	44.2	2,155
CR1-C14-NP	Non-P	Structure	657,982	4,985,894	609.0	44.2	1,880
CR1-C62-NP	Non-P	Structure	658,375	4,995,138	615.0	44.0	1,676
CR1-C34-NP	Non-P	Structure	658,661	4,990,389	588.2	43.4	2,093
CR1-C107-NP	Non-P	Structure	656,811	4,999,855	598.8	43.2	1,401
CR1-C16-NP	Non-P	Structure	661,960	4,986,288	606.0	42.2	2,648

Table B-3: Crowned Ridge 200 MW Sound Level Tabular Results Sorted by Sound Level

Realistic case sound results at land parcel boundaries and occupied structures

Results using GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's

LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)

UTM NAD83 Zone 14

Codington County

continued

Receptor ID	Participation Status	Type	Easting (m)	Northing (m)	Elevation AMSL (m)	Real Case Sound (dB(A))	Distance to Nearest Turbine (ft)
CR1-C40-NP	Non-P	Structure	657,865	4,991,818	583.7	42.1	2,690
CR1-C39-NP	Non-P	Structure	660,144	4,991,670	588.0	42.1	2,605
CR1-C63-NP	Non-P	Structure	658,566	4,995,254	612.4	42.0	2,408
CR1-C29-NP	Non-P	Structure	666,572	4,988,867	575.9	42.0	2,457
CR1-C28-NP	Non-P	Structure	665,429	4,988,598	590.9	42.0	2,831
CR1-C71-NP	Non-P	Structure	665,137	4,988,378	595.6	41.3	3,448
CR1-C38-NP	Non-P	Structure	660,639	4,991,557	597.0	41.1	3,474
CR1-C70-NP	Non-P	Structure	665,135	4,988,293	595.9	41.0	3,540
CR1-C12-1-NP	Non-P	Structure	662,199	4,986,047	606.0	40.8	2,956
CR1-C72-NP	Non-P	Structure	665,158	4,988,170	594.6	40.4	3,776
CR1-C61-NP	Non-P	Structure	656,690	4,997,831	612.0	40.3	2,405
CR1-C52-NP	Non-P	Structure	654,924	4,995,231	603.0	40.2	3,159
CR1-C105-NP	Non-P	Structure	658,372	5,001,257	600.3	39.8	2,549
CR1-C3-NP	Non-P	Structure	657,888	4,984,697	604.2	39.4	3,294
CR1-C55-NP	Non-P	Structure	660,914	4,995,169	607.5	39.2	3,360
CR1-C12-NP	Non-P	Structure	662,222	4,985,736	603.0	39.1	3,921
CR1-C60-NP	Non-P	Structure	656,855	4,998,565	613.5	38.7	3,120
CR1-C110-NP	Non-P	Structure	654,385	4,996,686	593.9	38.7	2,910
CR1-C15-NP	Non-P	Structure	663,291	4,986,026	615.0	38.5	3,907
CR1-C67-NP	Non-P	Structure	659,789	4,985,057	606.0	38.1	5,791
CR1-C27-NP	Non-P	Structure	656,876	4,988,683	583.0	38.1	5,974
CR1-C66-NP	Non-P	Structure	659,718	4,985,032	606.0	38.0	5,800
CR1-C65-NP	Non-P	Structure	665,805	4,995,305	579.0	37.8	3,884
CR1-C112-NP	Non-P	Structure	660,002	4,984,908	604.6	37.4	6,207
CR1-C5-NP	Non-P	Structure	659,958	4,984,794	604.8	37.0	6,601
CR1-C4-NP	Non-P	Structure	659,744	4,984,749	606.0	36.9	6,706
CR1-C33-NP	Non-P	Structure	656,839	4,990,404	569.8	36.9	7,418
CR1-C7-NP	Non-P	Structure	660,893	4,984,861	593.2	36.8	5,932
CR1-C58-NP	Non-P	Structure	657,781	4,996,906	615.0	36.8	5,384
CR1-C2-NP	Non-P	Structure	658,791	4,984,483	602.0	36.6	6,273
CR1-C13-NP	Non-P	Structure	663,792	4,985,785	612.0	36.4	5,643
CR1-C54-NP	Non-P	Structure	663,421	4,995,376	583.4	36.1	5,351
CR1-C111-NP	Non-P	Structure	653,857	4,995,573	591.0	35.9	4,564
CR1-C109-NP	Non-P	Structure	653,780	4,996,828	588.0	35.7	4,797
CR1-C32-NP	Non-P	Structure	655,843	4,989,581	568.8	35.0	9,708
CR1-C1-NP	Non-P	Structure	656,743	4,983,525	596.0	34.6	5,541
CR1-C53-NP	Non-P	Structure	663,376	4,996,043	578.8	34.5	7,201
CR1-C45-NP	Non-P	Structure	653,390	4,993,503	573.2	34.0	5,673

Table B-3: Crowned Ridge 200 MW Sound Level Tabular Results Sorted by Sound Level

Realistic case sound results at land parcel boundaries and occupied structures

Results using GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's

LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)

UTM NAD83 Zone 14

Grant County

continued

Receptor ID	Participation Status	Type	Easting (m)	Northing (m)	Elevation AMSL (m)	Real Case Sound (dB(A))	Distance to Nearest Turbine (ft)
CR1-G68-NP	Non-P	Structure	669,159	4,993,632	565.6	44.5	2,113
CR1-G23-NP	Non-P	Structure	670,471	4,992,104	560.0	44.1	2,185
CR1-G16-NP	Non-P	Structure	668,419	4,989,861	576.0	43.0	2,070
CR1-G34-NP	Non-P	Structure	671,320	4,995,798	531.0	42.0	2,238
CR1-G14-NP	Non-P	Structure	668,156	4,989,332	574.1	39.2	3,940
CR1-G13-NP	Non-P	Structure	672,216	4,989,142	558.0	38.3	3,576
CR1-G12-NP	Non-P	Structure	668,229	4,989,039	575.0	38.0	4,623
CR1-G37-NP	Non-P	Structure	668,998	4,996,452	549.0	36.5	5,246
CR1-G22-NP	Non-P	Structure	674,670	4,991,955	527.6	34.9	5,781
CR1-G42-NP	Non-P	Structure	670,566	4,997,097	518.9	34.7	6,476
CR1-G36-NP	Non-P	Structure	673,559	4,996,344	498.0	34.1	6,483
CR1-G43-NP	Non-P	Structure	661,141	5,001,721	583.6	32.2	6,552
CR1-G117-NP	Non-P	Structure	663,801	5,005,084	581.3	32.1	4,501
CR1-G44-NP	Non-P	Structure	661,781	5,001,732	583.7	31.7	6,939
CR1-G77-NP	Non-P	Structure	676,031	4,992,629	502.7	31.1	8,878
CR1-G105-NP	Non-P	Structure	668,696	4,998,325	549.0	30.9	11,263
CR1-G27-NP	Non-P	Structure	676,630	4,994,642	480.8	29.7	8,678
CR1-G130-NP	Non-P	Structure	668,147	5,000,233	549.0	28.2	17,756
CR1-G109-NP	Non-P	Structure	667,064	5,000,425	566.2	28.2	19,704
CR1-G125-NP	Non-P	Structure	668,289	5,000,643	543.0	27.7	18,888
CR1-G70-NP	Non-P	Structure	677,465	4,991,043	492.0	27.6	15,006
CR1-G115-NP	Non-P	Structure	664,933	5,006,731	544.6	27.3	10,531
CR1-G113-NP	Non-P	Structure	666,228	5,005,549	537.0	26.4	12,575
CR1-G114-NP	Non-P	Structure	666,214	5,006,667	521.1	25.9	13,878
CR1-G110-NP	Non-P	Structure	671,218	5,005,064	456.2	23.5	28,615
CR1-G600-NP	Non-P	Structure	674,301	5,005,773	393.0	21.8	36,397
CR1-G65-P	Participant	Structure	671,496	4,994,973	537.0	46.9	1,539
CR1-G32-P	Participant	Structure	669,477	4,995,401	546.0	46.7	1,545
CR1-G18-P	Participant	Structure	668,678	4,990,722	585.0	46.6	1,585
CR1-G21-P	Participant	Structure	666,766	4,991,807	577.1	46.2	1,555
CR1-G66-P	Participant	Structure	670,802	4,994,681	539.7	45.6	1,801
CR1-G25-P	Participant	Structure	671,391	4,992,858	549.0	45.4	1,804
CR1-G19-P	Participant	Structure	671,018	4,990,744	570.0	45.0	2,077
CR1-G67-P	Participant	Structure	669,597	4,993,440	556.1	44.7	2,106
CR1-G28-P	Participant	Structure	673,113	4,994,772	513.9	44.7	1,614
CR1-G24-P	Participant	Structure	673,058	4,992,440	539.4	42.0	2,231
CR1-G33-P	Participant	Structure	668,911	4,995,550	548.7	41.2	2,779
CR1-G26-P	Participant	Structure	672,589	4,993,869	531.0	41.2	3,140

Table B4: Crowned Ridge 200 MW Sound Level Tabular Results Sorted by Sound Level

Realistic case sound results 25 ft from occupied structures perimeter

Results using GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's

LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)

UTM NAD83 Zone 14

Codington County

Receptor ID	Participation Status	Easting (m)	Northing (m)	Elevation AMSL (m)	Real Case Sound (dB(A))	Distance to Nearest Turbine (ft)
CR1-C37-NP	Non-P	663,563	4,991,342	605.1	45.0	1,631
CR1-C46-NP	Non-P	658,661	4,990,389	588.2	44.6	1,795
CR1-C31-NP	Non-P	656,811	4,999,855	598.8	44.5	2,126
CR1-C41-NP	Non-P	654,924	4,995,231	603.0	44.5	2,356
CR1-C14-NP	Non-P	658,375	4,995,138	615.0	44.3	1,880
CR1-C44-NP	Non-P	655,802	4,993,540	609.1	44.3	2,155
CR1-C62-NP	Non-P	665,053	4,992,084	576.1	44.2	1,676
CR1-C34-NP	Non-P	657,982	4,985,894	609.0	43.5	2,093
CR1-C107-NP	Non-P	665,352	4,985,004	609.0	43.4	1,401
CR1-C16-NP	Non-P	657,781	4,996,906	615.0	42.3	2,648
CR1-C29-NP	Non-P	658,372	5,001,257	600.3	42.2	2,457
CR1-C40-NP	Non-P	658,566	4,995,254	612.4	42.2	2,690
CR1-C28-NP	Non-P	662,222	4,985,736	603.0	42.1	2,831
CR1-C39-NP	Non-P	661,960	4,986,288	606.0	42.1	2,605
CR1-C63-NP	Non-P	663,291	4,986,026	615.0	42.1	2,408
CR1-C71-NP	Non-P	660,144	4,991,670	588.0	41.4	3,448
CR1-C38-NP	Non-P	657,865	4,991,818	583.7	41.2	3,474
CR1-C70-NP	Non-P	656,855	4,998,565	613.5	41.1	3,540
CR1-C12-1-NP	Non-P	665,939	4,988,950	585.4	41.0	2,956
CR1-C61-NP	Non-P	665,137	4,988,378	595.6	40.5	2,405
CR1-C72-NP	Non-P	665,429	4,988,598	590.9	40.5	3,776
CR1-C52-NP	Non-P	665,135	4,988,293	595.9	40.3	3,159
CR1-C105-NP	Non-P	665,158	4,988,170	594.6	39.9	2,549
CR1-C3-NP	Non-P	660,914	4,995,169	607.5	39.5	3,294
CR1-C55-NP	Non-P	660,639	4,991,557	597.0	39.5	3,360
CR1-C12-NP	Non-P	663,792	4,985,785	612.0	39.1	3,921
CR1-C110-NP	Non-P	654,385	4,996,686	593.9	38.8	2,910
CR1-C60-NP	Non-P	660,893	4,984,861	593.2	38.8	3,120
CR1-C15-NP	Non-P	662,199	4,986,047	606.0	38.6	3,907
CR1-C27-NP	Non-P	659,958	4,984,794	604.8	38.2	5,974
CR1-C67-NP	Non-P	657,888	4,984,697	604.2	38.1	5,791
CR1-C66-NP	Non-P	659,789	4,985,057	606.0	38.0	5,800
CR1-C65-NP	Non-P	665,805	4,995,305	579.0	37.9	3,884
CR1-C112-NP	Non-P	659,718	4,985,032	606.0	37.5	6,207
CR1-C33-NP	Non-P	653,780	4,996,828	588.0	37.0	7,418
CR1-C4-NP	Non-P	653,857	4,995,573	591.0	37.0	6,706
CR1-C5-NP	Non-P	660,002	4,984,908	604.6	37.0	6,601
CR1-C58-NP	Non-P	656,876	4,988,683	583.0	36.9	5,384
CR1-C7-NP	Non-P	666,572	4,988,867	575.9	36.8	5,932

Table B4: Crowned Ridge 200 MW Sound Level Tabular Results Sorted by Sound Level

Realistic case sound results 25 ft from occupied structures perimeter

Results using GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's

LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)

UTM NAD83 Zone 14

Codington County

continued

Receptor ID	Participation Status	Easting (m)	Northing (m)	Elevation AMSL (m)	Real Case Sound (dB(A))	Distance to Nearest Turbine (ft)
CR1-C2-NP	Non-P	659,744	4,984,749	606.0	36.7	6,273
CR1-C13-NP	Non-P	665,076	4,993,095	578.2	36.5	5,643
CR1-C54-NP	Non-P	663,421	4,995,376	583.4	36.2	5,351
CR1-C111-NP	Non-P	658,791	4,984,483	602.0	36.0	4,564
CR1-C109-NP	Non-P	656,839	4,990,404	569.8	35.8	4,797
CR1-C32-NP	Non-P	655,843	4,989,581	568.8	35.1	9,708
CR1-C1-NP	Non-P	663,376	4,996,043	578.8	34.7	5,541
CR1-C53-NP	Non-P	653,390	4,993,503	573.2	34.5	7,201
CR1-C45-NP	Non-P	656,743	4,983,525	596.0	34.0	5,673
CR1-C9-NP	Non-P	656,690	4,997,831	612.0	32.5	11,283
CR1-C30-P	Participant	661,699	4,988,957	615.0	49.5	1,614
CR1-C19-P	Participant	659,243	4,987,276	611.6	48.1	1,722
CR2-C150-P	Participant	657,178	4,985,788	612.0	47.4	1,640
CR1-C50-P	Participant	656,806	4,994,388	621.0	47.1	1,591
CR1-C68-P	Participant	663,181	4,990,600	615.0	46.6	2,146
CR1-C69-P	Participant	662,652	4,987,606	609.0	46.5	2,185
CR1-C17-P	Participant	658,031	4,986,373	609.1	46.4	1,886
CR1-C36-P	Participant	663,510	4,985,195	609.0	45.6	1,532
CR1-C48-P	Participant	662,685	4,987,619	609.0	45.4	1,847
CR1-C35-P	Participant	664,247	4,993,646	588.0	45.0	2,123
CR1-C11-P	Participant	664,111	4,985,679	609.0	44.9	6,676
CR1-C20-P	Participant	655,953	4,995,244	606.5	44.9	2,336
CR1-C57-P	Participant	656,628	4,995,266	615.0	44.8	1,568
CR1-C51-P	Participant	659,458	4,992,229	580.0	44.3	1,768
CR1-C56-P	Participant	659,436	4,992,174	581.0	44.0	1,972
CR1-C42-P	Participant	663,054	4,987,455	606.0	43.9	2,077
CR1-C64-P	Participant	662,025	4,990,475	609.0	43.5	2,270
CR1-C26-P	Participant	660,755	4,984,082	594.0	41.5	3,484
CR1-C18-P	Participant	661,548	5,000,754	584.2	41.4	3,435
CR1-C47-P	Participant	660,619	4,984,078	595.8	39.3	3,750
CR1-C49-P	Participant	660,532	4,984,445	599.4	38.1	5,148
CR1-C6-P	Participant	662,250	4,993,731	609.0	36.0	6,102
CR1-C8-P	Participant	662,825	4,993,508	613.9	35.6	7,293
CR1-C10-P	Participant	657,455	4,995,160	621.0	35.3	6,535
CR1-C23-P	Participant	657,767	4,988,493	597.0	34.6	8,478
CR1-C21-P	Participant	663,651	4,987,157	610.4	34.5	8,445
CR1-C22-P	Participant	660,756	4,984,086	594.0	34.5	8,458
CR1-C59-P	Participant	662,989	4,995,228	599.8	31.3	8,720

Table B4: Crowned Ridge 200 MW Sound Level Tabular Results Sorted by Sound Level

Realistic case sound results 25 ft from occupied structures perimeter

Results using GE 2.3-116-90 m HH, GE 2.3-116-80 m HH WTG's

LNTE run with on 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95 (new) and 20, 22, 24, 25, 31, 32, 36, 53 (existing)

UTM NAD83 Zone 14

Grant County

continued

Receptor ID	Participation Status	Easting (m)	Northing (m)	Elevation AMSL (m)	Real Case Sound (dB(A))	Distance to Nearest Turbine (ft)
CR1-G68-NP	Non-P	669,159	4,993,632	565.6	44.5	2,113
CR1-G23-NP	Non-P	661,141	5,001,721	583.6	44.1	2,185
CR1-G16-NP	Non-P	668,289	5,000,643	543.0	43.0	2,070
CR1-G34-NP	Non-P	670,471	4,992,104	560.0	42.0	2,238
CR1-G14-NP	Non-P	668,419	4,989,861	576.0	39.2	3,940
CR1-G13-NP	Non-P	671,320	4,995,798	531.0	38.3	3,576
CR1-G12-NP	Non-P	666,214	5,006,667	521.1	38.0	4,623
CR1-G37-NP	Non-P	664,933	5,006,731	544.6	36.5	5,246
CR1-G22-NP	Non-P	666,228	5,005,549	537.0	34.9	5,781
CR1-G42-NP	Non-P	667,064	5,000,425	566.2	34.7	6,476
CR1-G36-NP	Non-P	661,781	5,001,732	583.7	34.1	6,483
CR1-G43-NP	Non-P	668,147	5,000,233	549.0	32.2	6,552
CR1-G117-NP	Non-P	668,156	4,989,332	574.1	32.1	4,501
CR1-G44-NP	Non-P	670,566	4,997,097	518.9	31.7	6,939
CR1-G77-NP	Non-P	672,216	4,989,142	558.0	31.1	8,878
CR1-G105-NP	Non-P	668,229	4,989,039	575.0	30.9	11,263
CR1-G27-NP	Non-P	668,998	4,996,452	549.0	29.7	8,678
CR1-G109-NP	Non-P	673,559	4,996,344	498.0	28.2	19,704
CR1-G130-NP	Non-P	663,801	5,005,084	581.3	28.2	17,756
CR1-G125-NP	Non-P	668,696	4,998,325	549.0	27.7	18,888
CR1-G70-NP	Non-P	674,670	4,991,955	527.6	27.6	15,006
CR1-G115-NP	Non-P	671,218	5,005,064	456.2	27.3	10,531
CR1-G113-NP	Non-P	676,630	4,994,642	480.8	26.4	12,575
CR1-G114-NP	Non-P	676,031	4,992,629	502.7	25.9	13,878
CR1-G110-NP	Non-P	677,465	4,991,043	492.0	23.5	28,615
CR1-G600-NP	Non-P	674,301	5,005,773	393.0	21.8	36,397
CR1-G65-P	Participant	671,496	4,994,973	537.0	46.9	1,539
CR1-G32-P	Participant	669,477	4,995,401	546.0	46.7	1,545
CR1-G18-P	Participant	668,678	4,990,722	585.0	46.6	1,585
CR1-G21-P	Participant	666,766	4,991,807	577.1	46.2	1,555
CR1-G66-P	Participant	670,802	4,994,681	539.7	45.6	1,801
CR1-G25-P	Participant	671,391	4,992,858	549.0	45.4	1,804
CR1-G19-P	Participant	671,018	4,990,744	570.0	45.0	2,077
CR1-G28-P	Participant	673,113	4,994,772	513.9	44.7	1,614
CR1-G67-P	Participant	669,597	4,993,440	556.1	44.7	2,106
CR1-G24-P	Participant	670,242	5,001,314	513.0	42.0	2,231
CR1-G26-P	Participant	668,616	5,005,161	504.0	41.2	3,140
CR1-G33-P	Participant	669,843	5,000,605	525.0	41.2	2,779

