

LAW OFFICES

**Lynn, Jackson, Shultz & Lebrun, P.C.**

LAWYERS ALSO ADMITTED IN MINNESOTA, IOWA, NORTH DAKOTA, AND WYOMING  
www.lynnjackson.com

110 N. MINNESOTA AVENUE  
SUITE 400  
SIOUX FALLS, SD 57104  
605-332-5999  
FAX 605-332-4249

135 E. COLORADO BOULEVARD  
SPEARFISH, SD 57783-2755  
605-722-9000  
FAX 605-722-9001

909 ST. JOSEPH STREET  
SUITE 800  
RAPID CITY, SD 57701  
605-342-2592  
FAX 605-342-5185

REPLY TO: Sioux Falls 605-332-5999

*From the office of Miles F. Schumacher*

*e-mail address: mschumacher@lynnjackson.com*

January 6, 2020

**Via Electronic Filing**

Ms. Patricia Van Gerpen  
Executive Director  
South Dakota Public Utilities Commission  
500 East Capitol Avenue  
Pierre, SD 57501

Re: Docket #EL19-003; Application to the SD PUC for a Facility Permit to  
Construct  
A 300 megawatt Wind Facility

Dear Ms. Van Gerpen:


Crowned Ridge Wind is filing this letter to clarify that January 3, 2020 sound model showed that the following turbines need to be curtailed at CR1-29, CR1-44, CR1-48, and CR1-95 at wind speeds above 6 meters per second prior to the installation of LNTes on CR1-21, CR1-29, CR1-33, CR1-37, CR1-41, CR1-44, CR1-46, CR1-48, CR1-50, CR1-52, CR1-61, CR1-63, CR1-64, CR1-66, and CR1-95 (collectively referred to as the "Mitigation Plan"). Mr. Haley affidavit in Attachment 3 of the January 3, 2020 Response sets forth this mitigation. The Response itself inadvertently included CR1-21 and CR1-37 that do not need to be curtailed. The reason that the number of turbines are reduced from 6 to 4 in the January 3, 2020 model run versus the December 13, 2019 model run is because Mr. Haley backed out the alternative turbines that were not constructed from the January 3<sup>rd</sup> run. The reason the curtailment wind speed was reduced was because upon checking his results of the December 13, 2019 model run, he confirmed that curtailment would need to be a 6 meters per second, and not 9 meters per second to achieve the sound reductions necessary to be in compliance with the Condition 26 sound thresholds.

Ms. Patricia Van Gerpen  
January 6, 2020  
Page 2

If you have any questions, please contact me.

Yours very truly,

LYNN, JACKSON, SHULTZ & LEBRUN, P.C.



Miles F. Schumacher  
MFS:kab  
Enclosure