

Amber Christenson Impacts:

Exhibit #	Page #	Elevation	Hessler Sound	Real Case Sound	Change	Flicker	Distance	S=Structure B=Boundary	
County Application				44.2			1,952	<b>B</b>	
County Application						6:56	2,457	S	
A1-H	21	573.9		42.7			1,952	B	
A1-H	23	575.9		41.4			1,952	S	(Distance Typo)
A1-l	21	575.9				6:54	2,457	S	
A1-l	25	575.9				6:54	2,457	S	
A8	10	573.9		42.7			1,952	B	
A8	12	575.9		41.4			2,457	S	
A8	17	573.9		42.7			1,952	B	
A8	19	575.9		41.3			2,457	S	
A9	10	575.9				6:54	2,457	S	
A9	15	575.9				6:54	2,457	S	
A22-2	1	573.9		42.7			1,952	B	
A22-2	3	575.9		41.9			2,457	S	
A22-2	8	573.9		42.7			1,952	B	
A22-2	10	575.9		41.4			2,457	S	
A22-3	10	575.9				6:54	2,457	S	
A26	4			41.4			2,457		
A26	4					6:54	2,457		
A22-3	15	575.9				6:54	2,457	S	
A43-3	1	575.9		41.5			2,457	S	
A43-4	1	575.9	38.7	41.4	-2.7		2,457	S	w/Hessler 16 removed



CR2 JH-S-1 Sound 9/20/19	22	574.3		42.4			1,952	B	
CR2 JH-S-2 Flicker 9/20/19	21	575.9				6:54	2,457	S	
CR2 JH-S-3 Sound 9/20/19 200mw	1	574.3		42.4			1,952	B	
CR2 JH-S-4 Flicker 9/20/19 200mw	1	575.9				6:54	2,457	S	
<b>Waiver</b>									
Haley Attachment 1 Table A-2 12/13/19	5	574.3		43.7			1,952	B	200MW, Curtail 8 turbines
Haley Attachment 1 Table A-2 12/13/19	7	575.9		42.1			2,457	S	200MW, Curtail 8 turbines
Haley Attachment 1 Table A-3 12/13/19	11	574.3		43.7			1,952	B	200MW, Curtail 8 turbines
Haley Attachment 1 Table A-3 12/13/19	13	575.9		42.1			2,457	S	200MW, Curtail 8 turbines
Haley Attachment 1 Table A-4 12/13/19	17	600.3		42.2			2,457	-25' Structure	200MW, Curtail 8 turbines
Haley Attachment 2 Table B-2 12/13/19	5	574.3		43.6			1,952	B	LNTE 23 turbines
Haley Attachment 2 Table B-2 12/13/19	7	575.9		42.0			2,457	S	LNTE 23 turbines
Haley Attachment 2 Table B-3 12/13/19	11	574.3		43.6			1,952	B	LNTE 23 turbines
Haley Attachment 2 Table B-3 12/13/19	13	575.9		42.0			2,457	S	LNTE 23 turbines
Haley Attachment 2 Table B-4 12/13/19	17	600.3		42.2			2,457	-25' Structure	LNTE 23 turbines
Staff Memorandum 12/18/19	2			40.6			4,675	S?	LNTE All Turbines
Staff Memorandum 12/18/19	2			42.2	+1.6		4,675	S?	Curtailment of 8 turbines

Staff Memorandum Attachment B 12/18/19	1	600.3		42.2			2,457	S	Curtailed of 8 turbines
Staff Memorandum Attachment B 12/18/19	1	600.3		42.2			2,457	S	LNTE 23 turbines
Staff Memorandum Attachment B 12/18/19	1	600.3		40.6			2,457	S	All LNTE
Staff Memorandum Attachment C 12/18/19	1			42.2			4,675	S?	Curtailed of 8 turbines
Staff Memorandum Attachment C 12/18/19	1			42.2			4,675	S?	LNTE 23 turbines
Staff Memorandum Attachment C 12/18/19	1			40.6			4,675	S?	All LNTE
CR Response to Intervenors Compaaints Attachment 1 Table A-2 1/3/20	5	574.3		40.0			4,232	B	Curtailed 8 turbines Also curtailed 29,44,48.95? Attenuation .5
CR Response to Intervenors Complaints Attachment 1 Table A-2 1/3/20	7	575.9		39.3			4,675	S	Curtailed 8 turbines Also curtailed 29,44,48.95? Attenuation .5
CR Response to Intervenors Complaints Attachment 1 Table A-3 1/3/20	11	574.3		39.0			4,232	B	Curtailed 8 turbines Also curtailed 29,44,48.95? Attenuation .5

CR Response to Intervenor Complaints Attachment 1 Table A-3 1/3/20	13	575.9		38.3			4,675	S	Curtailed 8 turbines Also curtailed 29,44,48.95? Attenuation .5
CR Response to Intervenor Complaints Attachment 2 1/3/20	2			41.1			4,675	S	Curtailed Noise Attenuation .0
CR Response to Intervenor Complaints Attachment 2 1/3/20	2			39.3			4,675	S	Curtailed Noise Attenuation .3
CR Response to Intervenor Complaints Attachment 2 1/3/20	2			38.4			4,675	S	Curtailed Noise Attenuation .5
CR Response to Intervenor Complaints Attachment 2 1/3/20	2			38.3			4,675	S	23 LNTEs Attenuation Not Provided
CR Response to Intervenor Complaints Attachment 2 1/3/20	2			37.1			4,675	S	All LNTEs Attenuation Not Provided

CR Response to Intervenor Complaints Attachment 2 1/3/20	2					0:00	4,675	S	87 turbines as built Flicker
CR Response to Intervenor Complaints Attachment 2 1/3/20	2					6:56	4,675	S	7/29/19 Flicker Filing
CR Response to Intervenor Complaints Attachment 5 Table C-1 1/3/20	2	575.9				0:00	<b>1,425 ??</b>	<b>S ??</b>	200MW as built Flicker
CR Response to Intervenor Complaints Attachment 5 Table C-1 1/3/20	2	575.9				6:56	<b>1,425 ??</b>	<b>S ??</b>	300MW as filed 7/29/19 Flicker
CR Response to Intervenor Complaints Attachment 5 Table C-2 1/3/20	5	575.9				0:00	4,675		200MW as built Flicker
CR Response to Intervenor Complaints Attachment 5 Table C-2 1/3/20	7	575.9				6:56	4,675		300MW as filed 7/29/19 Flicker

