

LAW OFFICES

**Lynn, Jackson, Shultz & Lebrun, P.C.**

LAWYERS ALSO ADMITTED IN MINNESOTA, IOWA, NORTH DAKOTA, AND WYOMING

[www.lynnjackson.com](http://www.lynnjackson.com)

110 N. MINNESOTA AVENUE  
SUITE 400  
SIOUX FALLS, SD 57104  
605-332-5999  
FAX 605-332-4249

135 E. COLORADO BOULEVARD  
SPEARFISH, SD 57783-2755  
605-722-9000  
FAX 605-722-9001

909 ST. JOSEPH STREET  
SUITE 800  
RAPID CITY, SD 57701  
605-342-2592  
FAX 605-342-5185

REPLY TO: Sioux Falls 605-332-5999

*From the office of Miles F. Schumacher*

*e-mail address: [mschumacher@lynnjackson.com](mailto:mschumacher@lynnjackson.com)*

June 24, 2020

Ms. Patricia Van Gerpen, Executive Director  
South Dakota Public Utilities Commission  
Capital Building, 1<sup>st</sup> Floor  
500 East Capital Avenue  
Pierre, SD 57501-5070

Re: Docket No. EL19-003  
Application to the SD PUC for a Facility Permit to Construct  
A 300 Megawatt Wind Facility

Dear Ms. Van Gerpen:

Crowned Ridge Wind, LLC ("Crowned Ridge") submits this notification that it anticipates the attachment of low noise tailing edges ("LNTE") will be completed as of June 30, 2020, on the following 15 wind turbines: 21, 29, 33, 37, 41, 44, 46, 48, 50, 52, 61, 63, 64, 66, and 95.

As Crowned Ridge's request for a Temporary Waiver showed, under the Commission ordered use of a ground attenuation factor of 0.3 to perform the sound study, once LNTEs were installed on the above 15 wind turbines, the following 16 wind turbines no longer needed to be curtailed to ensure compliance with the Commission's sound thresholds set forth in the Final Order: 20, 21, 29, 33, 37, 39, 46, 48, 50, 52, 62, 73, 75, 95, 109, and 114. Therefore, once the LNTE installations are completed on or about June 30, 2020, these 16 wind turbines will no longer be curtailed.

Ms. Patricia Van Gerpen  
June 24, 2020  
Page 2

If you have any questions, please contact me.

Yours very truly,

LYNN, JACKSON, SHULTZ & LEBRUN, P.C.

*/s/ Miles F. Schumacher*

Miles F. Schumacher