

EXHIBIT B

Summary of Turbine Adjustments Up to 250 Feet

Turbine Number	Turbine Shift Distance (ft)	Turbine Shift Direction	Distance to nearest residence (ft) ¹	Type of residence	Distance to nearest road (ft) ²	Distance to nearest existing overhead distribution or transmission line (ft) ²	Distance to nearest non-participating parcel (ft) ²
34	68	South	3951.34	Participating	3746.08	15298.26	2662.85
59	40	East	8833.30	Non-Participating	10137.40	20248.16	911.79
77	120	Southwest	2879.72	Participating	2493.98	1531.47	3938.93
78	117	Northwest	2694.07	Participating	2028.21	1517.97	2720.06
79	122	Northwest	2881.75	Participating	2918.14	1368.08	1742.17

¹ Setback requirements – 1,320 feet from currently occupied residences, unless waived in writing

² Setback requirements – 549 feet, unless waived in writing