

EXHIBIT E

Summary of Turbine Adjustments Greater Than 250 Feet From Locations in Revised Figure A-2 (Project Layout Map Filed April 11, 2019)

Turbine Number	Turbine Shift Distance (ft)	Turbine Shift Direction	Distance to nearest residence (ft) ¹	Type of residence	Distance to nearest road (ft) ²	Distance to nearest existing overhead distribution or transmission line (ft) ²	Distance to nearest non-participating parcel (ft) ²
8A	508.5	South	4,741	Participating	5,465	39,457	1,552
9A	744.1	South	3,468	Participating	4,185	38,970	1,547
10A	1,001.2	South	2,223	Participating	2,825	38,227	1,707

¹ Setback requirements – 1,320 feet from currently occupied residences, unless waived in writing
² Setback requirements – 549 feet, unless waived in writing