

EXHIBIT B

Summary of Turbine Adjustment Up to 250 Feet

Turbine Number	Turbine Shift Distance (ft)	Turbine Shift Direction	Distance to nearest residence (ft) ¹	Type of residence	Distance to nearest road (ft) ²	Distance to nearest existing overhead distribution or transmission line (ft) ²	Distance to nearest non-participating parcel (ft) ²
69	85	SW	3,731	Participating	2,429	3,006	1,451

¹ Setback requirements – 1,320 feet from currently occupied residences, unless waived in writing
² Setback requirements – 549 feet, unless waived in writing