

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF SOUTH DAKOTA**

**IN THE MATTER OF THE APPLICATION BY SWEETLAND WIND FARM, LLC
FOR FACILITY PERMITS OF A WIND ENERGY FACILITY AND A 230-KV
TRANSMISSION FACILITY IN HAND COUNTY, SOUTH DAKOTA FOR THE
SWEETLAND WIND FARM PROJECT**

SD PUC DOCKET EL_____

**PRE-FILED DIRECT TESTIMONY OF ROBERT O'NEAL
ON BEHALF OF SWEETLAND WIND FARM, LLC**

March 6, 2019

32 **I. INTRODUCTION AND QUALIFICATIONS**

33

34 **Q. Please state your name, employer, and business address.**

35 A. My name is Robert O’Neal and I work for Epsilon Associates, Inc. (“Epsilon”),
36 located at 3 Mill & Main Place, Suite 250, Maynard, Massachusetts 01754.

37

38 **Q. Briefly describe your educational and professional background and your**
39 **current work for Epsilon.**

40 A. I have more than 30 years of experience in the areas of community noise impact
41 assessments, meteorological data collection and analyses, and air quality
42 modeling. My noise impact evaluation experience includes design and
43 implementation of sound level measurement programs nationwide, modeling of
44 future impacts, conceptual mitigation analyses, and compliance testing. I am a
45 nationally recognized acoustics expert in the wind energy field, having performed
46 noise impact assessments in over 25 states across the U.S. and Canada, and
47 have also directed and reviewed shadow flicker studies for wind energy projects.
48 I have provided expert witness testimony on noise impact studies, shadow flicker
49 issues, and air pollution modeling in front of local boards and courts of law, and
50 in adjudicatory hearings.

51

52 I have a B.A. in Engineering Science from Dartmouth College, and an M.S. in
53 Atmospheric Science from Colorado State University. I am a Certified Consulting
54 Meteorologist, a member of the American Meteorological Society, a member of
55 the Acoustical Society of America, and Board Certified by the Institute of Noise
56 Control Engineering (“INCE”). A copy of my curriculum vitae is provided as
57 **Exhibit A4-1.**

58

59 **Q. What is Epsilon’s role with respect to the Sweetland Wind Farm Project**
60 **(“Project”)?**

61 A. Epsilon conducted sound level and shadow flicker modeling analyses of the
62 Project’s proposed layout, and prepared a Sound Level Assessment Report

63 (“Sound Assessment”) and a Shadow Flicker Analysis Report (“Shadow Flicker
64 Analysis”), which are provided in Appendices L and M, respectively, of the
65 Sweetland Wind Farm, LLC’s (“Applicant” or “Sweetland”) Application for Energy
66 Facility Permits (“Application”) for the Project.

67

68 **II. OVERVIEW**

69

70 **Q. What is the purpose of your testimony?**

71 A. The purpose of my testimony is to discuss the methodology and results of the
72 sound level assessment and shadow flicker modeling analysis Epsilon conducted
73 for the Project. In addition, I will discuss how the modeling demonstrates that the
74 Project will comply with applicable acoustic and shadow flicker regulations and/or
75 commitments made by Sweetland.

76

77 **Q. Please identify which sections of the Application you are sponsoring for 78 the record.**

79 A. I am sponsoring the following sections of the Application:

- 80 • Section 15.3: Sound
- 81 • Section 15.5: Shadow Flicker
- 82 • Appendix L: Sound Level Assessment Report
- 83 • Appendix M: Shadow Flicker Analysis Report

84

85 **III. WIND TURBINE SOUND AND APPLICABLE STANDARDS**

86

87 **Q. Please provide an overview of the sound that may be generated by modern 88 utility-scale wind turbines, such as those that will be used for the Project.**

89 A. Wind turbine noise can originate from two different sources: mechanical sound
90 from the interaction of turbine components, and aerodynamic sound produced by
91 the flow of air over the rotor blades. In addition to the turbines, the transformer
92 located at a wind project’s substation will also emit sound.

93

94 Due to advances in wind turbine design, mechanical noise has been greatly
95 reduced in modern turbines and does not contribute significantly to sound levels
96 outside of the nacelle. Aerodynamic noise has also been reduced due to slower
97 rotational speeds and changes in materials of construction.

98

99 **Q. How are wind turbine sound levels measured?**

100 A. While sound (noise) levels are measured and quantified in several ways, all of
101 them use the logarithmic decibel (“dB”) scale to accommodate the wide range of
102 sound intensities found in the environment. A property of the decibel scale is that
103 the sound pressure levels of two or more separate sounds are not directly
104 additive. For example, if a sound of 50 dB is added to another sound of 50 dB,
105 the total is only a 3-decibel increase (53 dB), which is equal to doubling in sound
106 energy but not equal to a doubling in decibel quantity. Thus, every 3 dB change
107 in sound level represents a doubling or halving of sound energy, and a change in
108 sound levels of less than 3 dB is generally imperceptible to the human ear. Also,
109 if one source of noise is at least 10 dB louder than another source, then the total
110 sound level is simply the sound level of the higher-level source. For example, a
111 sound source at 60 dB plus another sound source at 47 dB is equal to 60 dB.

112

113 A sound level meter is a standardized instrument used to measure sound. It
114 contains “weighting networks” (e.g., A-, C-, Z-weightings) to adjust the frequency
115 response of the instrument. Frequencies, reported in Hertz (“Hz”), are detailed
116 characterizations of sounds, often addressed in musical terms as “pitch” or
117 “tone.” The most commonly used weighting network is the A-weighting because
118 it most closely approximates how the human ear responds to sound at various
119 frequencies (in the 20 to 20,000 Hz range). The A-weighting network, which
120 reports in decibels designated as “dBA,” is the accepted scale used for
121 community sound level measurements.

122

123 Sounds in the environment vary with time, and the two sound level metrics that
124 are commonly reported in community noise monitoring are:

- 125 • L_{90} , which is the sound level in dBA exceeded 90 percent of the time
126 during a measurement period. The L_{90} is close to the lowest sound level
127 observed. It is essentially the same as the “residual” sound level, which is
128 the sound level observed when there are no obvious nearby intermittent
129 noise sources.
- 130 • L_{eq} , the equivalent level, is the level of a hypothetical steady sound that
131 would have the same energy (i.e., the same time-averaged mean square
132 sound pressure) as the actual fluctuating sound observed. The equivalent
133 level is designated L_{eq} and is commonly A-weighted. The equivalent level
134 represents the time average of the fluctuating sound pressure, but
135 because sound is represented on a logarithmic scale and the averaging is
136 done with time-averaged mean square sound pressure values, the L_{eq} is
137 mostly determined by occasional loud noises.

138

139 **Q. Please explain what sound level metrics you believe are appropriate for a**
140 **permit condition for sound?**

141 A. The L_{eq} is the appropriate sound level metric for a permit condition for sound.
142 The L_{eq} is directly comparable to the model output of the pre-construction
143 predictive models since, by standard, the models use L_{eq} input sound data as
144 provided by the manufacturers of wind turbines.

145

146 **Q. How does the sound from wind turbines fit within the range of sound**
147 **audible to humans?**

148 A. The sound levels at the base of a modern utility-scale wind turbine are typically
149 between 55 and 60 dBA when the wind turbine is operating at full power. By
150 comparison, normal conversation between two people is 55–65 dBA when they
151 are about three feet apart. Therefore, one can hold a conversation at the base of
152 an operating wind turbine. Sound levels decrease with distance away from a
153 wind turbine. At 50 dBA, it would sound approximately half as loud as
154 conversational speech, and between 30 and 40 dBA it is comparable to sound
155 levels in a quiet rural area.

156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185

Q. Are you aware of any federal or state sound level regulations for wind energy facilities located in South Dakota?

A. There are no federal sound level regulations specific to wind energy facilities. Also, it is my understanding that the State of South Dakota does not have statutes or rules governing sound level requirements for wind energy facilities.

Q. Has Hand County established a sound level requirement for wind energy facilities to be located in that county?

A. Hand County has not adopted sound level requirements for wind farms and transmission facilities. However, Sweetland has entered into a Development Agreement with Hand County, which includes sound level requirements for the Project. Specifically, the Development Agreement provides that sound levels resulting from Project wind turbines will not exceed 50 dBA at the currently occupied residences of participating landowners and 45 dBA at the currently occupied residences of non-participating landowners, unless waived in writing by the owner of the occupied residence.

IV. ACOUSTIC ANALYSIS

Q. Was the Sound Assessment provided as Appendix L to the Application prepared by you or under your supervision and control?

A. Yes.

Q. What was the purpose of the acoustic modeling and assessment?

A. The purpose was to conservatively model the sound level to be produced by the Project and to confirm the Project will comply with applicable sound limits established pursuant to the Applicant's Development Agreement with Hand County.

186 **Q. Who provided the turbine model, turbine layout, and receptors to be used**
187 **when conducting the acoustic modeling for the Project?**

188 A. Applicant provided the turbine model (General Electric (“GE”) 2.82/127¹ with a
189 hub height of 89 or 114 meters),² the proposed layout with up to 71 primary
190 turbine locations and 15 alternate locations, and the receptor dataset (41
191 currently occupied residences in proximity of the Project).

192
193 **Q. Are the turbine model and turbine layout the same as depicted in Figure A-**
194 **2 of the Application?**

195 A. Yes.

196
197 **Q. Could you provide an overview of the methodology used in conducting the**
198 **acoustic modeling analysis for the Project?**

199 A. A conservative prediction of sound levels associated with the Project was made
200 using Cadna/A noise calculation software, which is commonly used in the
201 industry for sound modeling. This software incorporates the ISO 9613-2
202 international standard for sound propagation (Acoustics – Attenuation of sound
203 during propagation outdoors – Part 2: General method of calculation).

204
205 In addition to the turbine model specifications, proposed Project layout, and the
206 receptor locations discussed above, inputs and significant parameters employed
207 in the model included:

- 208 • Project Layout: All 86 possible turbine locations were modeled (including
209 71 primary turbine locations and 15 alternate turbine locations) as well as
210 the two substation transformers. A total of 64 primary and 9 alternate
211 turbines are proposed to have a hub height of 114 meters, and a total of 7
212 primary and 6 alternate turbines are proposed to have a hub height of 89

¹ Two of the turbines (Turbines 42 and 43 as shown on Figure A-2 of the Application) will be GE 2.82-127 Low Noise Trailing Edge (“LNTE”) units.

² A total of 64 primary and 9 alternate wind turbines are proposed to have a hub height of 114 meters and a total of 7 primary and 6 alternate wind turbines are proposed to have a hub height of 89 meters.

213 meters. The hub height of each turbine in the layout is included in
214 Appendix A of the Sound Assessment. Two of the turbines will be GE
215 2.82-127 LNTE units. Specific locations of the transformers were not
216 provided, so Epsilon conservatively modeled them on the north side of the
217 substation area closest to the nearest modeling receptor.

218 • Parcel Participation: A dataset containing property parcels in the proximity
219 of the Project was provided by the Applicant. Parcels identified as Wind
220 Energy Lease and Easement Agreement (“Controlled Land”) and Good
221 Neighbor Agreement (“GNA”) within the dataset have been considered
222 participating parcels and are indicated as such on Figure 5-1 of the Sound
223 Assessment. Parcels containing wind turbines that were not identified as
224 ‘Controlled Land’ or ‘GNA’ have been given “pending participation” status
225 and are indicated as such on the figure. Parcels not indicated on that
226 figure are considered non-participating properties.

227 • Modeling Location: Sound levels at receptors were modeled as discrete
228 points at a height of 1.5 meters above ground level to correlate with the
229 typical ear height of a standing person. Sound levels were also modeled
230 throughout a large grid of receptor points, each spaced 20 meters apart to
231 allow for the generation of sound level isolines, which are lines on a map
232 depicting sound levels.

233 • Terrain Elevation: The terrain height contour elevations for the area
234 modeled were generated from elevation information derived from the
235 National Elevation Dataset (“NED”) developed by the U.S. Geological
236 Survey.

237 • Source Sound Levels: The expected sound power levels associated with
238 the GE 2.82-127 turbine with hub heights of 89 or 114 meters were
239 obtained from a GE technical report. The expected sound power levels
240 associated with the GE 2.82-127 LNTE turbine were obtained from a GE
241 technical report. The expected sound power levels for the Project
242 substation were calculated based on information provided by the
243 Applicant. The octave-band sound power levels calculated for the GE

244 2.82/127 and GE 2.82-127 LNTE turbines represent “worst-case”
245 operational sound level emissions. The substation transformer sound
246 power levels as presented in Table 5-1 of the Sound Assessment were
247 input to the model. Further, all turbines were assumed to be operating
248 simultaneously and at the design wind speed corresponding to the
249 greatest sound level impacts. In addition, an uncertainty factor of 2.0 dBA
250 was added to the sound power level for the proposed turbine to account
251 for uncertainty in the manufacturer’s sound data.

- 252 • Ground Attenuation: Spectral ground absorption was calculated using a
253 G-factor of 0.5, which corresponds to “mixed ground” consisting of both
254 hard and porous ground cover. No additional attenuation due to tree
255 shielding, air turbulence, or wind shadow effects was considered in the
256 model.
- 257 • Meteorological Assumptions: Meteorological conditions were selected to
258 minimize atmospheric attenuation in the 500 Hz and 1 kHz octave bands
259 where the human ear is most sensitive. The model also assumed
260 favorable conditions for sound propagation, corresponding to a moderate,
261 well-developed ground-based temperature inversion, as might occur on a
262 calm, clear night or equivalently downwind propagation.

263

264 **Q. Could you summarize the results of the Sound Assessment?**

265 A. A sound model was first performed using all 86 wind turbines as GE 2.82-127
266 units with regular blades. Results showed that sound levels at two participating
267 residences would exceed the Hand County Development Agreement limits. The
268 sound modeling was changed to include LNTE turbine blades on two turbines,
269 which produce lower sound levels compared to the standard blade counterparts.
270 With use of the LNTE units on the two turbines identified in the Sound
271 Assessment, sound levels at the two participating receptors would be reduced to
272 50 dBA, which would meet the Hand County Development Agreement limit for
273 participating landowners. It is Epsilon’s understanding that Sweetland has

274 committed to using LNTE turbine models to reduce sound levels at these two
275 participating residences.

276 The sound levels range from 35 to 50 dBA at participating receptors and from 27
277 to 43 dBA at nonparticipating receptors. The highest modeled sound level at a
278 non-participating residence is 43 dBA. Accordingly, the Project will comply with
279 the Hand County Development Agreement sound limits of 50 dBA at occupied
280 residences of participating landowners and 45 dBA at occupied residences of
281 non-participating landowners.

282 **Q. How accurate is your analysis of the anticipated sound levels that will be**
283 **generated by the Project?**

284 A. The Massachusetts Clean Energy Center’s Research Study on Wind Turbine
285 Acoustics (“RSOWTA”),³ showed that the same parameters used in the Sound
286 Report resulted in model results (L_{eq1hr}) that were nearly identical (within one
287 dBA) to the monitoring results, with the exception of one outlier. Another study
288 showed that for sites with similar topography to the Project, the same modeling
289 parameters used in the Sound Assessment resulted in measured sound levels
290 one dBA less than the modeled sound levels.⁴

291
292 **Q. Are you aware of any post-construction sound studies for other wind farms**
293 **that support the accuracy and conservativeness of the pre-construction**
294 **sound modeling you conducted for the Project?**

295 A. The conservative set of modeling assumptions for this analysis has been verified
296 through post-construction sound level measurement programs at five different
297 operating wind energy facilities in the RSOWTA. According to the RSOWTA,
298 ISO 9613-2 model with mixed ground ($G=0.5$) with +2 dB added to the results
299 was most precise and accurate at modeling the hourly L_{eq} . In addition, a post-

³ RSG et al, “Massachusetts Study on Wind Turbine Acoustics,” Massachusetts Clean Energy Center and Massachusetts Department of Environmental Protection, 2016.

⁴ Cooper, J. and T. Evans, “Accuracy of noise predictions for wind farms,” Proceedings of the 5th International Conference on Wind Turbine Noise, Denver, CO, 2013.

300 construction measurement program conducted by Epsilon in the Rocky Mountain
301 region found measured sound levels met the predicted sound level under worst-
302 case operating conditions.

303

304 **V. SHADOW FLICKER AND APPLICABLE STANDARDS**

305

306 **Q. Could you please explain what shadow flicker is?**

307 A. With respect to wind turbines, shadow flicker is an intermittent change in the
308 intensity of light in a given area resulting from the operation of a wind turbine due
309 to its interaction with the sun. While indoors, an observer experiences repeated
310 changes in the brightness of the room as shadows cast from the wind turbine
311 blades briefly pass by windows as the blades rotate. In order for this to occur,
312 the wind turbine must be operating, the sun must be shining, and the window
313 must be within the shadow region of the wind turbine, otherwise there is no
314 shadow flicker.

315

316 **Q. Are you aware of any federal, state, or local shadow flicker regulations for**
317 **wind energy facilities located in South Dakota?**

318 A. Shadow flicker is not currently regulated in applicable local, state or federal law.

319

320 **Q. Please describe the shadow flicker requirement agreed to by the Applicant**
321 **pursuant to its Development Agreement with Hand County.**

322 A. Sweetland's Development Agreement with Hand County limits shadow flicker
323 resulting from Project wind turbines at currently occupied residences to 30 hours
324 per year or less, unless waived in writing by the owner of the occupied residence.

325

326 **Q. Is the 30-hour per year (absent a waiver agreement) standard agreed to by**
327 **the Applicant and Hand County a common standard in the industry and, if**
328 **so, why?**

329 A. Typically there are no regulations for shadow flicker. As more areas see wind
330 energy projects, some jurisdictions are trying to implement a guideline or limit on

331 the amount of shadow flicker from wind turbines. The most common limit is 30
332 hours per year. This number arose from a German court case which deemed 30
333 hours per year of flicker acceptable.⁵

334

335 **VI. SHADOW FLICKER ANALYSIS**

336

337 **Q. Was the Shadow Flicker Analysis provided as Appendix M to the**
338 **Application prepared by you or under your supervision and control?**

339 A. Yes.

340

341 **Q. What was the purpose of the shadow flicker modeling and analysis**
342 **discussed in the Shadow Flicker Analysis?**

343 A. The purpose of the Shadow Flicker Analysis was to estimate the potential annual
344 frequency of shadow flicker associated with the operation of the Project turbines
345 and to assess compliance with the shadow flicker requirements of the
346 Sweetland's Development Agreement with Hand County.

347

348 **Q. Were the same turbine model, turbine layout, and sensitive receptor data**
349 **used for the Shadow Flicker Analysis as were used for the acoustic**
350 **analysis?**

351 A. Yes.

352

353 **Q. Could you provide an overview of the methodology used in conducting the**
354 **shadow flicker modeling?**

355 A. The modeling was conducted using WindPRO, which is software commonly used
356 to assess potential wind turbine shadow flicker levels. Two different modeling
357 scenarios were used: a "worst-case" scenario and an "expected" scenario. In
358 addition to the proposed Project layout, turbine dimensions, and receptor data

⁵ This citation comes from the following reference on the Danish Wind Industry Association website: <http://xn--drmsttre-64ad.dk/wp-content/wind/miller/windpower%20web/en/tour/env/shadow/index.htm>.

359 provided by the Applicant, the following inputs were used for the “worst-case”
360 scenario:

- 361 • Greenhouse Mode: Each receptor was assumed to have glass on all
362 sides of the building in all directions (“greenhouse” mode), which yields
363 conservative results.
- 364 • Terrain: The terrain height contour elevations for the area modeled were
365 generated from elevation information derived from the U.S. Geological
366 Survey’s NED. A conservative “bare earth” modeling approach was used,
367 which excludes obstacles (i.e., buildings and vegetation) from the
368 analysis. When accounted for in the shadow flicker calculations, such
369 obstacles may significantly mitigate or eliminate the flicker effect
370 depending on their size, type, and location.
- 371 • Constant Sunshine and Operation: The sun was assumed to always be
372 shining during daylight hours and the wind turbine was assumed to always
373 be operating.

374
375 For the “expected” scenario, the worst-case model was further refined by
376 incorporating site-specific sunshine probabilities and yearly wind turbine
377 operational estimates:

- 378 • Sunshine Probabilities: Monthly sunshine probability values were obtained
379 from the National Oceanic and Atmospheric Administration’s National
380 Centers for Environmental Information publicly available historical dataset
381 for Huron, South Dakota.
- 382 • Operational Estimates: The number of operational hours for each of the
383 16 wind direction sectors was provided by the Applicant. These hours per
384 wind direction sector were used by WindPRO to estimate the “wind
385 direction” and “operation time” reduction factors. Based on this dataset,
386 the wind turbines would operate 90 percent of the year due to cut-in and
387 cut-out specifications of the proposed unit.

388

389 The values produced by the “expected” shadow flicker refinement are presented
390 in the Shadow Flicker Analysis.

391

392 **Q. Could you summarize the results of the shadow flicker modeling?**

393 A. Modeling was completed for the GE 2.82-127 turbine model with either an 89- or
394 114-meter hub height.⁶ Although up to 71 turbines are expected to be installed,
395 modeling was conducted at all 86 potential turbine locations of the proposed
396 configuration to ensure that any location selected has been considered in the
397 shadow flicker analysis and represented in the results of such analysis. The
398 model included a total of 41 occupied receptors.

399

400 Utilizing the conservative modeling parameters and expected shadow flicker
401 values, the shadow flicker modeling results indicate the maximum expected
402 annual flicker at a non-participating receptor is 9 hours, 16 minutes. The
403 maximum expected annual flicker at a receptor with pending participation is 14
404 hours, 49 minutes.

405

406 While the modeling indicates that four residences in Hand County could
407 experience annual shadow flicker levels above 30 hours per year, all four
408 residences are participants and it is Epsilon’s understanding that Sweetland will
409 obtain written waivers for these residences in accordance with the Hand County
410 Development Agreement for the Project. Therefore, the Project meets the
411 requirements with respect to shadow flicker in the Development Agreement.

412

413 Since the modeling treated homes as all-glass houses and assumed no
414 vegetation or other existing structures, the modeled levels are likely higher than
415 actual levels would be.

416

⁶ A total of 64 primary and 9 alternate turbines are proposed to have a hub height of 114 meters and a total of 7 primary and 6 alternate turbines are proposed to have a hub height of 89 meters.

417 **Q. Based on the results of the shadow flicker analysis set forth in the Study,**
418 **will the Project comply with the requirements of the Development**
419 **Agreement between the Applicant and Hand County?**

420 A. Yes.

421

422 **VII. CONCLUSION**

423 **Q. Does this conclude your direct testimony?**

424 A. Yes.

425

426 Dated this 6th day of March, 2019.

427



428

429

430 Robert O'Neal

431 65518300