

**MONTANA-DAKOTA UTILITIES CO.
SOUTH DAKOTA PUBLIC UTILITIES COMMISSION
SET 1 DATA REQUESTS
ISSUED NOVEMBER 3, 2020
RESPONSES DUE NOVEMBER 17, 2020
DOCKET NO. EL20-028**

- 1-3. Do the customers on Rate 95 and Rate 96 have metering to measure (and bill) energy consumed separate from energy produced, or does MDU employ a 15-minute net metering process to bill these customers? Explain.**

MDU Response:

The meter currently installed on the Rate 95 customer's service measures and bills the energy consumed separate from the energy generated and purchased by the Company.