

**MONTANA-DAKOTA UTILITIES CO.
SOUTH DAKOTA PUBLIC UTILITIES COMMISSION
SECOND DATA REQUEST ISSUED MARCH 24, 2020
DOCKET NO. EL20-009**

2-2. Refer to MDU's response to DR 1-2, part c. Provide the current summer and winter rating, in MVA, and provide the kilovolts applicable to the new line.

Response:

The voltage rating of the transmission line will remain the same before and after the project is completed at 115 kilovolts. The current summer rating is 102 MVA and the current winter rating is 123 MVA.