

**MONTANA-DAKOTA UTILITIES CO.  
SOUTH DAKOTA PUBLIC UTILITIES COMMISSION  
SET 3 DATA REQUEST ISSUED APRIL 2, 2020  
RESPONSES DUE APRIL 9, 2020  
DOCKET NO. EL20-009**

- 3-2. Refer to MDU’s response to DR 2-5. The last paragraph of part a explained how “any potential limitations on generation output capability result only if all the project wind turbines are on-line and wind speeds are at or near rated output conditions at all the wind turbines”, and the last paragraph of part c indicated that “generation would rarely be curtailed due to the MISO generation interconnection limitation”.**
- a. Provide the total amount of curtailments due to the MISO generation interconnection limitation in calendar year 2019.**
  - b. Would MDU agree to provide these generation interconnection curtailment amounts along with its transmission and economic curtailments in its future annual infrastructure rider filings?**

**Response:**

- a. The amount of 2019 annual curtailments of Thunder Spirit Wind due to MISO generation interconnection limits is estimated at 490 MWh.
- b. Yes, Montana-Dakota would agree to add an additional reporting criterion to identify generation interconnection curtailments.