


DESIGN DATA
 CONDUCTOR: 795 ACSR 3500# DTHL
 SHIELD WIRE: 3/8" 7-STRAND EHSS 1500# DTHL
 BASIC STRUCTURE: TH-5BD-230
 RULING SPAN: SLACK SPANS
 POLE GROUND: TM-9
 POLE CLASS: LAMINATED WOOD
 TG-5A ON ALL DOWN GUYS
 POLE LINE FOOTAGE: 502' OR 0.095 MILES
 YEAR OF CONSTRUCTION OR AS BUILT: 2024/2025



DATE	REVISION	DATE	REVISION	DATE	REVISION
03/20/2024	ISSUE FOR CONSTRUCTION				

PRINT DATE 03/20/2024 W.D. NO. 2023187 DESIGNED BY UEI - EEE PLOT SCALE 1=1

230KV LINE WAPA NORTH BEND TO PRATT TIE			
PROFILE	SECTION	TAP NO.	SHEET
PR	09	20	1