

- ☐ Not-Public Document – Not For Public Disclosure
☐ Public Document – Not-Public Data Has Been Excised
☒ Public Document

Xcel Energy Data Request No. 2-1
Docket No.: EL25-020
Response To: South Dakota Public Utilities Commission
Requestor: Eric Paulson
Date Received: October 1, 2025

Question:

Page 9 of the revised Petition states, “a minimum of one control event per cooling season is required by MISO.” The response to DR1-14 states there is no MISO minimum. Explain which is correct.

Response:

MISO requires at least one event if registered as a Load Modifying Resource (LMR). Saver’s Switch is registered as a Load Modifying Resource with MISO, so we do have a requirement of at least one event. We apologize for the confusion on this.

Preparer: Patrik Ronnings
Title: Sr. Product Portfolio Manager
Department: Demand Management
Telephone: (612) 330-5787
Date: October 15, 2025