

Not-Public Document – Not For Public Disclosure
 Public Document – Not-Public Data Has Been Excised
 Public Document

Xcel Energy Data Request No. 2-2
Docket No.: EL25-031
Response To: Sioux Valley Energy, East River Electric, Basin Electric
Requestor: Mike Nadolski, Daniel Brown, Meredith Moore
Date Received: December 19, 2025

Question:

Please indicate whether it would be necessary to construct on-site electrical distribution system to enable Knife River to receive service from Xcel Energy.

Response:

No, Xcel energy would serve them with a primary voltage service at 34.5kV. Any distribution facilities beyond that point would be owned and operated by the customer.

Preparer: Brad Sylliaasen
Title: Senior Engineer
Department: Area Engineering North
Telephone: (701) 241-8626
Date: January 6, 2026