

- Not-Public Document – Not For Public Disclosure
- Public Document – Not-Public Data Has Been Excised
- Public Document

Xcel Energy Data Request No. 3-3
Docket No.: EL25-031
Response To: Sioux Valley Energy, East River Electric, Basin Electric
Requestor: Mike Nadolski, Daniel Brown, Meredith Moore
Date Received: December 19, 2025

Question:

Please confirm whether the Plant will be served at primary voltage or transmission voltage.

Response:

We confirm that the Plant will be served at primary voltage of 34.5kv.

Preparer: Brad Sylliaasen
Title: Senior Engineer
Department: Area Engineering North
Telephone: (701) 241-8626
Date: March 20, 2026