

**Northern States Power Company, doing business as Xcel Energy
Information Request**

Docket No.: EL25-032
South Dakota Knife River
Requestor: Xcel Energy
Requested From: Sioux Valley Energy
Analyst: Steve Kolbeck
Date of Request: March 10, 2026 Data Request No. 1-8
Response Due: March 24, 2026

Question:

Please identify what equipment and/or infrastructure Knife River will be required to install at Knife River's cost to complete the on-site electrical distribution system, including the technical details and any engineering documentation of the capability of these new facilities.

Response:

Knife River would be responsible for installing all necessary secondary service wire from the distribution transformers to the desired service panels or equipment. Sioux Valley Energy would provide service at Knife River's desired locations at service voltage of 277/480V or 4,160V as identified in the table provided earlier in this request.

Preparer: Ted Smith
Title: V.P. Engineering/Operations
Department: Engineering/Operations
Telephone: (605)534-3535
Date: March 24, 2026