

Docket Number: NG24-002
Subject Matter: First Data Request
Request to: Montana-Dakota Utilities Co. (MDU or Company)
Request from: South Dakota Public Utilities Commission Staff
Date of Request: February 1, 2024
Responses Due: February 8, 2024

1-5. Provide an explanation of the one Custom Efficiency program in 2023.

Response:

The Custom Efficiency rebate that was processed in 2023 was for a church that replaced an old boiler (installed in 1968) with 2 new high efficiency boilers. Two high efficiency (95% AFUE) boilers were installed, but they are running in a lead-lag configuration, therefore the rebate and savings calculation were offered for only one boiler.