Questions for Controller Interview Associated with CRM Inspection

192.631(a)(2) The procedures required by this section must be integrated, as appropriate, with operating and emergency procedures required by §§192.605 and 192.615. An operator must develop the procedures no later than August 1, 2011, and must implement the procedures according to the following schedule. The procedures required by paragraphs (b), (c)(5), (d)(2) and (d)(3), (f) and (g) must be implemented no later than October 1, 2011. The procedures required by paragraphs (c)(1)-(4), (d)(1), (d)(4), and (e) must be implemented no later than August 1, 2012. The training procedures required by paragraph (h) must be implemented no later than August 1, 2012, except that any training required by another paragraph of this section must be implemented no later than the deadline for that paragraph.

Inspection	Question	Pro	cedures	Imp	lementation	Inspector Notes
A1-4:	Are procedures readily available to controllers in the control room?		SAT		SAT	
	 Procedures in the control room must be the most current approved version. 		UNSAT		UNSAT	
	 Procedures should be conveniently available to on-shift controllers in paper format and/or electronically. 				Observed Records	
	 Procedures should be accessible from each controller's console/desk. 				Interview	
Where	e are the CRM procedures kept?					

192.631(b) Roles and responsibilities. Each operator must define the roles and responsibilities of a controller during normal, abnormal, and emergency operating conditions. To provide for a controller's prompt and appropriate response to operating conditions, an operator must define each of the following:

(1) A controller's authority and responsibility to make decisions and take actions during normal operations;

Inspection	Question	Pro	cedures	Imp	lementation	Inspector Notes
B1-1:	The operator should have clear procedures been established to describe		SAT		SAT	
	each controller's physical domain of responsibility for pipelines and other facility assets.		UNSAT		UNSAT	_
	• If the control room has more than one controller on shift, roles and				Observed	-
	domain of responsibility for each controller must be clearly				Records	
	established."Physical domain of responsibility" refers to both the physical				Interview	
	pipeline assets being monitored and controlled, and					
	SCADA/communications assets (such as desks, consoles, phones,					
	radios, etc.) being used in support of monitor and control duties. • FAQ B.01. Procedure includes formal definition and					
	documentation of controller roles and responsibilities.					
What i	is your role and what are your responsibilities?					
B1-2:	Are there provisions in place to assure that only qualified individuals		SAT		SAT	
	may assume control at any console/desk?Provisions could include measures such as SCADA login passwords,		UNSAT		UNSAT	
	and/or controlled access to the control room. Such measures				T	_
	should address periods when the control room is unattended, if				Observed	
	applicable (also, see B4-1e).				Records	_
	 Provisions must be in place to assure that controllers are qualified persons as detailed in covered tasks that are required by Part 195, 					
	Subpart G—Qualification of Pipeline Personnel and Part 192,					
	Subpart N—Qualification of Pipeline Personnel.					
What	OQ training have you had?					
	 FAQ B.03. A control room supervisor may direct or advise a controller on specific actions to take to complete a safety-related 				Interview	
	task, if and only if, the supervisor is a qualified controller on that					
	console/desk. If the supervisor is not a qualified controller, then					
	the supervisor may assign activities to the controller, but not the					
	precise actions to take to implement those activities.					

When do you seek assistance from your supervisor? Overpressure Rupture Unusual alarms Nuisance alarms How does your supervisor direct you to handle these situations?			
 B1-5: Do the defined roles and responsibilities require controllers to stay at the console to verify all SCADA commands that have been initiated are fulfilled, and that commands given via verbal communications are acknowledged before leaving the console for any reason? Some SCADA commands can be complex or take an extended period of time to execute in the field. Because control actions can be critical to maintain safety, controllers should remain attentive during this time, and not leave the console prematurely. Shift change operations should not conflict or interfere with controller vigilance during the fulfillment of command actions or critical communications with field personnel. When are you allowed to leave your console? Lunch Bathroom breaks To get beverages What do you do if there is currently a situation that needs attention?	SAT	SAT UNSAT Observed Records Interview	

192.631(b)(2) A controller's role when an abnormal operating condition is detected, even if the controller is not the first to detect the condition, including the controller's responsibility to take specific actions and to communicate with others;

Inspectio	n Question	Proce	dures	Imp	lementation	Inspector Notes
B2-1:	Has a procedure been established to define the controllers' authority		SAT		SAT	
	and responsibilities when an abnormal operating condition is detected?		UNSAT		UNSAT	
	 Many controllers have the same authority and set of responsibilities during normal, abnormal and emergency situations, 					
	including the expectation to directly take action when abnormal				Observed	
	conditions arise.				Records	
	 Some controllers may need to seek guidance or get a supervisor's approval before taking action. This must be explained in the 				Interview	_
	 operator's procedures. If controllers must seek approval from supervisors or other authorized personnel, procedures must require that those other persons always be immediately available, and controllers should have the means to immediately communicate with those individuals. Procedures should address a controller's responsibility when the controller is not the first to detect the condition, including the controller's responsibility to take specific actions and to communicate with others. 					
detect	is the procedure when an abnormal operating condition is					
B2-2:			CAT.		I 64.7	
BZ-Z:	Are controllers aware of the current MAOPs/MOPs of all pipeline segments for which they are responsible, and have they been assigned		SAT		SAT	
	the responsibility to maintain those pipelines at or below the		UNSAT		UNSAT	-
	MAOP/MOP?				1	
					Observed	

 Some operators may choose to set actual operating pressure limits lower than MAOP/MOP. In these cases, controllers should at least know the limits in lieu of full MAOP/MOP. Controllers' written procedures should include a stipulation to protect pipeline segments from exceeding authorized pressures. A thorough listing of MAOPs/MOPs (or prescribed lower limits) should be in easy reach to the controllers, either in paper format or accessible on computer. It is also especially important that procedures specify the importance of protecting pipeline segments from exceeding any imposed pressure reductions which would supersede normal maximum limits. 	Records Interview	
Where do you find the MAOPs/MOPs of the system? What do you do if you see a MAOP/MOP that is unusual? Too high Too low		

192.631(b)(3) A controller's role during an emergency, even if the controller is not the first to detect the emergency, including the controller's responsibility to take specific actions and to communicate with others; and

Inspection	Question	Prod	cedures	Impl	ementation	Inspector Notes
B3-1:	Has the operator procedurally defined the controllers' authority and		SAT		SAT	
	responsibility to make decisions, take actions, and communicate with		UNSAT		UNSAT	1
	others upon being notified of, or upon detection of, and during, an		1			-
	emergency or if a leak or rupture is suspected?			-	·	
	Many controllers have the same authority and set of				Observed	
	responsibilities during normal, abnormal and emergency situations,				Records	
	including the expectation to directly take action when abnormal				Interview	1
	conditions arise without the need to consult with supervision/					-
	management or get management approval.					
	Other controllers may be required to seek guidance or get a					
	supervisor's approval before taking action. This must be explained					
	in the operator's procedures. If controllers must seek approval					
	from supervisors or other authorized personnel, procedures must require that those other persons always be immediately available,					
	and controllers should have the means to immediately					
	communicate with those individuals.					
	Procedures should address a controller's responsibility when the					
	controller is not the first to detect the emergency.					
	 Procedures should address the controller's responsibility to: 					
	directly call 911 or local phone number of appropriate local					
	emergency officials to report emergencies to first responder					
	agencies/authorities, or prompt others to make such calls.					
\						
	authority do you have to make decisions, take action, and					
comm	unicate with others?					
When	do you need to clear actions with your supervisor?					
How d	o you contact your supervisor?					
	•					
When	do you call 911?					
		l		1		1

B3-2:	Do the operator's procedures specifically address the controller's	SAT	SAT	
	responsibilities in the event the control room must be evacuated?	UNSAT	UNSAT	ļ
What	 Although an unforeseen need to evacuate the control room or the entire building should be a rare event, operators must plan for such an occasion. In such an event, there may be little time to act, so an operator's plan must be able to be executed immediately and quickly. do you do if the control room needs to be evacuated? 		Observed Records Interview	
B3-3:	Do the operator's procedures specifically address the controller's	SAT	SAT	
	responsibilities in the event of a SCADA system or data communications	UNSAT	UNSAT	
	system failure impacting large sections of the controller's domain of			1
	responsibility?		Observed	
			Records	
	Procedures must address controllers' initial actions after a major SCADA system or communications system failure.		Interview	
	 SCADA system or communications system failure. Plans should include contacting supervision, but should also 			
	include what first actions the controllers should initiate in the first			
	few minutes of the event.			
What	do you do if the SCADA system fails?			
What	do you do if a large set of data communications fail?			

192.631(b)(4) A method of recording controller shift-changes and any hand-over of responsibility between controllers. *NOTE: SHIFT CHANGE PROCESS IS ADDRESSED IN B4. THE CONTENT OF SHIFT CHANGE IS ADDRESSED IN C5.*

Inspection Question	Procedures	Implementation	on Inspector Notes
B4-2: Do the procedures require that records document the hand-over of responsibility, document the time the actual hand-over of responsib	SAT	SAT	
occurs, and the key information and topics that were communicated	' I I I I I I I I I I I I I I I I I I I	T UNSA	Т
during the hand-over?			
		Obser	ved
 An operator's records must annotate what topics were covered during shift change. In the event certain operational aspects are 		Record	ds
not important to the incoming controller, the record must still		Intervi	iew
annotate "no change" rather than not covering the topic.			
The specific time and date of shift change must be included in t	he		
records, not just "Tuesday night" or "morning shift" • Just recording the time/date of shift change, without the			
annotation of topics covered, is not adequate.			
SCADA server time should be synchronized with other sources of the synchronized with other sources. - The synchronized with the synchroniz	of		
timekeeping used for operational records.			
Because of varying operational needs, a controller arriving late	or		
an extended discussion of unusual events, shift change will not actually occur at exactly the same time every day. Records that			
annotate a shift change at exactly the same time every day sho			
be questioned during an inspection.			
Shift hand-over records may refer to other information or records.	ds,		
as appropriate.			
• See C5-1 for specifics.			
Explain the process for a shift change.When is it done?			
What forms are filled out?			
 What information is documented on the form? 			
 What other information is communicated? 			
B4-4: When a controller is unable to continue or assume responsibility for	any SAT	SAT	
reason, does the shift hand-over procedure include alternative shift	UNSA	T UNSA	Т
hand-over actions that specifically address this situation?		'	
 If the incoming controller is late arriving, procedures should 		Obser	ved

 address the responsibilities of the current controller and/or management to address the issue. If controllers are permitted to find their own replacement among available controller staff, control room supervisors/managers should still be accountable for Hours of Service (HOS) requirements and limitations. Operator's procedures should provide a mechanism for an on-shift controller (or a controller due to come on shift) to alert 	-	Records Interview	
management that he/she is unable or unfit for duty, because of illness, fatigue, car trouble or other issues. What happens if you get sick during your shift?			
What happens if the controller on the next shift can't get to work?			
B4-5: Has the operator established adequate procedures for occasions when the console is left temporarily unattended for any reason?	SAT UNSAT	SAT UNSAT	
 FAQ B.04. Depending on an operator's specific system operations, a particular control room may not have to be staffed by controllers, full time. The operator's procedures should include an explanation of when and how the pipeline is operated when the control room is unattended. Such procedures should include special provisions for shift change realizing that face-to-face communications between the departing and arriving controllers may not occur. What is the procedure when you leave the console for short breaks 		Observed Records Interview	
such as getting beverages or food, using the restroom, etc.? B4-6: Does the operator maintain adequate console coverage during shift	SAT	SAT	
hand-over?	UNSAT	UNSAT	·
 Assure coverage if occasionally the controller needs to leave the console/desk area (beyond visual and hearing range of alarms). If the controller is allowed to leave the console/desk area, procedures must assure adequate responsiveness. If the shift changes to a different physical location, the actual time of the hand-over in responsibility must be known to both the outgoing and incoming controllers. The time allocated to complete shift hand-over should be sufficient to adequately communicate needed information exchange. How do you ensure that alarms and other conditions are recognized during a shift change? 		Observed Records Interview	

192.631(c) Provide adequate information. Each operator must provide its controllers with the information, tools, processes and procedures necessary for the controllers to carry out the roles and responsibilities the operator has defined by performing each of the following:

(5) Establish and implement procedures for when a different controller assumes responsibility, including the content of information to be exchanged.

NOTE: SHIFT CHANGE PROCESS IS ADDRESSED IN B4. THE CONTENT OF SHIFT CHANGE IS ADDRESSED IN C5.

Inspection	Question	Prod	cedures	Imp	ementation	Inspector Notes
C5-1:	Has the operator established and implemented a procedure to		SAT		SAT	
	orchestrate the hand-over of responsibility from one controller to another?		UNSAT		UNSAT	
	different.					
	All items in this listing are specified in section 5 of API RP 1168, and				Observed	
	are mandatory for HL operators. Gas operators should also				Records	
	address these items, but may be able to justify not including some				Interview	

of these items in their checklist based on the specific nature of	
their gas pipeline operations.	
 Assure operational continuity 	
 Address system control accountability during hand-over 	
 Generate a record of accountability transfer 	
 Assure phone monitoring during transfer 	
 Manage distractions that could adversely impact transfer 	
 Require a meeting to be conducted to brief incoming 	
controllers on the status of current operations.	
 Procedures to require a console specific checklist of 	
information to be exchanged. (See C5-1c for content of	
checklist.)	
 FAQ C.10. Shift hand-over procedure must be performed even if 	
no unusual events occurred during the entire previous shift.	
 FAQ C.11. Shift hand-over procedure must be performed even if 	
an operator has a controller on regular day shifts only (e.g., 8-5 M-	
F) and uses callouts to handle off-shift needs, since the controller	
may unexpectedly have to be replaced as the result of illness or	
other circumstance that prevents the controller from returning to	
duty the next day as planned.	
 Even if the same individual plans to return the next morning, the 	
shift hand-over process will help ensure no critical information has	
been forgotten.	
(See questions in B4)	

192.631(c)(1) Implement sections 1, 4, 8, 9, 11.1, and 11.3 of API RP 1165 (incorporated by reference, see §192.7) whenever a SCADA system is added, expanded or replaced, unless the operator demonstrates that certain provisions of sections 1, 4, 8, 9, 11.1, and 11.3 of API RP 1165 are not practical for the SCADA system used;

C1-3:	Has the operator implemented section 4 of API RP 1165 regarding	SAT	SAT
C1-3.	human factors engineering?	UNSAT	UNSAT
	numan ractors engineering:	N/A	N/A
	4.1 Short term memory	IN/A	IN/A
			Observat
	_	_	Observed
	• 4.3 Eye scan pattern	_	Records
	 4.4 Consistency General consistency for shapes and symbols 	_	Interview
	 Layout consistent among displays Information density consistent among displays 		
	 Flow paths depicted consistently among displays 		
	o If the operator has grouped more than one console/desk into		
	a team, consistency of display formats, layout, shapes and		
	colors across all team consoles/desks.		
	 Consistency between control room display colors for off, 		
	closed, open, on and locked out with color choices on related		
	field equipment controls		
	• 4.5 Coding		
	 Coding is the assignment of meaning to an arbitrary visual 		
	cue. Examples of information coding include color-coding of		
	normal/abnormal conditions or shape-coding of device		
	symbols such as pumps, valves, and meters.		
What ch	allenges do you have during a shift?		
	 Too many things happening at once? 		
	Unable to understand alarms?		
	 Inconsistent alarm indication? (such as color for "open" isn't 		
	always the same)		
	Confusing layout of system?		
	 Difficult to remember everything that needs to be done? 		
	to the family that it is a to to do not	<u> </u>	

192.631(c)(2) Conduct a point-to-point verification between SCADA displays and related field equipment when field equipment is added or moved and when other changes that affect pipeline safety are made to field equipment or SCADA displays;

Inspection	Question	Procedures		Imp	lementation	Inspector Notes
C2-1:	Has the operator adequately defined safety-related points?		SAT		SAT	
			UNSAT		UNSAT	7
	 Examples of safety-related points are provided in FAQ C.01. 					7
	 Procedures should be established to define which points are 				Observed	7
	declared as safety-related				Records	
	 Operator should have a list (or database) of points that indicates whether or not each point is safety-related. 				Interview	
	 Procedures should also address criteria for treating points as safety-related. 					
	 Points associated with all safety-related alarms and control points must be included. 					
	 Station inlet and discharge pressures should fall into the safety- related category. 					
	 Pressure Regulator inlet and outlet pressures should fall into the safety-related category. 					
	 Soft points (points created in SCADA software) should be considered when determining a list of safety-related points. 					
How d	o you know if a point is safety-related?					
How a	re the criteria for these points identified?					

192.631(d) Fatigue mitigation. Each operator must implement the following methods to reduce the risk associated with controller fatigue that could inhibit a controller's ability to carry out the roles and responsibilities the operator has defined:

Inspection	Question	Prod	cedures	Imp	ementation	Inspector Notes
D0-2:	Does the operator's plan adequately address how the program reduces		SAT		SAT	
	the risk associated with controller fatigue?		UNSAT		UNSAT	
	 An operator's fatigue mitigation plan and document the scientific 				Observed	
	basis for provisions of the plan. (74 FR 63321)				Records	
	 Operators should have a documented and accessible policy for 				Interview	
	dealing with controllers who are self-identified and/or identified by					
	supervisors as being too fatigued to safely control the pipeline.					
	 The operator's plan should address identified issues in Advisory 					
	Bulletin (ADB–05–06) "Countermeasures to Prevent Human					
	Fatigue in the Control Room" dated August 11, 2005 (70 FR 46917).					
What o	do you do if you are too tired to adequately perform your					
duties	?					

192.631(d)(4) Establish a maximum limit on controller HOS, which may provide for an emergency deviation from the maximum limit if necessary for the safe operation of a pipeline facility.

D4-12:	Doe	es the operator implement specific fatigue countermeasures during:	SAT	SAT
	a)	Any and all shift duty hours worked after the first 8 hours?	UNSAT	UNSAT
	b)	Any and all hours worked between 2:00 a.m. and 6:00 a.m.?		
	c)	Any and all night shifts immediately following three successive		Observed
		nights?		Records
	d)	Any and all day or night shifts following four successive night shifts		Interview
		unless three nocturnal sleep cycles have been completed?		
	•	FAQs D.05 and D.07.		
D · ·		and the duly all and the set are such along 2		
Does y	our	work schedule allow you to get enough sleep?		

192.631(d)(2) Educate controllers and supervisors in fatigue mitigation strategies and how off-duty activities contribute to fatigue;

Inspection	Question	Pro	cedures	Imp	lementation	Inspector Notes
D2-1:	Is fatigue education required to all controllers and control room		SAT		SAT	
	supervisors?		UNSAT		UNSAT	 -
	 Records must demonstrate that all controllers and supervisors have received the required fatigue training. The content of training material for new controllers may include additional topics not necessary for experienced controllers Education on fatigue mitigation strategies may be incorporated into OQ requirements or may be implemented as a separate training program. 				Observed Records Interview	
What	training have you had on fatigue?					
What	things can you do to help alleviate fatigue?					
D2-2:	Is refresher fatigue education provided at regular intervals?		SAT		SAT	
			UNSAT		UNSAT	
	 Refresher training should be provided on an annual basis (typically 					
	once per calendar year, not to exceed 15 months).				Observed	
How o	ften do you have training on fatigue?				Records	
					Interview	

192.631(d)(3) Train controllers and supervisors to recognize the effects of fatigue; and

Inspection	Question	tion Procedures		Impl	ementation	Inspector Notes
D3-4:	Is the content of fatigue training adequate for training controllers and		SAT		SAT	
	supervisors to recognize the effects of fatigue?		UNSAT		UNSAT	
	• FAQ D-04.				Observed	
	 Circadian rhythm effects on work performance 				Records	
	 Time-on-task-fatigue effects on work performance 				Interview	
	 Effects of prescription and over-the-counter drugs on sleep and work performance 					
	 Uses of prescription sleep aids and alertness aids 					
	 Actions to be taken when controllers are self-identified or identified by colleagues or supervisors as being too fatigued to safely control the pipeline 					
What	is covered in your fatigue training?					

192.631(e) Alarm management. Each operator using a SCADA system must have a written alarm management plan to provide for effective controller response to alarms. An operator's plan must include provisions to:

Inspection Question		Procedures Impleme		lementation	Inspector Notes	
E0-1:	Is the operator's alarm management plan a formal process that	SA	Α Τ		SAT	
	specifically identifies critical topical areas included in their program?	ıu	NSAT		UNSAT	1
	Operator may use other terms rather than "alarm", such as "alert."				Observed	_
	 Refer to FAQ E.04 for the definition for safety-related alarm and 				Records	1
	FAQ A.16 for definition of safety-related.					-
	 Operator should have a list of alarm setpoints for each safety- related point. 				Interview	
	 Alarm management should be included in the management of change process. 					

•	International Society of Automation (ISA) 18 may be used for	
	guidance.	
•	Typical critical topical areas are:	
	 Alarm philosophy 	
	 Alarm identification 	
	 Alarm rationalization, not necessarily alarm reduction. 	
	 Detailed design 	
	 Implementation 	
	 Operation 	
	 Maintenance 	
	 Monitoring 	
	 Assessment (including a method to confirm effective 	
	controller response)	
	 Internal audits 	
Where car	you find the alarm set point for each safety related	
noint?	you mid the didinisee point for each survey related	

192.631(e)(1) Review SCADA safety-related alarm operations using a process that ensures alarms are accurate and support safe pipeline operations;

Inspection Question		Procedures	Implementation	Inspector Notes
E1-1: Does the operator have a process to identify and c	orrect inaccurate or	SAT	SAT	
malfunctioning alarms?		UNSAT	UNSAT	
 Operator must have a means to identify inaccommunity 	urate alarms.		Observed	
 Operator should have formal process for cont 	rollers to report		Records	
alarm problems and malfunctions.			Interview	
 Process should include requirements for pron 	npt correction of			
alarm malfunctions.				
 Alarm reports and alarm inhibited reports are 				
not be a complete listing of alarms that fail to	function as or when			
required.				
How do you identify inaccurate alarms?				
What is the process for reporting alarms that are	malfunctioning or			
causing problems?				
E1-2: Does the review of safety-related alarms account f	or different alarm	SAT	SAT	
designs and all alarm types/priorities?		UNSAT	UNSAT	
Operator must ensure soft (software calculate)	ed or "synthetic")		Observed	
alarms are accurate and can be identified by t			Records	
Adequate procedures must be in place to exp			Interview	
administrative controls for the disabling of sa			interview	
FAQ E.12. Alarm priorities used by the opera	tor should			
differentiate alarm importance. Too many ala	arm priorities could			
lead to confusion and inconsistent response t	o alarms.			
 In evaluating whether alarms support safe op 	erations, operators			
should account for type of alarm used, e.g., vi	sual alarms are more			
likely to go unnoticed than alarms that are bo	th audible and visual.			
Make a notation of the types of alarm used.				
 If there are differences in alarm design based 	on alarm priority, the			
operator should be able to explain the rational	ale for the chosen			
approach and its effect on ensuring controller	rs recognize and			
handle alarms efficiently.				
Do you know what alarms are calculated rather the	nan actual data?			
E1-4: Does the review of safety-related alarms include s	pecific procedures	SAT	SAT	
and practices for managing stale or unreliable data	1?	UNSAT	UNSAT	
]
 Adequate procedures should be in place for c 			Observed	
stale data. Reviews of safety related alarms s	hould account for the		Records	

and the Heat are a second state of the	Last a modern co	
way controllers manage stale data.	Interview	
 The operator should have a procedure to insure errant or stale 		
data sources are promptly remediated, in order to minimize		
adverse impact on safety related alarm capabilities.		
Operators should account for errant or stale data when reviewing		
safety related alarms. The cause of errant or stale data should also		
be accounted for, including but not limited to, communication		
system errors, SCADA system errors, operational practices to take		
points off-scan or inhibit alarms, and other applicable causes.		
, , , , , , , , , , , , , , , , , , , ,		
Operators should be able to determine stale data for all points that		
impact safety or safety-related points.		
 Operators should be able to distinguish between stale or forced 		
data in the RTU versus the SCADA system.		
How do you recognize stale data?		
How can you verify that the data is stale?		
What is the process for reporting errant or stale data?		
Tride to the process for reporting entant of state data.		

192.631(e)(2) Identify at least once each calendar month points affecting safety that have been taken off scan in the SCADA host, have had alarms inhibited, generated false alarms, or that have had forced or manual values for periods of time exceeding that required for associated maintenance or operating activities;

Inspection	Question	Procedures		Procedures Implementation		Inspector Notes
E2-1:	Does the procedure require the monthly identification, recording,		SAT		SAT	
	review, and analysis of points that have been taken off scan, have had		UNSAT		UNSAT	
	alarms inhibited, generated false alarms, or that have had forced or					
	manual values for periods of time exceeding that required for				Observed	
	associated maintenance or operating activities?				Records	1
					Interview	
	 Documentation must include dates showing: 					
	 When points were taken off scan/inhibited/forced/manual, 					
	 When points were restored, and 					
	 The duration of outage. 					
	FAQ E.02 for false alarms.					
	 FAQ E.03 for alarms generated during testing. 					
	 FAQ E.04 for safety related alarms and FAQ A.16 for definition of 					
	safety-related.					
	FAQ E.05 for alarm setpoint values.					
	 Procedures must require the review of analysis of such points. 					
	Results of the review and analysis should be documented.					
	 Off scan points should be promptly restored to service. 					
How d	o you log information on data points that are:					
	Taken off scan					
	Have had alarms inhibited					
	False alarms					
	Forced values					
_	Forced values					
What i	information is recorded in the log?					
E2-2:	Does the operator's alarm management plan include a procedure for		SAT		SAT	
	promptly correcting identified problems and for returning these points		UNSAT		UNSAT	1
	to service?		•			1
					Observed	1
	Operator should analyze problems to identify recurring or chronic				Records	1
	issues that are not getting corrected promptly enough.				Interview	
	• FAQ E.14.				c. view	1
Are pr	oblems corrected promptly?					
J p.	, , , , , , , , , , , , , , , , , , ,			<u> </u>		

192.631(e)(5) Monitor the content and volume of general activity being directed to and required of each controller at least once each calendar year, but at intervals not exceeding 15 months, that will assure controllers have sufficient time to analyze and react to incoming alarms; and

ES-1: Does the operator's program have a means of identifying and measuring the work load (content and volume of general activity) being directed to an individual controller? • Process must have a sufficient degree of formality and documentation. Operators might implement this requirement by means of a job task analysis (JTA), formal workload study or other means. • "General activity" means any activity that is required of the controller. This includes, but is not limited to, pipeline operations, handling SCADA slarms, conducting shift change, greeting and responding to visitors, administrative tasks, impromptu requests, telephone calls, face, or other activities such as monitoring weather and news reports, training (including CSI), checking, security and video sourcellance systems, using the internet, and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/right shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the nest workload review. • If the operator has added any significant assets or SCADA points since the previous review, he operator must account for this change in the nest workload review. • If the operator has impressed other activities, not related to pipeline operation, not the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received	Inspection	Question	Procedures		rocedures Implementation		Inspector Notes
directed to an individual controller? Process must have a sufficient degree of formality and documentation. Operators might implement this requirement by means of a job task analysis (ITA), formal workload study or other means. "General activity" means any activity that is required of the controller. This includes, but is not limited to, pipeline operations, handling SCADA alarms, conducting shift change, greeting and responding to visitros, administrative tasks, impromptur equests, telephone calls, faxes, or other activities such as monitoring weather and news reports, training fincluding CBTJ, hedsing security and video surveillance systems, using the internet, and interacting with toolleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. Pror continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. If the operator has impressed other activities, not related to pipeline operation, not the controller position, the operator should ascertain these activities do not undermine pipeline safety. Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other rasks are you assigned in addition to monitoring the system? Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. Criteria for acceptable controller performance in response to alarms. Operators should place particular importance on proper and timely response to leak detection slams. TAQ A.15 clarifies that leak detection systems, batch tr	E5-1:			SAT		SAT	
directed to an individual controller? Process must have a sufficient degree of formality and documentation. Operators might implement this requirement by means of a job task analysis (JTA), formal workload study or other means. "General activity" means any activity that is required of the controller. This includes, but is not limited to, pipeline operations, handling SCADA alarms, conducting shift change, greeting and responding to visitors, administrative tasks, impromptu requests, telephone calls, faxes, or other activities such as monitoring weather and news reports, training including CST, checking security and video surveillance systems, using the Internet, and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console; including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/right shifts. If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. If the operator has impressed other activities, not related to pipeline operation, not the controller position, the operator should ascertain these activities of not undermine pipeline safety. Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are youl assigned in addition to monitoring the system? Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. Circlera for acceptable controller performance in response to alarms. Operators should place particular importance on proper and timely response to leak detection salms. FAQ A.15 clarifies that leak detection systems, batch trac				UNSAT		UNSAT	
documentation. Operators might implement this requirement by means of a job task analysis (ITA), formal workload study or other means. • "General activity" means any activity that is required of the controller. This includes, but is not limited to, pipeline operations, handling SCADA alarms, conducting shift change, greeting and responding to visitors, administrative tasks, impromptu requests, telephone calls, faces, or other activities such as monitoring weather and news reports, training (including CBT), checking security and video surveillance systems, using the internet; and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which sate least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, not to the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to lalarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that teak detection systems, batch tracking systems and other special applications can be considered as an extensi		directed to an individual controller?		ı			
documentation. Operators might implement this requirement by means of a job task analysis (ITA), formal workload study or other means. • "General activity" means any activity that is required of the controller. This includes, but is not limited to, pipeline operations, handling SCADA alarms, conducting shift change, greeting and responding to visitors, administrative tasks, impromptu requests, telephone calls, faces, or other activities such as monitoring weather and news reports, training (including CBT), checking security and video surveillance systems, using the internet; and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which sate least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, not to the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to lalarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that teak detection systems, batch tracking systems and other special applications can be considered as an extensi						Observed	
## Interview Interview Interview							
* "General activity" means any activity that is required of the controller. This includes, but is not limited to, pipeline operations, handling SCADA alarms, conducting shift change, greeting and responding to visitors, administrative tasks, impromptur requests, telephone calls, faxes, or other activities such as monitoring weather and news reports, training (Including CBT), checking security and video surveillance systems, using the internet, and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which has the leads. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/ingith shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, not to the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • It Conyl See Advisory Bulletin ADB—10—01, "Leak Detection on Hazardo							
"General activity" means any activity that is required of the controller. This includes, but is not limited to, pipeline operations, handling SCADA alarms, conducting shift change, greeting and responding to visitors, administrative tasks, impromptur equests, telephone calls, faxes, or other activities such as monitoring weather and news reports, training (including CRI), checking security and video surveillance systems, using the internet, and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control romos with multiple consoles) which console has the most activity and which has the least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/ingit shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? • Controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shifty received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 charifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. •		means of a job task analysis (JTA), formal workload study or other				Interview	
controller. This includes, but is not limited to, pipeline operations, handling SCADA alarms, conducting shift change, greeting and responding to visitors, administrative tasks, impromptu requests, telephone calls, faxes, or other activities such as monitoring weather and news reports, training (including (ET), checking security and video surveillance systems, using the internet, and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should sacertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB-10-01, "teak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators m		means.					
controller. This includes, but is not limited to, pipeline operations, handling SCADA alarms, conducting shift change, greeting and responding to visitors, administrative tasks, impromptu requests, telephone calls, faxes, or other activities such as monitoring weather and news reports, training (including (ET), checking security and video surveillance systems, using the internet, and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should sacertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB-10-01, "teak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators m							
handling SCADA alarms, conducting shift change, greeting and responding to visitors, administrative tasks, impromptu requests, telephone calls, faxes, or other activities such as monitoring weather and news reports, training (including CBT), checking security and video surveillance systems, using the internet, and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [Ht Only] See Advisory Bulletin ADB-10-11, "leak Detection on Hazardous Liquid Pipelines" dated January 25, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standard		· · · · · · · · · · · · · · · · · · ·					
responding to visitors, administrative tasks, impromptu requests, telephone calls, faxes, or other activities such as monitoring weather and news reports, training (including CBT), checking security and video surveillance systems, using the internet, and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/ingith shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB—10—01, "(teak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as international Society of							
telephone calls, faxes, or other activities such as monitoring weather and news reports, training (including CBT), checking security and video surveillance systems, using the internet, and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? • Controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB—10—01, "Cask Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as international Soci							
weather and news reports, training (including CBT), checking security and video surveillance systems, using the internet, and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, not the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ.A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to RM requirements. • [HL Only] See Advisory Bulletin ADB—10—01, "leak Detection on Hazardous Equipid Pipeliness" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as international Soc							
security and video surveillance systems, using the internet, and interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HI. Only] See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" (Acted January 26, 2010 (75 FR 4134)). • Operators may identify relevant alarm managem							
interacting with colleagues, supervisors, and managers. Operator should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" (adted January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (15.4) 18. Analysis of Increased activity as a							
should be able to describe the level of activity for each console, including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ. A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [IHL Only] See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
including (in cases of control rooms with multiple consoles) which console has the most activity and which has the least. • For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection slarms. FAQ. A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HI. Only] See Advisory Bulletin ADB—10–01, "Leak Detection on Hazardous Liquid Pipeliness" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
Por continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/night shifts. If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [IHL Only] See Advisory Bulletin ADB—10–01, "Leak Detection on Hazardous Liquid Pipeliness' dated January 26, 2010 (75 Fr R 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
For continuous operations, operator should be able to describe the differences in the level of activity during weekdays/weekends, and during day/hight shifts. If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities on ot undermine pipeline safety. Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. Criteria for acceptable controller performance in response to alarms. Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. [HL Only] See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undemine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB—10—01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a		console has the most activity and which has the least.					
differences in the level of activity during weekdays/weekends, and during day/night shifts. • If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undemine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB—10—01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a		For each to the contract of th					
during day/night shifts. If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
If the operator has added any significant assets or SCADA points since the previous review, the operator must account for this change in the next workload review. If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. Criteria for acceptable controller performance in response to alarms. Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. Interview Interview Interview Interview							
since the previous review, the operator must account for this change in the next workload review. • If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
change in the next workload review. If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. Criteria for acceptable controller performance in response to alarms. Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. IHL Onlyl See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
If the operator has impressed other activities, not related to pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. Criteria for acceptable controller performance in response to alarms. Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. If HL Only] See Advisory Bulletin ADB=10-01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
pipeline operation, onto the controller position, the operator should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB—10–01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
should ascertain these activities do not undermine pipeline safety. • Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB—10–01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
Measurement of workload should be performed during all periods of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
of time, seasons, and shifts to account for variations in overall demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB—10—01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
demands on controllers. What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
What other tasks are you assigned in addition to monitoring the system? E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a	M/hat o						
E5-3: Does the operator's program have a means of determining that the controller has sufficient time to analyze and react to incoming alarms? • Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. • Criteria for acceptable controller performance in response to alarms. • Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. • [HL Only] See Advisory Bulletin ADB—10—01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). • Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
Controller has sufficient time to analyze and react to incoming alarms? Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. Criteria for acceptable controller performance in response to alarms. Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. [HL Only] See Advisory Bulletin ADB—10—01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a				1			
Controller response metrics associated with alarm handling such as frequency of alarms (typically alarms per shift) received per console. Criteria for acceptable controller performance in response to alarms. Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. [HL Only] See Advisory Bulletin ADB—10—01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a	E5-3:			SAT		SAT	
frequency of alarms (typically alarms per shift) received per console. Criteria for acceptable controller performance in response to alarms. Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. HL Only] See Advisory Bulletin ADB–10–01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a		controller has sufficient time to analyze and react to incoming alarms?		UNSAT		UNSAT	
frequency of alarms (typically alarms per shift) received per console. Criteria for acceptable controller performance in response to alarms. Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. HL Only] See Advisory Bulletin ADB–10–01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
console. Criteria for acceptable controller performance in response to alarms. Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. Interview [HL Only] See Advisory Bulletin ADB—10—01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a						01	
 Criteria for acceptable controller performance in response to alarms. Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. [HL Only] See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a 							
alarms. Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. [HL Only] See Advisory Bulletin ADB—10—01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a						Records	
 Operators should place particular importance on proper and timely response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. [HL Only] See Advisory Bulletin ADB-10-01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a 							
response to leak detection alarms. FAQ A.15 clarifies that leak detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. Interview IHL Only] See Advisory Bulletin ADB–10–01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
detection systems, batch tracking systems and other special applications can be considered as an extension of the SCADA System and subject to CRM requirements. Interview HL Only] See Advisory Bulletin ADB–10–01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
applications can be considered as an extension of the SCADA System and subject to CRM requirements. Interview [HL Only] See Advisory Bulletin ADB–10–01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
System and subject to CRM requirements. Interview [HL Only] See Advisory Bulletin ADB–10–01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
 [HL Only] See Advisory Bulletin ADB–10–01, "Leak Detection on Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a 						l	
Hazardous Liquid Pipelines" dated January 26, 2010 (75 FR 4134). Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a						Interview	
 Operators may identify relevant alarm management practices by consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a 							
consulting with applicable industry standards such as International Society of Automation (ISA) 18. Analysis of increased activity as a							
Society of Automation (ISA) 18. Analysis of increased activity as a		, , ,					
result of failures, fiear filisses, effors, operating experience, of							
		result of failures, flear fillisses, effors, operating experience, of					

	lessons learned and how they relate to volume of work.	
	FAQ E.08. Operators should identify the workload threshold that	
	would lead to adding controllers and/or consoles.	
	Operators should document the results of the workload analysis	
	and document the number of controllers and consoles needed to	
	safety manage workload.	
	FAQ E.07. Credible reviews should identify the need to make	
	adjustments as workload increases. Inspections should include	
	discussions about any changes in the number of consoles in the	
	past year, and if the operator has plans to change the workload on	
	any console.	
	• FAQs E.09 and E.13.	
	How many alarms do you typically see in a shift?	
	now many diarms do you typicany see in a sinit!	
	Do you feel you have enough time to recognize and react to alarms	
	as they come in?	
ı		

192.631(f) Change management. Each operator must assure that changes that could affect control room operations are coordinated with the control room personnel by performing each of the following:

(1) Establish communications between control room representatives, operator's management, and associated field personnel when planning and implementing physical changes to pipeline equipment or configuration;

Inspectio	spection Question		Procedures		ementation	Inspector Notes
F1-4:	[Gas ONLY] Does the operator have a procedure to assure changes in	5	SAT		SAT	
	field equipment that could affect control room operations are	ι	UNSAT		UNSAT	
	coordinated with the control room personnel?	1	N/A (HL)		N/A (HL)	
	FAQs F.01 and F.02. Procedures should include guidance or a				Observed	-
	description of what changes in field equipment would constitute				Records	-
	the need to invoke change management provisions.				Interview	-
How a	 Management of Change process must also assure that controller training is updated to reflect the change and that controllers are adequately trained, as needed, on changes before the changes are placed into operation. There should be a procedure to manage SCADA and data communications maintenance or configuration activities to assure controllers are aware of, review, and provide input, in advance of work. The change management procedure should also be implemented when temporary changes are no longer necessary and operations are returned to normal. 					
F1-5:	[Gas ONLY] Is there a procedure to mandate a control room	9	SAT		SAT	
	representative will participate in meetings where changes that could		UNSAT		UNSAT	
	directly or indirectly affect the hydraulic performance of the pipeline	1	N/A (HL)		N/A (HL)	
	(including routine maintenance and repairs) are being considered,					
	designed and implemented?				Observed	
					Records	
	 The control room representative must have sufficient technical and 				Interview	

	procedural familiarity with control room activities to adequately
	perform this task.
•	The control room representative must adequately communicate
	related information to all impacted controllers.
•	Records should include meeting topics and communiqué created
	for controllers.
Are you incl	uded in meetings or notified of changes that could
affect the or	peration of the system?
How often	does this occur?
now often c	ides tills occur:

192.631(f)(2) Require its field personnel to contact the control room when emergency conditions exist and when making field changes that affect control room operations; and

Inspection			Procedures		lementation	Inspector Notes
F2-1:	Does the operator have a process or procedure to require its field personnel and SCADA support personnel to contact the control room when emergency conditions exist?		SAT		SAT UNSAT	
	Field personnel must communicate with the control room				Observed Records	
	immediately upon discovery of an emergency condition.				Interview	
	 Records must demonstrate that field personnel have contacted the control room whenever emergency conditions existed. 					
	o field personnel and SCADA support personnel unicate with the controller during emergency conditions?					
F2-2:	Does the operator have and implement a procedure to require its field		SAT		SAT	
	personnel and SCADA support personnel to contact the control room		UNSAT		UNSAT	
	when making field changes (for example, moving a valve) that affect					
	control room operations?				Observed]
					Records	
	 Field personnel must communicate with the control room before any equipment is being put into local control or returned to remote control. 				Interview	
	 Field personnel must communicate with the control room before any equipment is being taken out of service or returned to service. Field personnel should alert the control room before personnel enter a SCADA-controlled facility (including but not limited to 					
	compressor/pump stations, meter stations, main-line valves, etc.), which is normally unattended.					
	 Field personnel should be trained to call the controller when making field changes that have the potential to affect control room operations. 					
Do fiel	d personnel and SCADA support personnel communicate					
inform	ation to the control room when field changes are being					
made	that could affect control room operations?					
How a	re those communications done?					

192.631(f)(3) Seek control room or control room management participation in planning prior to implementation of significant pipeline hydraulic or configuration changes.

Inspectio	n Question	Procedures		Implementation		Inspector Notes
F3-1:	[Gas ONLY] Does management include control room or control room		SAT		SAT	
	management participation in planning, prior to the implementation of		UNSAT		UNSAT	
	significant pipeline hydraulic or configuration changes?		N/A (HL)		N/A (HL)	
Are yo	ou included in planning, prior to the implementation of				Observed	
					Records	

significant system changes?		Interview	

192.631(g) Operating experience. Each operator must assure that lessons learned from its operating experience are incorporated, as appropriate, into its control room management procedures by performing each of the following:

(1) Review incidents that must be reported pursuant to 49 CFR part 191 to determine if control room actions contributed to the event and, if so, correct, where necessary, deficiencies related to: (i) Controller fatigue; (ii) Field equipment; (iii) The operation of any relief device; (iv) Procedures; (v) SCADA system configuration; and (vi) SCADA system performance.

Inspection	Inspection Question		Implementation	Inspector Notes
G1-1:	Does the operator employ a formal, structured approach for reviewing	SAT	SAT	
	and critiquing reportable events to identify lessons learned?	UNSAT	UNSAT	
	Operator must incorporate a methodology to determine the cause		Observed	
	of the event.		Records	
	 Event cause analysis includes analysis of the potential contribution of controller or control room decisions/actions to the event. A root cause analysis process should be used when applicable. 		Interview	
	 Secondary or contributing causes should be addressed. 			
	 Operator should address potential contribution of erroneous training. 			
	 When applicable, the operator's review and critique of actual failure experience should critique the adequacy of SCADA design and performance of both the primary and back-up systems. 			
	reportable event is meeting conducted analyze the actions			
perfor	med and to determine lessons learned?			

192.631(g)(2) Include lessons learned from the operator's experience in the training program required by this section.

Inspection	nspection Question		Procedures		lementation	Inspector Notes
G2-1:	Is training provided on lessons learned from a broad range		SAT		SAT	
	of events, even though the control room may not have		UNSAT		UNSAT	
	been at fault?					
	been at laute:				Observed	
					Records	
					Interview	

192.631(h) Training. Each operator must establish a controller training program and review the training program content to identify potential improvements at least once each calendar year, but at intervals not to exceed 15 months. An operator's program must provide for training each controller to carry out the roles and responsibilities defined by the operator. In addition, the training program must include the following elements:

Inspection	Question	Procedures		ures Implementation		Inspector Notes
H0-1:	Has the operator established and implemented a controller training		SAT		SAT	
	program to provide training for each controller to carry out their roles		UNSAT		UNSAT	
	and responsibilities?		N/A		N/A	
	 CRM training program must provide training as appropriate to ensure that individuals performing "controller" activities (i.e., covered tasks) have the necessary knowledge and skills to perform 					
					Observed	
					Records	
					Interview	

the tasks in a manner that ensures the safe operation of pipeline facilities.		
 Records must demonstrate that each controller has successfully completed the controller OQ and CRM training program, including requalification training. 		
 Records must include names and dates of training. 		
All elements of OQ and CRM training must be documented on		
training records.Training program can address cross-training on consoles not	UNSAT	UNSAT
normally used, but cross-training to other consoles is not required.	N/A	N/A
What training have you had for performing your duties as a		
controller?		Observed
		Records
		Interview

192.631(h)(2) Use of a computerized simulator or non-computerized (tabletop) method for training controllers to recognize abnormal operating conditions;

Inspection Question	Procedures	Implementation	Inspector Notes
H2-1: Does the operator's training program use a simulator or tabletop	SAT	SAT	
exercises to train controllers how to recognize and respond to	UNSAT	UNSAT	
 abnormal operating conditions? Operators must use either or both computerized and non-computerized (tabletop) method for simulator training. The training must require that controllers demonstrate proficiency in recognizing and responding to abnormal conditions based on actual scenarios from reportable accidents/incidents and likely abnormal situations in order to prevent or mitigate future similar conditions. Operators are not required to use of a computerized training simulator. Well thought out and interactive tabletop exercises are likely to be used by smaller operators. If computerized simulators are used, consoles should be clearly labeled to avoid controller/trainee from confusing a live console with a training console. Use of simulator should be more than just interacting with SCADA system. Simulator training should also include use of related operational and emergency procedures and interaction with others. Have you gone through a simulation of abnormal operating conditions during this training? How is this done? 	Simulator Tabletop	Observed Records Interview	

192.631(h)(3) Training controllers on their responsibilities for communication under the operator's emergency response procedures;

Inspection	n Question	Procedures		ures Implementation		Inspector Notes
H3-1:	Does the operator's program train controllers on their responsibilities		SAT		SAT	
	for communication under the operator's emergency response		UNSAT		UNSAT	
	procedures?		N/A		N/A	
	The training program must require that controllers demonstrate				Observed	
	knowledge and proficiency in communicating during an				Records	

emergency.		Interview	
The operator should have controllers participate in			
accident/incident drills.			
Have you had training on communication during an emergency			
response situation? What is the process for this communication?			

192.631(h)(4) Training that will provide a controller a working knowledge of the pipeline system, especially during the development of abnormal operating conditions; and

Inspection Question		Procedures		Implementation		Inspector Notes
H4-1:	Does the operator training program provide controllers a working		SAT		SAT	
	knowledge of the pipeline system, especially during the development of		UNSAT		UNSAT	
	abnormal operating conditions?		N/A		•	
					Observed	
	 Training must ensure that controllers have practical knowledge of how fluid dynamics, electrical power, communications, etc. impact operations. 				Records	
					Interview]
	 Training must include information about how pressure and flow in all pipeline segments are impacted by control actions. 					
	 Training must include any facilities that are different than typical. 					
	 Training should include information (within the controller's domain of responsibility) about flexibility and limitations at inlet points, mainline valves, stations and delivery points. 					
	 Training must include MAOPs/MOPs, and any imposed lower pressures, on all pipeline segments. 					
What training have you had regarding how the gas system						
operat	t <mark>es?</mark>					